
ADDRESS . . : 150 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER . . . : STANCIL BUILDERS INC
PARCEL . . . : 03-9597- - -0225- -02-
APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II #120.
27W, LEFT ON DOCS RD, RIGHT ON MICRO
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/17/2008 03:06 PM VBROWN ----
****CUSTOMER SUBMIT NEW PLANS FOR HOUSE
4-20-09 CUSTOMER STATES IT IS STILL
40X60 WITH SAME SET BACKS JUST
DIFFERENT HOUSE PLAN.
T/S: 04/20/2009 09:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/09 <u>4-22-9</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758592

COMMENTS AND NOTES

ADDRESS : 150 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -02-
APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II #120.
27W, LEFT ON DOCS RD, RIGHT ON MICRO
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/17/2008 03:06 PM VBROWN ----
****CUSTOMER SUBMIT NEW PLANS FOR HOUSE
4-20-09 CUSTOMER STATES IT IS STILL
40X60 WITH SAME SET BACKS JUST
DIFFERENT HOUSE PLAN.
T/S: 04/20/2009 09:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758592
	4/22/09	AP	
B103 01	5/06/09	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764344
	<i>5/6/09</i>	<i>AP-MR</i>	

COMMENTS AND NOTES

ADDRESS : 150 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -02-
APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II #120.
27W, LEFT ON DOCS RD, RIGHT ON MICRO
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/17/2008 03:06 PM VBROWN ----
****CUSTOMER SUBMIT NEW PLANS FOR HOUSE
4-20-09 CUSTOMER STATES IT IS STILL
40X60 WITH SAME SET BACKS JUST
DIFFERENT HOUSE PLAN.
T/S: 04/20/2009 09:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758592
	4/22/09	AP	
B103 01	5/06/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764344
	5/06/09	AP	
B105 01	5/26/09	TI	R*OPEN FLOOR VRU #: 001771737
	<u>5 26 9</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS : 150 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -02-
APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II #120.
27W, LEFT ON DOCS RD, RIGHT ON MICRO
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/17/2008 03:06 PM VBROWN ----
****CUSTOMER SUBMIT NEW PLANS FOR HOUSE
4-20-09 CUSTOMER STATES IT IS STILL
40X60 WITH SAME SET BACKS JUST
DIFFERENT HOUSE PLAN.
T/S: 04/20/2009 09:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758592
	4/22/09	AP	
B103 01	5/06/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764344
	5/06/09	AP	
B105 01	5/26/09	MR	R*OPEN FLOOR VRU #: 001771737
	5/26/09	AP	
A814 01	6/04/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777572
R425 01	6/05/09	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001777598
	6-5-9	DA-MR	

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 06-05-09

PERMIT# 08-50019877

ADDRESS: 150 true blue

VIOLATIONS:

1. Install flashing at front door for porch and under front door
2. Finish shingles and boots
3. Remove low volt wire from fireplace switch box.. no low and high allowed in same box
4. Fireblock 2nd floor from attic
5. Tempered window required on stairs

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 150 TRUE BLUE DR
 CONTRACTOR : STANCIL BUILDERS INC.
 OWNER : STANCIL BUILDERS INC
 PARCEL : 03-9597- - -0225- -02-
 APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : PATTONS POINT II #120.
 27W, LEFT ON DOCS RD, RIGHT ON MICRO
 TOWER RD, SUB DIV ON RIGHT.
 T/S: 04/17/2008 03:06 PM VBROWN ----
 ****CUSTOMER SUBMIT NEW PLANS FOR HOUSE
 4-20-09 CUSTOMER STATES IT IS STILL
 40X60 WITH SAME SET BACKS JUST
 DIFFERENT HOUSE PLAN.
 T/S: 04/20/2009 09:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
 PHONE : (919) 639-2073
 PHONE :

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758592
	4/22/09	AP	
B103 01	5/06/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764344
	5/06/09	AP	
B105 01	5/26/09	MR	R*OPEN FLOOR VRU #: 001771737
	5/26/09	AP	
A814 01	6/04/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777572
	6/08/09	AP	150 true blue dr lot 120 broadway 27505
R425 01	6/05/09	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001777598
	6/05/09	DA	1 install flashing at front door and porch 2 remove low volt wire from hi volt box at fireplace 3 tempered window needed on stairs 4 all grounds must be tied together
R425 02	6/10/09	TI	FOUR TRADE ROUGH IN VRU #: 001779365
	6.10.9	AP-MR	

COMMENTS AND NOTES

ADDRESS : 150 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -02-
APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

DIRECTIONS : PATTONS POINT II #120.
27W, LEFT ON DOCS RD, RIGHT ON MICRO
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/17/2008 03:06 PM VBROWN ----
****CUSTOMER SUBMIT NEW PLANS FOR HOUSE
4-20-09 CUSTOMER STATES IT IS STILL
40X60 WITH SAME SET BACKS JUST
DIFFERENT HOUSE PLAN.
T/S: 04/20/2009 09:53 AM VBROWN ----

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758592
	4/22/09	AP	
B103 01	5/06/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764344
	5/06/09	AP	
B105 01	5/26/09	MR	R*OPEN FLOOR VRU #: 001771737
	5/26/09	AP	
A814 01	6/04/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777572
	6/08/09	AP	150 true blue dr lot 120 broadway 27505
R425 01	6/05/09	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001777598
	6/05/09	DA	install flashing at front door and porch 2. remove low volt wire from hi volt box at fireplace 3. tempered window needed on stairs 4. all grounds must be tied together
R425 02	6/10/09	MR	FOUR TRADE ROUGH IN VRU #: 001779365
	6/10/09	AP	
I129 01	6/11/09	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001780493

6.11.9 AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 150 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -02-
APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

DIRECTIONS : PATTONS POINT II #120.
27W, LEFT ON DOCS RD, RIGHT ON MICRO
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/17/2008 03:06 PM VBROWN ----
****CUSTOMER SUBMIT NEW PLANS FOR HOUSE
4-20-09 CUSTOMER STATES IT IS STILL
40X60 WITH SAME SET BACKS JUST
DIFFERENT HOUSE PLAN.
T/S: 04/20/2009 09:53 AM VBROWN ----

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758592
	4/22/09	AP	
B103 01	5/06/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764344
	5/06/09	AP	
B105 01	5/26/09	MR	R*OPEN FLOOR VRU #: 001771737
	5/26/09	AP	
A814 01	6/04/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777572
	6/08/09	AP	150 true blue dr lot 120 broadway 27505
R425 01	6/05/09	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001777598
	6/05/09	DA	install flashing at front door and porch 2. remove low volt wire from hi volt box at fireplace 3. tempered window needed on stairs 4. all grounds must be tied together
R425 02	6/10/09	MR	FOUR TRADE ROUGH IN VRU #: 001779365
	6/10/09	AP	
I129 02	6/11/09	TI	R*INSULATION INSPECTION VRU #: 001780068
	6/24/09	CA	T/S: 06/24/2009 02:10 PM NTART -----
I129 01	6/11/09	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001780493
	6/11/09	AP	tempered window still need at final on stairs
R325 01	6/25/09	TI	THREE TRADE ROUGH IN VRU #: 001786044

6-24-9 AP-MR

COMMENTS AND NOTES

For Bonus Room Area

ADDRESS . . : 150 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER . . . : STANCIL BUILDERS INC
PARCEL . . . : 03-9597- - -0225- -02-
APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II #120.
27W, LEFT ON DOCS RD, RIGHT ON MICRO
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/17/2008 03:06 PM VBROWN ----
****CUSTOMER SUBMIT NEW PLANS FOR HOUSE
4-20-09 CUSTOMER STATES IT IS STILL
40X60 WITH SAME SET BACKS JUST
DIFFERENT HOUSE PLAN.
T/S: 04/20/2009 09:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPIR 00 CP INSULATION RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	6/26/09 " "	TI <i>ap mr</i>	R*INSULATION INSPECTION VRU #: 001786650

----- COMMENTS AND NOTES -----

ADDRESS : 150 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -02-
APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	7/06/09	AP	T/S: 07/07/2009 11:02 AM SSTEWARD ----- T/S: 07/07/2009 11:02 AM SSTEWARD -----
M305 01	7/15/09 7-15-09	TI AP AP	R*PLUMB SEWER CONNECTION VRU #: 001794473
P307 01	7/15/09 7-15-09	TI AP AP	R*PLUMB WATER CONNECTION VRU #: 001794482

COMMENTS AND NOTES

ADDRESS : 150 TRUE BLUE DR SUBDIV: PATTONS POINT PH 2 73LOTS
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
 OWNER : STANCIL BUILDERS INC. PHONE :
 PARCEL : 03-9597- - -0225- -02-
 APPL NUMBER: 08-50019877 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : PATTONS POINT II #120.
 27W, LEFT ON DOCS RD, RIGHT ON MICRO
 TOWER RD, SUB DIV ON RIGHT.
 T/S: 04/17/2008 03:06 PM VBROWN ----
 ****CUSTOMER SUBMIT NEW PLANS FOR HOUSE
 4-20-09 CUSTOMER STATES IT IS STILL
 40X60 WITH SAME SET BACKS JUST
 DIFFERENT HOUSE PLAN.
 T/S: 04/20/2009 09:53 AM VBROWN ----

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758592
	4/22/09	AP	
B103 01	5/06/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764344
	5/06/09	AP	
B105 01	5/26/09	MR	R*OPEN FLOOR VRU #: 001771737
	5/26/09	AP	
A814 01	6/04/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777572
	6/08/09	AP	✓ 150 true blue dr lot 120 broadway 27505
R425 01	6/05/09	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001777598
	6/05/09	DA	install flashing at front door and porch 2. remove low volt wire from hi volt box at fireplace 3. tempered window needed on stairs 4. all grounds must be tied together
R425 02	6/10/09	MR	FOUR TRADE ROUGH IN VRU #: 001779365
	6/10/09	AP	
I129 02	6/11/09	TI	R*INSULATION INSPECTION VRU #: 001780068
	6/24/09	CA	T/S: 06/24/2009 02:10 PM NTART -----
I129 01	6/11/09	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001780493
	6/11/09	AP	tempered window still need at final on stairs
R325 01	6/25/09	MR	THREE TRADE ROUGH IN VRU #: 001786044
	6/25/09	AP	
H824 01	7/06/09	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001791136
	7/06/09	AP	T/S: 07/07/2009 11:02 AM SSTEWARD ----- T/S: 07/07/2009 11:02 AM SSTEWARD -----
M305 01	7/15/09	TI	R*PLUMB SEWER CONNECTION VRU #: 001794473
	<u>7-15</u>	<u>AP</u>	
P307 01	7/15/09	TI	R*PLUMB WATER CONNECTION VRU #: 001794482
	<u>7-15</u>	<u>AP</u>	
R429 01	7/16/09	TA	FOUR TRADE FINAL VRU #: 001795105
	<u>7-16</u>	<u>AP</u>	

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: Steel Building Building Permit No.: _____
Owner of Building: _____ Electrical Permit No.: _____
Building Address: 150 True Blue Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: _____ Mech. Permit No.: _____
Date: 7-16-09 Envir. C.O. No.: 08-50019877
Ke Slatts Building Official _____ Zoning Official