

-----  
ADDRESS . . : 27 TRUE BLUE DR  
CONTRACTOR : STANCIL BUILDERS INC.  
OWNER . . . : STANCIL BUILDERS INC  
PARCEL . . . : 03-9597- - -0225- -32-  
APPL NUMBER: 08-50019881 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : PATTONS POINT II SUB DIV #152  
27W, LEFT ON DOCS RD, RIGHT ON MICRO  
TOWER RD, SUB DIV ON RIGHT.  
T/S: 04/18/2008 08:50 AM VBROWN -----

SUBDIV: PATTONS POINT PH 2 73LOTS  
PHONE : (919) 639-2073  
PHONE :

-----  
**STRUCTURE: 000 000 40X60 3BDR 2BATH SFD**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 3.00 PROPOSED USE . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW SEPTIC

-----  
**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/09 <u>4-23-9</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758841

----- COMMENTS AND NOTES -----

ADDRESS : 27 TRUE BLUE DR  
CONTRACTOR : STANCIL BUILDERS INC.  
OWNER : STANCIL BUILDERS INC  
PARCEL : 03-9597- - -0225- -32-  
APPL NUMBER: 08-50019881 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : PATTONS POINT II SUB DIV #152  
27W, LEFT ON DOCS RD, RIGHT ON MICRO  
TOWER RD, SUB DIV ON RIGHT.  
T/S: 04/18/2008 08:50 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS  
PHONE : (919) 639-2073  
PHONE :

**STRUCTURE: 000 000 40X60 3BDR 2BATH SFD**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW SEPTIC

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758841
	4/23/09	AP	
B103 01	5/26/09	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772335

5269 ~~MR~~  
~~DA~~ ~~AP~~ ~~MR~~

COMMENTS AND NOTES

*No Plot Plan on site*

ADDRESS : 27 TRUE BLUE DR  
CONTRACTOR : STANCIL BUILDERS INC.  
OWNER : STANCIL BUILDERS INC  
PARCEL : 03-9597- - -0225- -32-  
APPL NUMBER: 08-50019881 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : PATTONS POINT II SUB DIV #152  
27W, LEFT ON DOCS RD, RIGHT ON MICRO  
TOWER RD, SUB DIV ON RIGHT.  
T/S: 04/18/2008 08:50 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS  
PHONE : (919) 639-2073  
PHONE :

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00  
SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758841
	4/23/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772335
	5/26/09	AP	
A814 01	6/10/09	TI	ADDRESS CONFIRMATION VRU #: 001777465
B105 01	6/18/09	TI	R*OPEN FLOOR VRU #: 001782994
	<u>6-18-9</u>	<u>AP-MR</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 27 TRUE BLUE DR  
CONTRACTOR : STANCIL BUILDERS INC.  
OWNER : STANCIL BUILDERS INC  
PARCEL : 03-9597- - -0225- -32-  
APPL NUMBER: 08-50019881 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : PATTONS POINT II SUB DIV #152  
27W, LEFT ON DOCS RD, RIGHT ON MICRO  
TOWER RD, SUB DIV ON RIGHT.  
T/S: 04/18/2008 08:50 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS  
PHONE : (919) 639-2073  
PHONE :

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00  
SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758841
	4/23/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772335
	5/26/09	AP	
A814 01	6/10/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777465
	6/18/09	AP	27 TRUE BLUE DR LOT 152 BROADWAY 27505
B105 01	6/18/09	MR	R*OPEN FLOOR VRU #: 001782994
	6/18/09	AP	
H824 01	7/09/09	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001793470
	7/09/09	AP	T/S: 07/13/2009 10:11 AM SSTEWARD ----- T/S: 07/13/2009 10:11 AM SSTEWARD -----
R425 01	7/17/09	TI	FOUR TRADE ROUGH IN VRU #: 001796006
	<u>7-17</u>	<u>DA</u>	

COMMENTS AND NOTES

**Violation Notice  
Do Not Remove**

**Harnett County Inspection Department  
102 East Front St P.O. Box 65  
Lillington, NC 27546  
Phone (910) 893-7525 Fax (910) 893-2793**

08-50019881

July 17, 2009

1. Floor joist over-notched for 3 inch toilet drain..

**Ken Slattum**

ADDRESS : 27 TRUE BLUE DR  
 CONTRACTOR : STANCIL BUILDERS INC.  
 OWNER : STANCIL BUILDERS INC  
 PARCEL : 03-9597- - -0225- -32-  
 APPL NUMBER: 08-50019881 CP NEW RESIDENTIAL (SFD)

SUBDIV: PATTONS POINT PH 2 73LOTS  
 PHONE : (919) 639-2073  
 PHONE :

DIRECTIONS : PATTONS POINT II SUB DIV #152  
 27W, LEFT ON DOCS RD, RIGHT ON MICRO  
 TOWER RD, SUB DIV ON RIGHT.  
 T/S: 04/18/2008 08:50 AM VBROWN ----

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW SEPTIC

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758841
	4/23/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772335
	5/26/09	AP	
A814 01	6/10/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777465
	6/18/09	AP	27 TRUE BLUE DR LOT 152 BROADWAY 27505
B105 01	6/18/09	MR	R*OPEN FLOOR VRU #: 001782994
	6/18/09	AP	
H824 01	7/09/09	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001793470
	7/09/09	AP	T/S: 07/13/2009 10:11 AM SSTEWARD ----- T/S: 07/13/2009 10:11 AM SSTEWARD -----
R425 01	7/17/09	KS	FOUR TRADE ROUGH IN VRU #: 001796006
	7/17/09	DA	50 % of floor joist notched beneath toildt flange. T/S: 07/17/2009 12:32 PM KSLATTUM -----
I129 01	7/21/09	TI	R*INSULATION INSPECTION VRU #: 001797586
	<u>7.21.9</u>	<u>AP-MR</u>	
R425 02	7/21/09	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001797737
	<u>7.21.9</u>	<u>AP-MR</u>	T/S: 07/20/2009 02:16 PM NTART -----

COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

DATE 11/02/09

-----

ADDRESS . . : 27 TRUE BLUE DR SUBDIV: PATTONS POINT PH 2 73LOTS  
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073  
 OWNER . . : STANCIL BUILDERS INC PHONE :  
 PARCEL . . : 03-9597- - -0225- -32-  
 APPL NUMBER: 08-50019881 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : PATTONS POINT II SUB DIV #152  
 27W, LEFT ON DOCS RD, RIGHT ON MICRO  
 TOWER RD, SUB DIV ON RIGHT.  
 T/S: 04/18/2008 08:50 AM VBROWN ----

-----

**STRUCTURE: 000 000 40X60 3BDR 2BATH SFD**  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW SEPTIC

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758841
	4/23/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772335
	5/26/09	AP	
A814 01	6/10/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777465
	6/18/09	AP	27 TRUE BLUE DR LOT 152 BROADWAY 27505
B105 01	6/18/09	MR	R*OPEN FLOOR VRU #: 001782994
	6/18/09	AP	
H824 01	7/09/09	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001793470
	7/09/09	AP	T/S: 07/13/2009 10:11 AM SSTEWARD ----- T/S: 07/13/2009 10:11 AM SSTEWARD -----
R425 01	7/17/09	KS	FOUR TRADE ROUGH IN VRU #: 001796006
	7/17/09	DA	50 % of floor joist notched beneath toildt flange. T/S: 07/17/2009 12:32 PM KSLATTUM -----
I129 01	7/21/09	MR	R*INSULATION INSPECTION VRU #: 001797586
	7/21/09	AP	T/S: 07/21/2009 02:24 PM MREARIC -----
R425 02	7/21/09	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001797737
	7/21/09	AP	T/S: 07/20/2009 02:16 PM NTART ----- T/S: 07/21/2009 02:24 PM MREARIC -----
R429 01	10/30/09	KS	FOUR TRADE FINAL VRU #: 001843697
	10/30/09	CA	T/S: 10/30/2009 07:49 AM KSLATTUM -----
R429 02	11/02/09	TI	FOUR TRADE FINAL VRU #: 001844561

11/2/9 DP-MR

----- COMMENTS AND NOTES -----

# **HARNETT COUNTY**

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

**DO NOT REMOVE**

DATE: 11-02-09

PERMIT # 08-50019881

ADDRESS: 27 true blue

## VIOLATIONS:

1. Finish light in kitchen
2. Install outlets on both porches
3. Water heater needs a shut off valve
4. Water heater needs a disconnecting means
5. Relief line is to run to outside the crawlspace
6. Boots on ac floor ducts are not insulated
  
- 7.

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772



Harnett, County

INSPECTOR: IVR

DATE 11/06/09

-----

ADDRESS . . : 27 TRUE BLUE DR  
 CONTRACTOR : STANCIL BUILDERS INC.  
 OWNER . . . : STANCIL BUILDERS INC  
 PARCEL . . . : 03-9597- - -0225- -32-  
 APPL NUMBER: 08-50019881 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : PATTONS POINT II SUB DIV #152  
 27W, LEFT ON DOCS RD, RIGHT ON MICRO  
 TOWER RD, SUB DIV ON RIGHT.  
 T/S: 04/18/2008 08:50 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS  
 PHONE : (919) 639-2073  
 PHONE :

-----

STRUCTURE: 000 000 40X60 3BDR 2BATH SFD  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00  
 SEPTIC - EXISTING? . . . . : NEW SEPTIC

PROPOSED USE . . . . . : SFD

PERMIT: CPSP 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001758841
	4/23/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772335
	5/26/09	AP	
A814 01	6/10/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777465
	6/18/09	AP	✓ 27 TRUE BLUE DR LOT 152 BROADWAY 27505
B105 01	6/18/09	MR	R*OPEN FLOOR VRU #: 001782994
	6/18/09	AP	
H824 01	7/09/09	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001793470
	7/09/09	AP	T/S: 07/13/2009 10:11 AM SSTEWARD ----- T/S: 07/13/2009 10:11 AM SSTEWARD -----
R425 01	7/17/09	KS	FOUR TRADE ROUGH IN VRU #: 001796006
	7/17/09	DA	50 % of floor joist notched beneath toildt flange. T/S: 07/17/2009 12:32 PM KSLATTUM -----
I129 01	7/21/09	MR	R*INSULATION INSPECTION VRU #: 001797586
	7/21/09	AP	T/S: 07/21/2009 02:24 PM MREARIC -----
R425 02	7/21/09	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001797737
	7/21/09	AP	T/S: 07/20/2009 02:16 PM NTART ----- T/S: 07/21/2009 02:24 PM MREARIC -----
R429 01	10/30/09	KS	FOUR TRADE FINAL VRU #: 001843697
	10/30/09	CA	T/S: 10/30/2009 07:49 AM KSLATTUM -----
R429 02	11/02/09	MR	FOUR TRADE FINAL VRU #: 001844561
	11/02/09	DP	T/S: 11/02/2009 10:24 AM MREARIC ----- <del>1.</del> finish light in kitchen <del>2.</del> install outlets on both porches <del>3.</del> water needs shut off valve <del>4.</del> water heater needs disconnect <del>5.</del> relief line is to run outside the foundation <del>6.</del> ac boots on floor are not insulated
R429 03	11/06/09	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001846963
	11-6-9	AP-MR	T/S: 11/05/2009 10:52 AM VBROWN -----

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Conditional Use Permit No.: \_\_\_\_\_

Type of Construction: II

Building Permit No.: 08-50014881

Owner of Building: Stensel Builders

Electrical Permit No.: 11

Building Address: 27 True Blue

Insulation Permit No.: 11

Zoning District: \_\_\_\_\_

Plumbing Permit No.: 11

Zoning Permit No.: \_\_\_\_\_

Mech. Permit No.: 11

Envir. C.O. No.: \_\_\_\_\_

Date: 11-6-9

T. Mould Ream

Building Official

Zoning Official