

ADDRESS . . : 15 ABRAM CT
CONTRACTOR : STANCIL BUILDERS INC.
OWNER . . . : STANCIL BUILDERS INC
PARCEL . . . : 03-9597- - -0225- -33-
APPL NUMBER: 08-50019882 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II SUB DIV #154
27W, LEFT ON DOCS RD, RIGHT ON MICOR
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/18/2008 08:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR SFD CRAWL W/ GARAGE/DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/17/09 <u>4-17-09</u>	TI <u>AP-MP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001756530

----- COMMENTS AND NOTES -----

ADDRESS . . : 15 ABRAM CT
CONTRACTOR : STANCIL BUILDERS INC.
OWNER . . . : STANCIL BUILDERS INC
PARCEL . . . : 03-9597- - -0225- -33-
APPL NUMBER: 08-50019882 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II SUB DIV #154
27W, LEFT ON DOCS RD, RIGHT ON MICOR
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/18/2008 08:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR SFD CRAWL W/ GARAGE/DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/17/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001756530
	4/17/09	AP	
B103 01	5/26/09	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772353
	<u>5/26/09</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS : 15 ABRAM CT
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -33-
APPL NUMBER: 08-50019882 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II SUB DIV #154
27W, LEFT ON DOCS RD, RIGHT ON MICOR
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/18/2008 08:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR SFD CRAWL W/ GARAGE/DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/17/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001756530
	4/17/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772353
	5/26/09	AP	
A814 01	6/10/09	TI	ADDRESS CONFIRMATION VRU #: 001777474
B105 01	6/18/09	TI	R*OPEN FLOOR VRU #: 001782985

6/18/09 AP-MR

----- COMMENTS AND NOTES -----

Harnett County

INSPECTOR: IVR

DATE 7/28/09

ADDRESS : 55 TRUE BLUE DR
 CONTRACTOR : STANCIL BUILDERS INC.
 OWNER : STANCIL BUILDERS INC
 PARCEL : 03-9597- - -0225- -33-
 APPL NUMBER: 08-50019882 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : PATTONS POINT II SUB DIV #154
 27W, LEFT ON DOCS RD, RIGHT ON MICOR
 TOWER RD, SUB DIV ON RIGHT.
 T/S: 04/18/2008 08:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
 PHONE : (919) 639-2073
 PHONE :

STRUCTURE: 000 000 40X60 3BDR SFD CRAWL W/ GARAGE/DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/17/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001756530
	4/17/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772353
	5/26/09	AP	
A814 01	6/10/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777474
	6/18/09	AP	55 true blue dr broadway 27505
B105 01	6/18/09	MR	R*OPEN FLOOR VRU #: 001782985
	6/18/09	AP	
H824 01	7/08/09	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001792480
	7/08/09	AP	T/S: 07/09/2009 10:58 AM SSTEWARD ----- T/S: 07/09/2009 10:58 AM SSTEWARD -----
R425 01	7/28/09	TI	FOUR TRADE ROUGH IN VRU #: 001800830

7.28.9 DA-MR

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 07-28-09

PERMIT # 08-50019882

ADDRESS: 55 true blue

VIOLATIONS:

1. Nuts missing in garage sill plate
2. Wire for stove is too small for a 40 amp circuit
3. Tempered window needed in stairs
4. Ok to side and insulate

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 55 TRUE BLUE DR SUBDIV: PATTONS POINT PH 2 73LOTS
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
OWNER : STANCIL BUILDERS INC PHONE :
PARCEL : 03-9597- - -0225- -33-
APPL NUMBER: 08-50019882 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II SUB DIV #154
27W, LEFT ON DOCS RD, RIGHT ON MICOR
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/18/2008 08:53 AM VBROWN ----

STRUCTURE: 000 000 40X60 3BDR SFD CRAWL W/ GARAGE/DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/17/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001756530
	4/17/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772353
	5/26/09	AP	
A814 01	6/10/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777474
	6/18/09	AP	55 true blue dr broadway 27505
B105 01	6/18/09	MR	R*OPEN FLOOR VRU #: 001782985
	6/18/09	AP	
H824 01	7/08/09	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001792480
	7/08/09	AP	T/S: 07/09/2009 10:58 AM SSTEWARD ----- T/S: 07/09/2009 10:58 AM SSTEWARD -----
R425 01	7/28/09	MR	FOUR TRADE ROUGH IN VRU #: 001800830
	7/28/09	DA	T/S: 07/28/2009 01:18 PM MREARIC ----- 1. nuts missing in garage 2. wire to stove is too small 3. tempered window needed on stairs at final 4. ok to side and ins.
I129 01	7/30/09	TI	R*INSULATION INSPECTION VRU #: 001801964
	<u>7:30-9</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

Rough OK also

ADDRESS : 55 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -33-
APPL NUMBER: 08-50019882 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II SUB DIV #154
27W, LEFT ON DOCS RD, RIGHT ON MICOR
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/18/2008 08:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR SFD CRAWL W/ GARAGE/DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW SEPTIC

WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/17/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001756530
	4/17/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772353
	5/26/09	AP	
A814 01	6/10/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777474
	6/18/09	AP	55 true blue dr broadway 27505
B105 01	6/18/09	MR	R*OPEN FLOOR VRU #: 001782985
	6/18/09	AP	
H824 01	7/08/09	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001792480
	7/08/09	AP	T/S: 07/09/2009 10:58 AM SSTEWARD ----- T/S: 07/09/2009 10:58 AM SSTEWARD -----
R425 01	7/28/09	MR	FOUR TRADE ROUGH IN VRU #: 001800830
	7/28/09	DA	T/S: 07/28/2009 01:18 PM MREARIC ----- 1. nuts missing in garage 2. wire to stove is too small 3. tempered window needed on stairs at final 4. ok to side and ins.
I129 01	7/30/09	MR	R*INSULATION INSPECTION VRU #: 001801964
	7/30/09	AP	T/S: 07/30/2009 12:33 PM MREARIC ----- rough ok also
R429 01	8/20/09	TI	FOUR TRADE FINAL VRU #: 001811276

820.9 DP-MR

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 08-20-09

PERMIT # 08-50019882

ADDRESS: 55 true blue

VIOLATIONS:

1. House numbers
2. Bolts missing in garage
3. Finish room....what is it?
4. Receptacle needed on back porch
5. Fee 50.00

Harnett County Building Department

Mike Rearic cell# (910) 984-4772

ADDRESS : 55 TRUE BLUE DR
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -33-
APPL NUMBER: 08-50019882 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PATTONS POINT II SUB DIV #154
27W, LEFT ON DOCS RD, RIGHT ON MICOR
TOWER RD, SUB DIV ON RIGHT.
T/S: 04/18/2008 08:53 AM VBROWN ----

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 40X60 3BDR SFD CRAWL W/ GARAGE/DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/17/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001756530
	4/17/09	AP	
B103 01	5/26/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001772353
	5/26/09	AP	
A814 01	6/10/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001777474
	6/18/09	AP	✓ 55 true blue dr broadway 27505
B105 01	6/18/09	MR	R*OPEN FLOOR VRU #: 001782985
	6/18/09	AP	
H824 01	7/08/09	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001792480
	7/08/09	AP	T/S: 07/09/2009 10:58 AM S STEWART ----- T/S: 07/09/2009 10:58 AM S STEWART -----
R425 01	7/28/09	MR	FOUR TRADE ROUGH IN VRU #: 001800830
	7/28/09	DA	T/S: 07/28/2009 01:18 PM MREARIC ----- 1. nuts missing in garage 2. wire to stove is too small 3. tempered window needed on stairs at final 4. ok to side and ins.
I129 01	7/30/09	MR	R*INSULATION INSPECTION VRU #: 001801964
	7/30/09	AP	T/S: 07/30/2009 12:33 PM MREARIC ----- rough ok also
R429 01	8/20/09	MR	FOUR TRADE FINAL VRU #: 001811276
	8/20/09	DP	T/S: 08/20/2009 11:33 AM MREARIC ----- 1. numbers 2. bolts in garage 3. unfinished attic cannot have an ac outlet 4. door to attic must be weatherstripped 5. recept. on back porch needed
R429 02	8/21/09	TI	FOUR TRADE FINAL VRU #: 001811793

8/21/09 AP-MR

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Owner: Stancil Builders

911 Address: _____

55 True Blue

State: _____ Zip Code: _____

Date: 8-21-9

W. Michael Ream

Building Official

PERMIT NUMBERS

Building Permit No.: 08-50019882

Electrical Permit No.: 11

Insulation Permit No.: "

Plumbing Permit No.: 1

Mech. Permit No.: "

MFG. Home: _____