

ADDRESS : 88505 *UNASSIGNED
CONTRACTOR : SERENITY BUILT HOMES INC
OWNER : FRYE RANDY & MARIA
PARCEL : 10-0578- - -0050- -01-
APPL NUMBER: 08-50019925 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TRUN LEFT ON PRISON CAMP RD GO APPROX
2.9 MILES ON LEFT JB

SUBDIV:
PHONE : (910) 893-2462
PHONE : (910) 984-7042

STRUCTURE: 000 000 74X50.4 SFD CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/23/08	TI <i>AP JH</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001614088 <i>before SK: school on Left</i>

COMMENTS AND NOTES

ADDRESS . : 2865 ROSS RD SUBDIV:
CONTRACTOR : SERENITY BUILT HOMES INC PHONE : (910) 893-2462
OWNER . . : FRYE RANDY & MARIA PHONE : (910) 984-7042
PARCEL . . : 10-0578- - -0050- -01-
APPL NUMBER: 08-50019925 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TRUN LEFT ON PRISON CAMP RD GO APPROX
2.9 MILES ON LEFT JB

STRUCTURE: 000 000 74X50.4 SFD CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/23/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001614088
	5/23/08	AP	
A814 01	5/27/08	TI	ADDRESS CONFIRMATION VRU #: 001614759
	5/28/08	AP	2865 ROSS RD
B103 01	6/04/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619246
	6/04/08	CA	
B103 02	6/05/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619832

AP JH

----- COMMENTS AND NOTES -----

ADDRESS . . : 2865 ROSS RD SUBDIV:
CONTRACTOR : SERENITY BUILT HOMES INC PHONE : (910) 893-2462
OWNER . . . : FRYE RANDY & MARIA PHONE : (910) 984-7042
PARCEL . . . : 10-0578- - -0050- -01-
APPL NUMBER: 08-50019925 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TRUN LEFT ON PRISON CAMP RD GO APPROX
2.9 MILES ON LEFT JB

STRUCTURE: 000 000 74X50.4 SFD CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/23/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001614088
	5/23/08	AP	
A814 01	5/27/08	TI	ADDRESS CONFIRMATION VRU #: 001614759
	5/28/08	AP	2865 ROSS RD
B103 01	6/04/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619246
	6/04/08	CA	
B103 02	6/05/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619832
	6/05/08	AP	
B105 01	6/10/08	TI	R*OPEN FLOOR VRU #: 001622885
		AP JH	WOULD LIKE A MORNING INSPECTION.

----- COMMENTS AND NOTES -----

ADDRESS : 2865 ROSS RD SUBDIV:
CONTRACTOR : SERENITY BUILT HOMES INC PHONE : (910) 893-2462
OWNER : FRYE RANDY & MARIA PHONE : (910) 984-7042
PARCEL : 10-0578- - -0050- -01-
APPL NUMBER: 08-50019925 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TRUN LEFT ON PRISON CAMP RD GO APPROX
2.9 MILES ON LEFT JB

STRUCTURE: 000 000 74X50.4 SFD CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/23/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001614088
	5/23/08	AP	
A814 01	5/27/08	TI	ADDRESS CONFIRMATION VRU #: 001614759
	5/28/08	AP	2865 ROSS RD
B103 01	6/04/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619246
	6/04/08	CA	
B103 02	6/05/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619832
	6/05/08	AP	
B105 01	6/10/08	JH	R*OPEN FLOOR VRU #: 001622885
	6/10/08	AP	WOULD LIKE A MORNING INSPECTION.
H824 01	7/11/08	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001640861
	7/11/08	AP	
R427 01	7/18/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001644384
	<u>7-18</u>	<u>DA</u>	

----- COMMENTS AND NOTES -----

Flash porch

ADDRESS : 2865 ROSS RD
CONTRACTOR : SERENITY BUILT HOMES INC
OWNER : FRYE RANDY & MARIA
PARCEL : 10-0578- - -0050- -01-
APPL NUMBER: 08-50019925 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TRUN LEFT ON PRISON CAMP RD GO APPROX
2.9 MILES ON LEFT JB

SUBDIV:
PHONE : (910) 893-2462
PHONE : (910) 984-7042

STRUCTURE: 000 000 74X50.4 SFD CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/23/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001614088
	5/23/08	AP	
A814 01	5/27/08	TI	ADDRESS CONFIRMATION VRU #: 001614759
	5/28/08	AP	2865 ROSS RD
B103 01	6/04/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619246
	6/04/08	CA	
B103 02	6/05/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619832
	6/05/08	AP	
B105 01	6/10/08	JH	R*OPEN FLOOR VRU #: 001622885
	6/10/08	AP	WOULD LIKE A MORNING INSPECTION.
H824 01	7/11/08	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001640861
	7/11/08	AP	
R427 01	7/18/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001644384
	7/18/08	DA	<ul style="list-style-type: none"> 1. No test on plumbing. Did not go under the house because there is no point without plumbing test on. 2. Receptacle for countertop may not meet code next to sink. 3. Valley in attic not supported per plan. 4. Breakfast nook and dining room receptacles shall be on 20 amp circuit. It is currently wired with 14-2. 5. Fflash fron porch and for rear steps. Ok to insulate.
I129 01	7/22/08	TI	R*INSULATION INSPECTION VRU #: 001646413
	7/22/08	CA	
R427 02	7/22/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001646421
	7/22/08	CA	
I129 02	7/23/08	TI	R*INSULATION INSPECTION VRU #: 001646900
R427 03	7/23/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001646892

AP JV
AP JV

COMMENTS AND NOTES

ADDRESS : 2865 ROSS RD SUBDIV:
CONTRACTOR : SERENITY BUILT HOMES INC PHONE : (910) 893-2462
OWNER : FRYE RANDY & MARIA PHONE : (910) 984-7042
PARCEL : 10-0578- - -0050- -01-
APPL NUMBER: 08-50019925 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TRUN LEFT ON PRISON CAMP RD GO APPROX
2.9 MILES ON LEFT JB

STRUCTURE: 000 000 74X50.4 SFD CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/23/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001614088
	5/23/08	AP	
A814 01	5/27/08	TI	ADDRESS CONFIRMATION VRU #: 001614759
	5/28/08	AP	✓ 2865 ROSS RD
B103 01	6/04/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619246
	6/04/08	CA	
B103 02	6/05/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619832
	6/05/08	AP	
B105 01	6/10/08	JH	R*OPEN FLOOR VRU #: 001622885
	6/10/08	AP	WOULD LIKE A MORNING INSPECTION.
H824 01	7/11/08	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001640861
	7/11/08	AP	
R427 01	7/18/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001644384
	7/18/08	DA	1. No test on plumbing. Did not go under the house because there is no point without plumbing test on. 2. Receptacle for countertop may not meet code next to sink. 3. Valley in attic not supported per plan. 4. Breakfast nook and dining room receptacles shall be on 20 amp circuit. It is currently wired with 14-2. 5. Fflash fron porch and for rear steps. Ok to insulate.
I129 01	7/22/08	TI	R*INSULATION INSPECTION VRU #: 001646413
	7/22/08	CA	
R427 02	7/22/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001646421
	7/22/08	CA	
I129 02	7/23/08	JH	R*INSULATION INSPECTION VRU #: 001646900
	7/23/08	AP	
R427 03	7/23/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001646892
	7/23/08	AP	
R431 01	10/09/08	TI	FOUR TRADE FINAL >2500 VRU #: 001689611

DA JV

----- COMMENTS AND NOTES -----

ADDRESS : 2865 ROSS RD SUBDIV:
 CONTRACTOR : SERENITY BUILT HOMES INC PHONE : (910) 893-2462
 OWNER : FRYE RANDY & MARIA PHONE : (910) 984-7042
 PARCEL : 10-0578- - -0050- -01-
 APPL NUMBER: 08-50019925 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : TRUN LEFT ON PRISON CAMP RD GO APPROX
 2.9 MILES ON LEFT JB

STRUCTURE: 000 000 74X50.4 SFD CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/23/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001614088
	5/23/08	AP	
A814 01	5/27/08	TI	ADDRESS CONFIRMATION VRU #: 001614759
	5/28/08	AP	✓ 2865 ROSS RD
B103 01	6/04/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619246
	6/04/08	CA	
B103 02	6/05/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619832
	6/05/08	AP	
B105 01	6/10/08	JH	R*OPEN FLOOR VRU #: 001622885
	6/10/08	AP	✓ WOULD LIKE A MORNING INSPECTION.
H824 01	7/11/08	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001640861
	7/11/08	AP	
R427 01	7/18/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001644384
	7/18/08	DA	1. No test on plumbing. Did not go under the house because there is no point without plumbing test on. 2. Receptacle for countertop may not meet code next to sink. 3. Valley in attic not supported per plan. 4. Breakfast nook and dining room receptacles shall be on 20 amp circuit. It is currently wired with 14-2. 5. Fflash fron porch and for rear steps. Ok to insulate.
I129 01	7/22/08	TI	R*INSULATION INSPECTION VRU #: 001646413
	7/22/08	CA	
R427 02	7/22/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001646421
	7/22/08	CA	
I129 02	7/23/08	JH	R*INSULATION INSPECTION VRU #: 001646900
	7/23/08	AP	
R427 03	7/23/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001646892
	7/23/08	AP	
R431 01	10/09/08	JH	FOUR TRADE FINAL >2500 VRU #: 001689611
	10/09/08	DA	1) Need plastic under house. 2) Need receptacl on front of house accessible from grade.
R431 02	10/10/08	TI	FOUR TRADE FINAL >2500 VRU #: 001690122
	10/10/08	AP	

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: Randy & Maria Frye

911 Address: 2565 Ross Rd.

State: NC Zip Code: _____

Date: 10/10/08

[Signature]
Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: 08-50019925

MFG. Home: _____