
ADDRESS . : 115 MOONLIGHT DR SUBDIV: STETSON 53LOTS
CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242
OWNER . . : COMFORT HOMES #5 PHONE : (919) 553-3242
PARCEL . . : 04-0674- - -0046- -05-
APPL NUMBER: 08-50019932 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : STETSON SUBD #5
401 NORTH RIGHT ON RAWLS CHURCH RD LEFT
ON ATKINS RD, SUBD ON RIGHT ON
MOONLIGHT DRIVE
T/S: 04/25/2008 12:01 PM DJOHNSON --

STRUCTURE: 000 000 70X36 3 BR W/GARAGE/10X12 DECK/FINISH BO
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/13/08 <i>6-13-08</i>	TI <i>APBS</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001625102 TSP IS READY

----- COMMENTS AND NOTES -----

84057468

ADDRESS . . : 115 MOONLIGHT DR SUBDIV: STETSON 53LOTS
 CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242
 OWNER . . : COMFORT HOMES #5 PHONE : (919) 553-3242
 PARCEL . . : 04-0674- - -0046- -05-
 APPL NUMBER: 08-50019932 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : STETSON SUBD #5
 401 NORTH RIGHT ON RAWLS CHURCH RD LEFT
 ON ATKINS RD, SUBD ON RIGHT ON
 MOONLIGHT DRIVE
 T/S: 04/25/2008 12:01 PM DJOHNSON --

STRUCTURE: 000 000 70X36 3 BR W/GARAGE/10X12 DECK/FINISH BO
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/13/08 6/13/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001625102 TSP IS READY. 84057468
A814 01	6/24/08	TI	ADDRESS CONFIRMATION VRU #: 001630490
B103 01	<u>6/24/08</u> <u>6:24-08</u>	<u>TI</u> <u>AEBS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001630508

----- COMMENTS AND NOTES -----

ADDRESS . . : 115 MOONLIGHT DR SUBDIV: STETSON 53LOTS
CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242
OWNER . . : COMFORT HOMES #5 PHONE : (919) 553-3242
PARCEL . . : 04-0674- - -0046- -05-
APPL NUMBER: 08-50019932 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : STETSON SUBD #5
401 NORTH RIGHT ON RAWLS CHURCH RD LEFT
ON ATKINS RD, SUBD ON RIGHT ON
MOONLIGHT DRIVE
T/S: 04/25/2008 12:01 PM DJOHNSON --

STRUCTURE: 000 000 70X36 3 BR W/GARAGE/10X12 DECK/FINISH BO
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/13/08 6/13/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001625102 TSP IS READY. 84057468
B103 01	6/24/08 6/24/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001630508 pier on right side rear of porch (connected to porch) has no projection. Change pier to 4 inch block or extend footing. Will check at open floor
A814 01	6/24/08 6/24/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001630490 115 MOONLIGHT DR LOT 5
B105 01	7/02/08 <u>7-2-08</u>	TI <u>AEBS</u>	R*OPEN FLOOR VRU #: 001635523

----- COMMENTS AND NOTES -----

553 1215
625 0815

ADDRESS . : 115 MOONLIGHT DR SUBDIV: STETSON 53LOTS
CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242
OWNER . . : COMFORT HOMES #5 PHONE : (919) 553-3242
PARCEL . . : 04-0674- - -0046- -05-
APPL NUMBER: 08-50019932 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : STETSON SUBD #5
401 NORTH RIGHT ON RAWLS CHURCH RD LEFT
ON ATKINS RD, SUBD ON RIGHT ON
MOONLIGHT DRIVE
T/S: 04/25/2008 12:01 PM DJOHNSON --

STRUCTURE: 000 000 70X36 3 BR W/GARAGE/10X12 DECK/FINISH BO
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/13/08 6/13/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001625102 TSP IS READY. 84057468
B103 01	6/24/08 6/24/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001630508 pier on right side rear of porch (connected to porch) has no projection. Change pier to 4 inch block or extend footing. Will check at open floor
A814 01	6/24/08 6/24/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001630490 115 MOONLIGHT DR LOT 5
B105 01	7/02/08 7/02/08	BS AE	R*OPEN FLOOR VRU #: 001635523 plan calls for 4-2x10 girder on left side. Correct/will recheck at framing inspection
R427 01	7/23/08 <u>7-23-08</u>	TI <u>DAES</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001646942

----- COMMENTS AND NOTES -----

ADDRESS : 115 MOONLIGHT DR SUBDIV: STETSON 53LOTS
 CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242
 OWNER : COMFORT HOMES #5 PHONE : (919) 553-3242
 PARCEL : 04-0674- - -0046- -05-
 APPL NUMBER: 08-50019932 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : STETSON SUBD #5
 401 NORTH RIGHT ON RAWLS CHURCH RD LEFT
 ON ATKINS RD, SUBD ON RIGHT ON
 MOONLIGHT DRIVE
 T/S: 04/25/2008 12:01 PM DJOHNSON --

STRUCTURE: 000 000 70X36 3 BR W/GARAGE/10X12 DECK/FINISH BO
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/13/08 6/13/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001625102 TSP IS READY. 84057468
B103 01	6/24/08 6/24/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001630508 pier on right side rear of porch (connected to porch) has no projection. Change pier to 4 inch block or extend footing. Will check at open floor
A814 01	6/24/08 6/24/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001630490 115 MOONLIGHT DR LOT 5
B105 01	7/02/08 7/02/08	BS AE	R*OPEN FLOOR VRU #: 001635523 plan calls for 4-2x10 girder on left side. Correct/will recheck at framing inspection
R427 01	7/23/08 7/23/08	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001646942 No pressure on gas test. Must hold 10 psi min. sheet garage wall. ok to side/insulate
I129 01	7/25/08 <u>7-25-08</u>	TI <u>APBS</u>	R*INSULATION INSPECTION VRU #: 001649094
R427 02	7/25/08 <u>7/25/08</u>	TI <u>APBS</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001649102

COMMENTS AND NOTES

ADDRESS : 115 MOONLIGHT DR SUBDIV: STETSON 53LOTS
 CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242
 OWNER : COMFORT HOMES #5 PHONE : (919) 553-3242
 PARCEL : 04-0674- - -0046- -05-
 APPL NUMBER: 08-50019932 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : STETSON SUBD #5
 401 NORTH RIGHT ON RAWLS CHURCH RD LEFT
 ON ATKINS RD, SUBD ON RIGHT ON
 MOONLIGHT DRIVE
 T/S: 04/25/2008 12:01 PM DJOHNSON --

STRUCTURE: 000 000 70X36 3 BR W/GARAGE/10X12 DECK/FINISH BO
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/13/08 6/13/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001625102 TSP IS READY. 84057468
B103 01	6/24/08 6/24/08	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001630508 pier on right side rear of porch (connected to porch) has no projection. Change pier to 4 inch block or extend footing. Will check at open floor
A814 01	6/24/08 6/24/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001630490 115 MOONLIGHT DR LOT 5
B105 01	7/02/08 7/02/08	BS AE	R*OPEN FLOOR VRU #: 001635523 plan calls for 4-2x10 girder on left side. Correct/will recheck at framing inspection
R427 01	7/23/08 7/23/08	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001646942 No pressure on gas test. Must hold 10 psi min. sheet garage wall. ok to side/insulate
I129 01	7/25/08 7/25/08	BS AP	R*INSULATION INSPECTION VRU #: 001649094 all previous violations corrected
R427 02	7/25/08 7/25/08	BS AP	FOUR TRADE ROUGH IN >2500 VRU #: 001649102 all previous violations corrected
H824 01	9/04/08 9/04/08	JM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001672278
R431 01	10/01/08 <i>10-01-08</i>	TI <i>APBS</i>	FOUR TRADE FINAL >2500 VRU #: 001684810

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SED

Owner: Comfort Homes

911 Address: 115 Moonlight Dr

FV

State: NC Zip Code: 77526

Date: 10-1-08

Brad Smith
Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: 08-5-19932

MFG. Home: _____