

HTE# 08-5-19934

Har... County Department of Public Health

24634

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Comfort Homes Inc. PROPERTY LOCATION: SR1448 ATKINS RD. SUBDIVISION: STETSON LOT # 7. Type of Structure: SFD. Proposed Wastewater System Type: 25% RSD MANIFOLD. Projected Daily Flow: 360 GPD. Number of bedrooms: 3. Number of Occupants: 6 max. Basement: No. Pump Required: Yes. Type of Water Supply: Public. Permit valid for: Five years.

Authorized State Agent: James E. Manhart Date: 5-12-08 SEE ATTACHED SITE SKETCH. The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Comfort Homes Inc. PROPERTY LOCATION: SR1448 ATKINS RD. SUBDIVISION: STETSON LOT # 7. Facility Type: SFD. Wastewater Flow: 360 GPD. Type of Wastewater System: 25% RSD MANIFOLD (Initial) and 25% RSD MANIFOLD (Repair).

Installation Requirements/Conditions

Septic Tank Size: 1000 gallons. Pump Tank Size: 1000 gallons. Trench Spacing: 9 Feet on Center. Soil Cover: 6 inches. Maximum Trench Depth: 30" = 18 inches. Pump Requirements: 2' pressure 1 HEAD ft. TDH vs. GPM. Aggregate Depth: 6 inches below pipe, 2 inches above pipe, 12 inches total.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site.

Authorized State Agent: James E. Manhart Date: 5-12-08 Construction Authorization Expiration Date: 5-12-03 SEE ATTACHED SITE SKETCH

