
ADDRESS . . : 281 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER . . : WOODSHIRE PARTNERS LLC PHONE :
PARCEL . . : 01-0536-06- -0028- -20-
APPL NUMBER: 08-50019957 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 27 W TURN LEFT ON NURSERY TURN LEFT
WOODPOINT TURN RIGHT ADVANCE LOT ON
RIGHT JB

STRUCTURE: 000 000 56X56 3BDR CRAWL GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	7/02/09 <u>7/2/09</u>	TI <u>AP DS</u>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001789718 T/S: 07/01/2009 02:25 PM NTART -----

----- COMMENTS AND NOTES -----

ADDRESS : 281 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER : WOODSHIRE PARTNERS LLC PHONE :
PARCEL : 01-0536-06- -0028- -20-
APPL NUMBER: 08-50019957 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TURN LEFT ON NURSERY TURN LEFT
WOODPOINT TURN RIGHT ADVANCE LOT ON
RIGHT JB

STRUCTURE: 000 000 56X56 3BDR CRAWL GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/02/09	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001789718
	7/02/09	AP	T/S: 07/01/2009 02:25 PM NTART -----
A814 01	7/08/09	TI	ADDRESS CONFIRMATION VRU #: 001791342
B103 01	7/08/09 <i>7/8/09</i>	TI <i>AP DT</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791334

----- COMMENTS AND NOTES -----

ADDRESS : 281 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER : WOODSHIRE PARTNERS LLC PHONE :
PARCEL : 01-0536-06- -0028- -20-
APPL NUMBER: 08-50019957 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TURN LEFT ON NURSERY TURN LEFT
WOODPOINT TURN RIGHT ADVANCE LOT ON
RIGHT JB

STRUCTURE: 000 000 56X56 3BDR CRAWL GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/02/09	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001789718
	7/02/09	AP	T/S: 07/01/2009 02:25 PM NTART -----
A814 01	7/08/09	TI	ADDRESS CONFIRMATION VRU #: 001791342
B103 01	7/08/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791334
	7/08/09	AP	
B105 01	7/10/09	TI	R*OPEN FLOOR VRU #: 001792554
	<u>7-10</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 277 ADVANCE DR SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER : WOODSHIRE PARTNERS LLC PHONE :
 PARCEL : 01-0536-06- -0028- -20-
 APPL NUMBER: 08-50019957 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 W TURN LEFT ON NURSERY TURN LEFT
 WOODPOINT TURN RIGHT ADVANCE LOT ON
 RIGHT JB

STRUCTURE: 000 000 56X56 3BDR CRAWL GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/02/09	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001789718
	7/02/09	AP	T/S: 07/01/2009 02:25 PM NTART -----
B103 01	7/08/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791334
	7/08/09	AP	
A814 01	7/08/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001791342
	7/13/09	AP	277 advance dr lot 180 ----- lillington 27546 T/S: 07/13/2009 01:20 PM TWARD -----
B105 01	7/10/09	KS	R*OPEN FLOOR VRU #: 001792554
	7/10/09	AP	
R425 01	7/24/09	MR	FOUR TRADE ROUGH IN VRU #: 001799833
	7/24/09	DA	T/S: 07/24/2009 01:09 PM MREARIC ----- 1. connect all grounds in boxes together 2. flash porch at concrete 3. ok to side and insulk.
I129 01	7/30/09	TI	R*INSULATION INSPECTION VRU #: 001802106
	<u>7/30/09</u>	<u>AP IX</u>	
R427 01	7/30/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001802115
	<u>7/30/09</u>	<u>AP IX</u>	

COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

DATE 9/11/09

ADDRESS . . : 277 ADVANCE DR
 CONTRACTOR : CEBCO CONSTRUCTION INC
 OWNER . . . : WOODSHIRE PARTNERS LLC
 PARCEL . . . : 01-0536-06- -0028- -20-
 APPL NUMBER: 08-50019957 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 W TURN LEFT ON NURSERY TURN LEFT
 WOODPOINT TURN RIGHT ADVANCE LOT ON
 RIGHT JB

SUBDIV: WOODSHIRE PH 5
 PHONE : (910) 893-3331
 PHONE :

STRUCTURE: 000 000 56X56 3BDR CRAWL GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/02/09	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001789718
	7/02/09	AP	T/S: 07/01/2009 02:25 PM NTART -----
B103 01	7/08/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001791334
	7/08/09	AP	
A814 01	7/08/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001791342
	7/13/09	AP	✓ 277 advance dr lot 180, ----- lillington 27546 T/S: 07/13/2009 01:20 PM TWARD -----
B105 01	7/10/09	KS	R*OPEN FLOOR VRU #: 001792554
	7/10/09	AP	
R425 01	7/24/09	MR	FOUR TRADE ROUGH IN VRU #: 001799833
	7/24/09	DA	T/S: 07/24/2009 01:09 PM MREARIC ----- 1. connect all grounds in boxes together 2. flash porch at concrete 3. ok to side and insulk.
I129 01	7/30/09	DT	R*INSULATION INSPECTION VRU #: 001802106
	7/30/09	AP	
R427 01	7/30/09	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001802115
	7/30/09	AP	
R429 01	9/03/09	TI	FOUR TRADE FINAL VRU #: 001816173
	9/02/09	CA	T/S: 09/02/2009 02:32 PM NTART ----- NO OPERATIONS PERMIT***** CANCELLED FINAL INSPECTION.
H824 01	9/08/09	DJ	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001819929
	9/10/09	AP	T/S: 09/10/2009 09:11 AM DJOHNSON ----- APPROVED PER OPERATIONS PERMIT DATED 90809 BY JOE WEST T/S: 09/10/2009 09:11 AM DJOHNSON -----
R431 01	9/11/09	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 001819937
	<u>9/11/09</u>	<u>AP DJ</u>	T/S: 09/10/2009 09:13 AM VBROWN -----

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Conditional Use Permit No.: _____

Type of Construction: _____

Building Permit No.: _____

Owner of Building: Cebco Construction

Electrical Permit No.: _____

Building Address: 277 Advance Dr.

Insulation Permit No.: _____

Zoning District: Hillington, NC 27546

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: 08-50019957

Date: 9/11/09

Envir. C.O. No.: _____

[Signature]
Building Official

Zoning Official