
ADDRESS : 269 SONORA DR SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
 PARCEL : 01-0536-06- -0028- -58-
 APPL NUMBER: 08-50019982 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TRUN
 LEFT LEMUEL BLACK TURN LEFT WOODSHIRE
 TURN RIGHT SONORS LOT ON LEFT LOT 218
 JB

STRUCTURE: 000 000 55X61 3BDR W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/03/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001616914
	6/03/08	CA	
B101 02	6/04/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001619188
	<u>6/4/08</u>	<u>AS DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 269 SONORA DR
CONTRACTOR : CEBCO CONSTRUCTION INC
OWNER . . . : KENNETH CUMMINGS LLC
PARCEL . . . : 01-0536-06- -0028- -58-
APPL NUMBER: 08-50019982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TRUN
LEFT LEMUEL BLACK TURN LEFT WOODSHIRE
TURN RIGHT SONORS LOT ON LEFT LOT 218
JB

STRUCTURE: 000 000 55X61 3BDR W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/03/08 6/03/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001616914
B101 02	6/04/08 6/04/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001619188
B103 01	6/10/08	TI <i>AP-MR</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622266

----- COMMENTS AND NOTES -----

ADDRESS : 269 SONORA DR
CONTRACTOR : CEBCO CONSTRUCTION INC
OWNER : KENNETH CUMMINGS LLC
PARCEL : 01-0536-06- -0028- -58-
APPL NUMBER: 08-50019982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TRUN
LEFT LEMUEL BLACK TURN LEFT WOODSHIRE
TURN RIGHT SONORS LOT ON LEFT LOT 218
JB

SUBDIV: WOODSHIRE PH 5
PHONE : (910) 893-3331
PHONE : (910) 893-5826

STRUCTURE: 000 000 55X61 3BDR W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/03/08 6/03/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001616914
B101 02	6/04/08 6/04/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001619188
B103 01	6/10/08 6/10/08	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622266
B105 01	6/24/08 <i>6/24/08</i>	TI <i>AP DI</i>	R*OPEN FLOOR VRU #: 001630676

COMMENTS AND NOTES

ADDRESS . . : 269 SONORA DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER . . . : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
PARCEL . . . : 01-0536-06- -0028- -58-
APPL NUMBER: 08-50019982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TRUN
LEFT LEMUEL BLACK TURN LEFT WOODSHIRE
TURN RIGHT SONORS LOT ON LEFT LOT 218
JB

STRUCTURE: 000 000 55X61 3BDR W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/03/08 6/03/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001616914
B101 02	6/04/08 6/04/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001619188
B103 01	6/10/08 6/10/08	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622266
B105 01	6/24/08 6/24/08	DT AP	R*OPEN FLOOR VRU #: 001630676
A814 01	6/27/08 6/24/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001630701 269 sonora dr lot 218
R425 01	7/03/08 <u>7/3/08</u>	TI <u>DA DT</u>	FOUR TRADE ROUGH IN VRU #: 001636527

Tr. Flo. Gas

----- COMMENTS AND NOTES -----

ADDRESS : 269 SONORA DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
PARCEL : 01-0536-06- -0028- -58-
APPL NUMBER: 08-50019982 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TRUN
LEFT LEMUEL BLACK TURN LEFT WOODSHIRE
TURN RIGHT SONORS LOT ON LEFT LOT 218
JB

STRUCTURE: 000 000 55X61 3BDR W/ GARAGE & DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/03/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001616914
	6/03/08	CA	
B101 02	6/04/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001619188
	6/04/08	AP	
B103 01	6/10/08	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622266
	6/10/08	AP	
B105 01	6/24/08	DT	R*OPEN FLOOR VRU #: 001630676
	6/24/08	AP	
A814 01	6/27/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001630701
	6/24/08	AP	269 sonora dr lot 218
R425 01	7/03/08	DT	FOUR TRADE ROUGH IN VRU #: 001636527
	7/03/08	DA	1. No gas pressure. 2. Bathroom exhaust longer tan 14 ft flex duct. 3. A2 and A3 trussed braced wrong. Okay to side and insulate.
I129 01	7/09/08	TI	R*INSULATION INSPECTION VRU #: 001637152
	7/9/08	DA DT	
R427 01	7/09/08	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001638949
	7/9/08	DA DT	

----- COMMENTS AND NOTES -----

ADDRESS : 269 SONORA DR
 CONTRACTOR : CEBCO CONSTRUCTION INC
 OWNER : KENNETH CUMMINGS LLC
 PARCEL : 01-0536-06- -0028- -58-
 APPL NUMBER: 08-50019982 CP NEW RESIDENTIAL (SFD)

SUBDIV: WOODSHIRE PH 5
 PHONE : (910) 893-3331
 PHONE : (910) 893-5826

DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TRUN
 LEFT LEMUEL BLACK TURN LEFT WOODSHIRE
 TURN RIGHT SONORS LOT ON LEFT LOT 218
 JB

STRUCTURE: 000 000 55X61 3BDR W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/03/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001616914
	6/03/08	CA	
B101 02	6/04/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001619188
	6/04/08	AP	
B103 01	6/10/08	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622266
	6/10/08	AP	
B105 01	6/24/08	DT	R*OPEN FLOOR VRU #: 001630676
	6/24/08	AP	
A814 01	6/27/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001630701
	6/24/08	AP	269 sonora dr lot 218
R425 01	7/03/08	DT	FOUR TRADE ROUGH IN VRU #: 001636527
	7/03/08	DA	1. No gas pressure. 2. Bathroom exhaust longer tan 14 ft flex duct. 3. A2 and A3 trussed braced wrong. Okay to side and insulate.
I129 01	7/09/08	DT	R*INSULATION INSPECTION VRU #: 001637152
	7/09/08	DA	Need insulation under air hander platform above kitchen.
R427 01	7/09/08	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001638949
	7/09/08	DA	no pressure on gas line.
I129 02	7/11/08	TI	R*INSULATION INSPECTION VRU #: 001640200
		AP-MR	
R427 02	7/11/08	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001640564
		AP-MR	

COMMENTS AND NOTES

ADDRESS : 269 SONORA DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
PARCEL : 01-0536-06- -0028- -58-
APPL NUMBER: 08-50019982 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TRUN
LEFT LEMUEL BLACK TURN LEFT WOODSHIRE
TURN RIGHT SONORS LOT ON LEFT LOT 218
JB

STRUCTURE: 000 000 55X61 3BDR W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/03/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001616914
	6/03/08	CA	
B101 02	6/04/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001619188
	6/04/08	AP	
B103 01	6/10/08	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622266
	6/10/08	AP	
B105 01	6/24/08	DT	R*OPEN FLOOR VRU #: 001630676
	6/24/08	AP	
A814 01	6/27/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001630701
	6/24/08	AP	✓ 269 sonora dr lot 218
R425 01	7/03/08	DT	FOUR TRADE ROUGH IN VRU #: 001636527
	7/03/08	DA	1. No gas pressure. 2. Bathroom exhaust longer tan 14 ft flex duct. 3. A2 and A3 trussed braced wrong. Okay to side and insulate.
I129 01	7/09/08	DT	R*INSULATION INSPECTION VRU #: 001637152
	7/09/08	DA	Need insulation under air hander platform above kitchen.
R427 01	7/09/08	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001638949
	7/09/08	DA	No pressure on gas line.
I129 02	7/11/08	MR	R*INSULATION INSPECTION VRU #: 001640200
	7/11/08	AP	
R427 02	7/11/08	MR	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001640564
	7/11/08	AP	
H824 01	7/22/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001647007
	7/22/08	AP	
R429 01	8/20/08	TI	FOUR TRADE FINAL VRU #: 001664880

8-20 RP

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: Kenneth Cummings

911 Address: 269 Smora Drive

State: _____ Zip Code: _____

Date: 8-20-08
Ke Slath

Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: 8

MFG. Home: _____

50019982