

Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:
 Address:
 Proposed Facility: *SFD* Design Flow (.1949): *360*
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant: *20018*

Date Evaluated: *6-3-08*
 Property Size: *508*
 Property Recorded:
 Spring Other
 Pit Cut
 Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Hortz	
1	L 30%	0-20	SL	FR GR NSNP					.4
		20-44	SCL	FR GR NSNP	42" 7.5% 42				
2	L 30%	0-20	SL	FR GR NSNP					.4
		20-44	SCL	FR GR NSNP	40" 7.5% 40				
3	L 3%	0-20	SL	FR GR NSNP					.4
		20-44	SCL	FR GR NSNP	42" 7.5% 42				
4	L 3%	0-18	SL	FR GR NSNP					.4
		18-44	SCL	FR GR NSNP	40" 7.5% 40				

Description	Initial System	Repair System
Available Space (.1945)	<i>/</i>	<i>/</i>
System Type(s)	<i>25"</i>	<i>25"</i>
Site LTAR	<i>.4</i>	<i>.4</i>

Other Factors (.1946): _____
 Site Classification (.1948): *PS*
 Evaluated By: *[Signature]*
 Others Present: *[Signature]*