



-----  
ADDRESS . . : 88546 \*UNASSIGNED SUBDIV:  
CONTRACTOR : PHONE :  
OWNER . . : CASTALDP REGNALDO & SHARON PHONE : (910) 892-2866  
PARCEL . . : 02-1518- - -0181- -01-  
APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
-----

DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
RD PROPERTY .3 MILES ON RIGHT JB  
-----

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08 7/08/08	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688 T-pole good
B101 02	7/17/08 <u>7-17</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087 WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.

----- COMMENTS AND NOTES -----  
-----

-----  
ADDRESS . . : 88546 \*UNASSIGNED SUBDIV:  
CONTRACTOR : PHONE :  
OWNER . . : CASTALDP REGNALDO & SHARON PHONE : (910) 892-2866  
PARCEL . . : 02-1518- - -0181- -01-  
APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
RD PROPERTY .3 MILES ON RIGHT JB  
\*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*  
-----

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
A814 01	7/22/08	TI	ADDRESS CONFIRMATION VRU #: 001645803
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
B113 01	7/25/08	TI	R*BLDG <del>WATER</del> /DAMP PROOFING VRU #: 001648872

----- COMMENTS AND NOTES -----  
-----

ADDRESS : 88546 \*UNASSIGNED SUBDIV:  
 CONTRACTOR : PHONE :  
 OWNER : CASTALDP REGNALDO & SHARON PHONE : (910) 892-2866  
 PARCEL : 02-1518- - -0181- -01-  
 APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
 ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
 RD PROPERTY .3 MILES ON RIGHT JB  
 \*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*

**STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
A814 01	7/22/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001645803
	7/25/08	AP	3201 MEADOWLARK RD # ON HOUSE & BY DRIVE
B113 01	7/25/08	TI	R*BLDG WATER/DAMP PROOFING VRU #: 001648872
	7.25	AP	
B105 01	7/29/08	TI	R*OPEN FLOOR VRU #: 001650760
	7.29	AP	

COMMENTS AND NOTES

-----  
ADDRESS . . : 88546 \*UNASSIGNED SUBDIV:  
CONTRACTOR : PHONE :  
OWNER . . : CASTALDP REGNALDO & SHARON PHONE : (910) 892-2866  
PARCEL . . : 02-1518- - -0181- -01-  
APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
RD PROPERTY .3 MILES ON RIGHT JB  
\*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*  
-----

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
A814 01	7/22/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001645803
	7/25/08	AP	3201 MEADOWLARK RD # ON HOUSE & BY DRIVE
B113 01	7/25/08	KS	R*BLDG WATER/DAMP PROOFING VRU #: 001648872
	7/25/08	AP	
B105 01	7/29/08	KS	R*OPEN FLOOR VRU #: 001650760
	7/29/08	AP	
B101 03	7/30/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001651929

7-30      DA

----- COMMENTS AND NOTES -----

ADDRESS : 88546 \*UNASSIGNED SUBDIV:  
CONTRACTOR : PHONE :  
OWNER : CASTALDP REGNALDO & SHARON PHONE : (910) 892-2866  
PARCEL : 02-1518- - -0181- -01-  
APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
RD PROPERTY .3 MILES ON RIGHT JB  
\*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
A814 01	7/22/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001645803
	7/25/08	AP	3201 MEADOWLARK RD # ON HOUSE & BY DRIVE
B113 01	7/25/08	KS	R*BLDG WATER/DAMP PROOFING VRU #: 001648872
	7/25/08	AP	
B105 01	7/29/08	KS	R*OPEN FLOOR VRU #: 001650760
	7/29/08	AP	
B101 03	7/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001651929
	7/30/08	DA	Foot calls for 10 inch deep--grade set at 8 inch 30 X 30 footers missing at breezeway
B101 04	8/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001653286
	8-1	AP	

COMMENTS AND NOTES

-----  
ADDRESS . . : 88546 \*UNASSIGNED SUBDIV:  
CONTRACTOR : PHONE :  
OWNER . . : CASTALDP REGNALDO & SHARON PHONE : (910) 892-2866  
PARCEL . . : 02-1518- - -0181- -01-  
APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
RD PROPERTY .3 MILES ON RIGHT JB  
\*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*  
-----

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
A814 01	7/22/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001645803
	7/25/08	AP	3201 MEADOWLARK RD # ON HOUSE & BY DRIVE
B113 01	7/25/08	KS	R*BLDG WATER/DAMP PROOFING VRU #: 001648872
	7/25/08	AP	
B105 01	7/29/08	KS	R*OPEN FLOOR VRU #: 001650760
	7/29/08	AP	
B101 03	7/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001651929
	7/30/08	DA	Foot calls for 10 inch deep--grade set at 8 inch 30 X 30 footers missing at breezeway
B101 04	8/01/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001653286
	8/04/08	AP	
B103 03	8/12/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660018

8-12 AP

*Garage*

-----  
COMMENTS AND NOTES  
-----

-----  
ADDRESS . : 88546 \*UNASSIGNED SUBDIV:  
CONTRACTOR : PHONE :  
OWNER . . : CASTALDP REGNALDO & SHARON PHONE : (910) 892-2866  
PARCEL . . : 02-1518- - -0181- -01-  
APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
RD PROPERTY .3 MILES ON RIGHT JB  
\*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*  
-----

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
A814 01	7/22/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001645803
	7/25/08	AP	3201 MEADOWLARK RD # ON HOUSE & BY DRIVE
B113 01	7/25/08	KS	R*BLDG WATER/DAMP PROOFING VRU #: 001648872
	7/25/08	AP	
B105 01	7/29/08	KS	R*OPEN FLOOR VRU #: 001650760
	7/29/08	AP	
B101 03	7/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001651929
	7/30/08	DA	Foot calls for 10 inch deep--grade set at 8 inch 30 X 30 footers missing at breezeway
B101 04	8/01/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001653286
	8/04/08	AP	
B103 03	8/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660018
	8/12/08	AP	
B101 05	8/22/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001666441

8-22 AP

----- COMMENTS AND NOTES -----



ADDRESS : 88546 \*UNASSIGNED SUBDIV:  
 CONTRACTOR : PHONE :  
 OWNER : CASTALDO REGNALDO & SHARON PHONE : (910) 892-2866  
 PARCEL : 02-1518- - -0181- -01-  
 APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
 ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
 RD PROPERTY .3 MILES ON RIGHT JB  
 \*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 4.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
A814 01	7/22/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001645803
	7/25/08	AP	3201 MEADOWLARK RD # ON HOUSE & BY DRIVE
B113 01	7/25/08	KS	R*BLDG WATER/DAMP PROOFING VRU #: 001648872
	7/25/08	AP	
B105 01	7/29/08	KS	R*OPEN FLOOR VRU #: 001650760
	7/29/08	AP	
B101 03	7/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001651929
	7/30/08	DA	Foot calls for 10 inch deep--grade set at 8 inch 30 X 30 footers missing at breezeway
B101 04	8/01/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001653286
	8/04/08	AP	
B103 03	8/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660018
	8/12/08	AP	
B101 05	8/22/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001666441
	8/22/08	AP	
R427 01	9/25/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001682343

925 DA

COMMENTS AND NOTES

**Violation Notice  
Do Not Remove**

**Harnett County Inspection Department  
102 East Front St P.O. Box 65  
Lillington, NC 27546  
Phone (910) 893-7525 Fax (910) 893-2793**

08-50020063

Sept 25, 2008

1. Fire block between bottom riser of garage steps.
2. Fireplace masonry does not have proper clearance to studs on sides and back. See R1003.11
3. Master bedroom shower pan not installed and tested.
4. Standpipe empty
5. Drain through foundation not sleeved.
6. Need receptacle accessible from grade on back of house.
7. House wrap missing on front and rear of garage.
8. Roof hip and valley bracing missing in a couple areas. See circled areas on plan.

Signature Ken Slattum 910-984-4766 \_\_\_\_\_

ADDRESS : 88546 \*UNASSIGNED SUBDIV:  
 CONTRACTOR : PHONE :  
 OWNER : CASTALDO REGNALDO & SHARON PHONE : (910) 892-2866  
 PARCEL : 02-1518- - -0181- -01-  
 APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
 ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
 RD PROPERTY .3 MILES ON RIGHT JB  
 \*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
A814 01	7/22/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001645803
	7/25/08	AP	3201 MEADOWLARK RD # ON HOUSE & BY DRIVE
B113 01	7/25/08	KS	R*BLDG WATER/DAMP PROOFING VRU #: 001648872
	7/25/08	AP	
B105 01	7/29/08	KS	R*OPEN FLOOR VRU #: 001650760
	7/29/08	AP	
B101 03	7/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001651929
	7/30/08	DA	Foot calls for 10 inch deep--grade set at 8 inch 30 X 30 footers missing at breezeway
B101 04	8/01/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001653286
	8/04/08	AP	
B103 03	8/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660018
	8/12/08	AP	
B101 05	8/22/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001666441
	8/22/08	AP	
R427 01	9/25/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001682343
	9/26/08	DA	
R427 02	10/01/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001684582

10/1 AP

COMMENTS AND NOTES

-----  
ADDRESS . . : 88546 \*UNASSIGNED SUBDIV:  
CONTRACTOR : PHONE :  
OWNER . . : CASTALDO REGNALDO & SHARON PHONE : (910) 892-2866  
PARCEL . . : 02-1518- - -0181- -01-  
APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
RD PROPERTY .3 MILES ON RIGHT JB  
\*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*  
-----

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 4.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
A814 01	7/22/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001645803
	7/25/08	AP	3201 MEADOWLARK RD # ON HOUSE & BY DRIVE
B113 01	7/25/08	KS	R*BLDG WATER/DAMP PROOFING VRU #: 001648872
	7/25/08	AP	
B105 01	7/29/08	KS	R*OPEN FLOOR VRU #: 001650760
	7/29/08	AP	
B101 03	7/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001651929
	7/30/08	DA	Foot calls for 10 inch deep--grade set at 8 inch 30 X 30 footers missing at breezeway
B101 04	8/01/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001653286
	8/04/08	AP	
B103 03	8/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660018
	8/12/08	AP	
B101 05	8/22/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001666441
	8/22/08	AP	
R427 01	9/25/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001682343
	9/26/08	DA	
R427 02	10/01/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001684582
	10/01/08	AP	
I129 01	10/08/08	TI	R*INSULATION INSPECTION VRU #: 001689042

AP KS

----- COMMENTS AND NOTES -----

ADDRESS : 88546 \*UNASSIGNED  
CONTRACTOR :  
OWNER : CASTALDO REGNALDO & SHARON  
PARCEL : 02-1518- - -0181- -01-  
APPL NUMBER: 08-50020063 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 421 E LEFT ON RED HILL CHURCH RD RIGHT  
ON THREE BRIDGE RD RIGHT ON MEADOWLARK  
RD PROPERTY .3 MILES ON RIGHT JB  
\*\*\*\*\*PREMIS NUMBER 59612866\*\*\*\*\*

SUBDIV:  
PHONE :  
PHONE : (910) 892-2866

STRUCTURE: 000 000 80X63 4BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 4.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : WELL

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001637688
	7/08/08	AP	T-pole good
B101 02	7/17/08	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001644087
	7/17/08	AP	WILL BE A FOOTING FOR A REAL MASONRY FIREPLACE.
B103 01	7/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645385
	7/21/08	CA	
B103 02	7/22/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001645795
	7/22/08	AP	called in t pole at 1:10
A814 01	7/22/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001645803
	7/25/08	AP	✓ 3201 MEADOWLARK RD # ON HOUSE & BY DRIVE
B113 01	7/25/08	KS	R*BLDG WATER/DAMP PROOFING VRU #: 001648872
	7/25/08	AP	
B105 01	7/29/08	KS	R*OPEN FLOOR VRU #: 001650760
	7/29/08	AP	
B101 03	7/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001651929
	7/30/08	DA	Foot calls for 10 inch deep--grade set at 8 inch 30 X 30 footers missing at breezeway
B101 04	8/01/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001653286
	8/04/08	AP	
B103 03	8/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660018
	8/12/08	AP	
B101 05	8/22/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001666441
	8/22/08	AP	
R427 01	9/25/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001682343
	9/26/08	DA	
R427 02	10/01/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001684582
	10/01/08	AP	
I129 01	10/08/08	KS	R*INSULATION INSPECTION VRU #: 001689042
	10/08/08	AP	
H824 01	12/10/08	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001715739
	12/10/08	AP	
R431 01	2/09/09	TI	FOUR TRADE FINAL >2500 VRU #: 001732691

2-9 AP

COMMENTS AND NOTES

*New Well*

*1518-20-8216*

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: Reginaldo Castaldo

911 Address: 3201 Meadowlark Lane

Dunn

State: \_\_\_\_\_ Zip Code: \_\_\_\_\_

Date: 2-9-09

Ken Slatten

Building Official

PERMIT NUMBERS

Building Permit No.: \_\_\_\_\_

Electrical Permit No.: \_\_\_\_\_

Insulation Permit No.: \_\_\_\_\_

Plumbing Permit No.: \_\_\_\_\_

Mech. Permit No.: \_\_\_\_\_

MFG. Home: \_\_\_\_\_

08-53020063