

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner: 08-520-20079

Applicant:

Address:

Date Evaluated:

Proposed Facility: SFO

Design Flow (.1949): 360

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
S 2%		0-8	GRSL	VFA S ₂					.2
		8-18	SDKJCL	FA S ₂					
		18-28	SDKJC	FE SE	CR 2 c 28'				
		0-6	GRSL	VFA S ₂					.3
		6-18	SDKJCL	FA S ₂					
		18-30	SDKJCL	FE S ₂	CR 2 c 25'				
		0-4	GRSL	VFA S ₂					.25
		4-12	SDKJCL	FA S ₂					
		12-30	SDKJCL	FE S ₂	CR 2 c 28'				
		0-4	GRSL	VFA S ₂					.25
		4-12	SDKJCL	FA S ₂					
		12-30	SDKJC	FE S ₂	CR 2 c 25'				
		0-4	GRSL	VFA S ₂					.25
		4-12	SDKJCL	FA S ₂					
		12-30	SDKJC	FE S ₂	CR 2 c 25'				

Description	Initial System	Repair System
Available Space (.1945)	—	—
System Type(s)	257-	257.
Site LTAR	.25	.25

Other Factors (.1946): _____
 Site Classification (.1948): P1
 Evaluated By: gw
 Others Present:

1236 1206 at 12"