

-----  
ADDRESS . . : 39 ANCIENT OAK CT  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . . : H & H CONSTRUCTORS INC  
PARCEL . . . : 01-0536-05- -0028- -83-  
APPL NUMBER: 08-50020091 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
196 JB  
-----

STRUCTURE: 000 000 44X64 3BDR W/ GARAGE & DECK SLAB  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/28/08 <u>7/28/08</u>	TI <u>AP DT</u>	R*PLUMB UNDER SLAB VRU #: 001648799

----- COMMENTS AND NOTES -----  
-----

-----  
ADDRESS . : 39 ANCIENT OAK CT  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . : H & H CONSTRUCTORS INC  
PARCEL . . : 01-0536-05- -0028- -83-  
APPL NUMBER: 08-50020091 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
196 JB  
-----

STRUCTURE: 000 000 44X64 3BDR W/ GARAGE & DECK SLAB  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/28/08	DT	R*PLUMB UNDER SLAB VRU #: 001648799
	7/28/08	AP	
B111 01	7/30/08	JH	R*BLDG SLAB INSP VRU #: 001651868
	7/30/08	CA	per John
B111 02	7/31/08	TI	R*BLDG SLAB INSP VRU #: 001652627

*AP-MB*

----- COMMENTS AND NOTES -----



-----

ADDRESS . . : 39 ANCIENT OAK CT SUBDIV: FOREST OAKS PH 3 99LOTS  
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 OWNER . . . : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 PARCEL . . . : 01-0536-05- -0028- -83-  
 APPL NUMBER: 08-50020091 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
 NURSERY RD LEFT ON LEMUEL BLACK RD LEFT  
 ON VALLEY OAK INTO FOREST OAKS S/D LOT  
 196 JB

-----

STRUCTURE: 000 000 44X64 3BDR W/ GARAGE & DECK SLAB  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : UNKNOWN

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/28/08	DT	R*PLUMB UNDER SLAB VRU #: 001648799
	7/28/08	AP	
B111 01	7/30/08	JH	R*BLDG SLAB INSP VRU #: 001651868
	7/30/08	CA	per John
B111 02	7/31/08	MR	R*BLDG SLAB INSP VRU #: 001652627
	7/31/08	AP	
R427 01	8/25/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001667187
	8/25/08	CA	
R427 02	9/09/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001673854
	9/09/08	DA	1. truss strappingB-03 2. washer plmb too complicated 3. outlets on kitchen walls too fara back 4. firestop kitch. furred walls 5. two jacks required at back door header at each end. 6. hinge wall in living room
R427 03	9/11/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001675479
	9/11/08	DA DT	

----- COMMENTS AND NOTES -----

ADDRESS : 39 ANCIENT OAK CT SUBDIV: FOREST OAKS PH 3 99LOTS  
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 PARCEL : 01-0536-05- -0028- -83-  
 APPL NUMBER: 08-50020091 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
 NURSERY RD LEFT ON LEMUEL BLACK RD LEFT  
 ON VALLEY OAK INTO FOREST OAKS S/D LOT  
 196 JB

STRUCTURE: 000 000 44X64 3BDR W/ GARAGE & DECK SLAB  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/28/08	DT	R*PLUMB UNDER SLAB VRU #: 001648799
	7/28/08	AP	
B111 01	7/30/08	JH	R*BLDG SLAB INSP VRU #: 001651868
	7/30/08	CA	per John
B111 02	7/31/08	MR	R*BLDG SLAB INSP VRU #: 001652627
	7/31/08	AP	
R427 01	8/25/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001667187
	8/25/08	CA	
R427 02	9/09/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001673854
	9/09/08	DA	1. truss strappingB-03 2. washer plmb too complicated 3. outlets on kitchen walls too fara back 4. firestop kitch. furred walls 5. two jacks required at back door header at each end. 6. hinge wall in living room
R427 03	9/11/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001675479
	9/11/08	DA	✗ Plumbing not fixed. ✗ Furred wall not fireblocked. Okay to side and insulate.
I129 01	9/22/08	AP	R*INSULATION INSPECTION VRU #: 001680065
R427 04	9/22/08	AP	FOUR TRADE ROUGH IN >2500 VRU #: 001680024

DT  
DA

AP JH  
AP JH

COMMENTS AND NOTES

ADDRESS : 39 ANCIENT OAK CT SUBDIV: FOREST OAKS PH 3 99LOTS  
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 PARCEL : 01-0536-05- -0028- -83-  
 APPL NUMBER: 08-50020091 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
 NURSERY RD LEFT ON LEMUEL BLACK RD LEFT  
 ON VALLEY OAK INTO FOREST OAKS S/D LOT  
 196 JB

**STRUCTURE: 000 000 44X64 3BDR W/ GARAGE & DECK SLAB**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/28/08	DT	R*PLUMB UNDER SLAB VRU #: 001648799
	7/28/08	AP	
B111 01	7/30/08	JH	R*BLDG SLAB INSP VRU #: 001651868
	7/30/08	CA	per John
B111 02	7/31/08	MR	R*BLDG SLAB INSP VRU #: 001652627
	7/31/08	AP	
R427 01	8/25/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001667187
	8/25/08	CA	
R427 02	9/09/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001673854
	9/09/08	DA	1. truss strappingB-03 2. washer plmb too complicated 3. outlets on kitchen walls too fara back 4. firestop kitch. furred walls 5. two jacks required at back door header at each end. 6. hinge wall in living room
R427 03	9/11/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001675479
	9/11/08	DA	1. Plumbing not fixed. 2. Furred wall not fireblocked. Okay to side and insulate.
I129 01	9/22/08	JH	R*INSULATION INSPECTION VRU #: 001680065
	9/22/08	AP	
R427 04	9/22/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001680024
	9/22/08	AP	
H824 01	9/30/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 13:00 VRU #: 001685452
	9/30/08	AP	
R431 01	10/20/08	TI	FOUR TRADE FINAL >2500 VRU #: 001693852
	10/17/08	CA	CANCELLED FINAL INSPECTION. NO ADDRESS CONFIRMATION.
A814 02	10/20/08	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001694728
	10/20/08	AP	✓ 39 ANCIENT OAK CT LOT 196 39 ANCIENT OAK CT LOT 196
R431 02	10/21/08	TI	FOUR TRADE FINAL >2500 VRU #: 001694736
A814 01	10/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001694595
	10/20/08	CA	

*Handwritten signatures and initials:*  
 MRB  
 AP-*[initials]*

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Type of Construction: I

Owner of Building: H+H Const

Building Address: 39 Ancient Oak

Zoning District: \_\_\_\_\_

Zoning Permit No.: \_\_\_\_\_

Conditional Use Permit No.: \_\_\_\_\_

Building Permit No.: 08-50020091

Electrical Permit No.: 11

Insulation Permit No.: 11

Plumbing Permit No.: 11

Mech. Permit No.: 1

Envir. C.O. No.: \_\_\_\_\_

Date: 10-21-8

Mick Ream

Building Official

\_\_\_\_\_

Zoning Official