

SOIL SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: _____
 Proposed Facility: _____ Design Flow (.1949): _____ Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Saprot Class	.1944 Restr Horiz	
3% S		0-24	GR SL	VAR SE					.5
		24-38	SNH SCL	FR S					
		0-24	GR SL	VAR SE					
		24-38	SNH SCL	FR SE					
		0-24	GR SL	VAR SO					
		24-38	SNH SCL	FR SE					
		0-24	GR SL	VAR SE					
		24-38	SNH SCL	FR S					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25" L	25" L
Site LTAR	.5	.5

Other Factors (.1946): _____
 Site Classification (.1948): P
 Evaluated By: QV
 Others Present: _____