

HTE# 08-500-20094R

Harnett County Department of Public Health

25215

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: H & H Const. PROPERTY LOCATION: 1125 SUBDIVISION: FOREST OAKS LOT # 202

NEW [X] REPAIR [] EXPANSION [] Type of Structure: SFD-35x47-3BR Proposed Wastewater System Type: 25% Reduction gals Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: 6 max Basement [] Yes [X] No

Site Improvements required prior to Construction Authorization Issuance:

Pump Required: [] Yes [] No [X] May be required based on final location and elevations of facilities Type of Water Supply: [] Community [X] Public [] Well Distance from well: 100 feet Permit valid for: [X] Five years [] No expiration Permit conditions: meet onsite for final layout - STUB out plumbing shallow, AT GROUND level OR Higher where shown. Maintain all setbacks

Authorized State Agent: J. Waters Date: 12-16-08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: H & H Const. PROPERTY LOCATION: 1125 SUBDIVISION: FOREST OAKS LOT # 202

Facility Type: SFD-35x47-3BR [X] New [] Expansion [] Repair Basement? [] Yes [X] No Basement Fixtures? [] Yes [X] No Type of Wastewater System: SFD-35x47-3BR (Initial) Wastewater Flow: 360 GPD (See note below, if applicable [X]) LPP Repair (Repair)

Installation Requirements/Conditions Number of trenches: 1 Septic Tank Size: 1000 gallons Exact length of each trench: 300 feet Trench Spacing: 9 Feet on Center Pump Tank Size: gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18 MAX inches (Trench bottoms shall be level to +/- 1/4" in all directions) Soil Cover: 6 inches (Maximum soil cover shall not exceed 36" above the trench bottom) Pump Requirements: ft. TDH vs. GPM Aggregate Depth: inches below pipe inches above pipe inches total Conditions:

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: J. Waters Date: 12-16-08 Construction Authorization Expiration Date: 12-12-2013

HTE# 08-500-200942

Permit # 25215

Harnett County Department of Public Health Site Sketch

ISSUED TO: HOH CORP.

PROPERTY LOCATOR: 1125

SUBDIVISION: FORCIST OAKS

LOT # 202

Authorized State Agent: [Signature]

Date: 12-16-08

STATUS out Plumbing shallows, At ground level or higher where shown
maintain all setbacks Install 300' of 25% reduction system at 18' max
meet onsite

