

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 6/12/08

Proposed Facility: 3 bedroom house Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	FP 0.2%	0-8"	G LS	VFL NS/NP					PS .45
		8-36"	SBX SCL	FR SS/NP					
		36-48"	SBX SCL ⁺	FR SS/NP	10YR 7/2 @ 42"				
2		0-12"	G LS	VFL NS/NP					PS .4
		12-36"	SBX SCL	FR SS/SP	10YR 8/1 @ 32"				
3		0-8"	G LS	VFL NS/NP					PS .5
		8-23"	SBX SCL	FR SS/NP					
		23-48"	G S	VFL NS/NP					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	25% RFD
Site LTAR	.45	.4

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: OT
 Others Present: _____

1 x 270' @ 24" - 30"
 REPAIR 1 x 225' @ 18"