

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner:
Address:
Proposed Facility: 4 Bedroom Home Design Flow (.1949): 420 gpd
Location of Site:
Water Supply: Public Individual Well Spring Other
Evaluation Method: Auger Boring Pit Cut
Type of Wastewater: Sewage Industrial Process Mixed

Applicant:
Date Evaluated: 6/2/08
Property Size:
Property Recorded:

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro: Class	.1944 Restr: Horiz	
1	LS 0.2%	0-14"	G SL	VFR NS/NP					PS .5
		14-22"	SBK CL	FR SS/SP					
		42"	G S	VFR NS/NP					
2		0-44"	G SL	VFR NS/NP					PS .7
		44-58"	G S	VFR NS/NP					
3		0-22"	G SL	VFR NS/NP					PS .5
		22-38"	SBK CL	FR SS/SP					
		38-58"	G S	VFR NS/NP					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	.5	.5

Other Factors (.1946): _____
Site Classification (.1948): PS
Evaluated By: [Signature]
Others Present: _____

4x80 @ 42"
= REPAIR