

PERMIT # 24803

Operation Permit

New Installation Septic Tank Repair Nitrification Line Expansion

PROPERTY LOCATION: JOHNSON RD

Name: (owner) CHRIS JOHNSON SUBDIVISION STACEY JOHNSON LOT # 1

System Installer: Ed HUDSON Registration #

Basement with plumbing: Garage Number of Bedrooms 3

Type of Water Supply: Community Public Well Distance from well 100 feet

System Type: III Types V and VI Systems expire in 5 years.

(In accordance with Table V a)


Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

* ON 8-19-08 WATERLINE INSPECTION CALLED FOR. W/L WAS FOUND TO BE INSTALLED THROUGH MIDDLE OF DRAINFIELD REPAIR AREA. Plumber INSTALLED WATERLINES WITHOUT PERMIT IN HAND AND ON job site AGAINST SPECIFIC DIRECTION. O.T. WAS CALLED TO inspect waterline setback (40 min) O.T. Confirmed waterline 10' off septic system (Drainlines, Tank).

* Told Home Owners of mistake and advised on situation. GAVE 2 OPTIONS MOVE OR let stand and have to move when repair is needed. AT OWNERS expense.

* Owner chose option to let waterline stand AS IS and MOVE IT when repair is needed.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
II. Monitoring: As required by Rule .1961.
III. Maintenance: As required by Rule .1961. Other: Subsurface system operator required? Yes No
IV. Operation:
V. Other: ALL SYSTEM COMPONENTS CHECKED ON 8/15/08. WATER LINE STILL TO BE CHECKED

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other EZ Flow Septic Tank: 1000 gallons Pump Tank: gallons
Subsurface No. of exact length width of depth of
Drainage Field ditches 3 of each ditch 100 feet ditches 3 feet ditches 18-24 inches
French Drain Required: Linear feet

Authorized State Agent [Signature] RS Date 8/20/08