
ADDRESS . . : 102 RIVERSTONE DR SUBDIV: RIVERSTONE
CONTRACTOR : SHER LOCH HOMES DM INC PHONE : (919) 777-0666
OWNER . . . : INVESTMENT CHOICES IV PHONE :
PARCEL . . . : 08-0652- - -0025- -09-
APPL NUMBER: 08-50020147 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N RIGHT ON BALLARD RD RIGHT INTO
RIVERSTONE LOT 5 JB

STRUCTURE: 000 000 51X60 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	
B101 01	<u>7/01/08</u> <u>7-1-08</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE	VRU #: 001634609

----- COMMENTS AND NOTES -----

19758069

ADDRESS : 102 RIVERSTONE DR SUBDIV: RIVERSTONE
CONTRACTOR : SHER LOCH HOMES DM INC PHONE : (919) 777-0666
OWNER : INVESTMENT CHOICES IV PHONE :
PARCEL : 08-0652- - -0025- -09-
APPL NUMBER: 08-50020147 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N RIGHT ON BALLARD RD RIGHT INTO
RIVERSTONE LOT 5 JB

STRUCTURE: 000 000 51X60 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/01/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001634609
	7/01/08	AP	
B103 01	7/07/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001637009
	<u>7-7-08</u>	<u>APRS</u>	

----- COMMENTS AND NOTES -----

19758069

ADDRESS . . : 102 RIVERSTONE DR
CONTRACTOR : SHER LOCH HOMES DM INC
OWNER . . . : INVESTMENT CHOICES IV
PARCEL . . . : 08-0652- - -0025- -09-
APPL NUMBER: 08-50020147 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N RIGHT ON BALLARD RD RIGHT INTO
RIVERSTONE LOT 5 JB

STRUCTURE: 000 000 51X60 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/01/08 7/01/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001634609
B103 01	7/07/08 7/07/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001637009 19758069
B105 01	7/10/08 <u>7-10</u>	TI <u>AP</u>	R*OPEN FLOOR VRU #: 001639196

----- COMMENTS AND NOTES -----

ADDRESS : 102 RIVERSTONE DR SUBDIV: RIVERSTONE
CONTRACTOR : SHER LOCH HOMES DM INC PHONE : (919) 777-0666
OWNER : INVESTMENT CHOICES IV PHONE :
PARCEL : 08-0652- - -0025- -09-
APPL NUMBER: 08-50020147 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N RIGHT ON BALLARD RD RIGHT INTO
RIVERSTONE LOT 5 JB

STRUCTURE: 000 000 51X60 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/01/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001634609
	7/01/08	AP	
B103 01	7/07/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001637009
	7/07/08	AP	19758069
B105 01	7/10/08	KS	R*OPEN FLOOR VRU #: 001639196
	7/10/08	AP	
A814 01	8/01/08	TI	ADDRESS CONFIRMATION VRU #: 001654110
	8/01/08	AP	102 RIVERSTONE DR LOT 5
R425 01	8/04/08	TI	FOUR TRADE ROUGH IN VRU #: 001654677

8-04 OA

----- COMMENTS AND NOTES -----

ADDRESS : 102 RIVERSTONE DR SUBDIV: RIVERSTONE
CONTRACTOR : SHER LOCH HOMES DM INC PHONE : (919) 777-0666
OWNER : INVESTMENT CHOICES IV PHONE :
PARCEL : 08-0652- - -0025- -09-
APPL NUMBER: 08-50020147 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 401 N RIGHT ON BALLARD RD RIGHT INTO
RIVERSTONE LOT 5 JB

STRUCTURE: 000 000 51X60 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/01/08 7/01/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001634609
B103 01	7/07/08 7/07/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001637009 19758069
B105 01	7/10/08 7/10/08	KS AP	R*OPEN FLOOR VRU #: 001639196
A814 01	8/01/08 8/01/08	TI AP	ADDRESS CONFIRMATION VRU #: 001654110 102 RIVERSTONE DR LOT 5
R425 01	8/04/08 8/04/08	KS DA	FOUR TRADE ROUGH IN VRU #: 001654677 1. Nuts and washers missing in garage 2. Gas line not secured to floor joists 3. Need a receptacle at floor level in cabinet wall.
I129 01	8/06/08 <u>8-4</u>	TI <u>DA</u>	R*INSULATION INSPECTION VRU #: 001656657 <i>NOT Insulated behind MB TUB</i>
R425 02	8/06/08 <u>8-6</u>	TI <u>AP</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001656990

----- COMMENTS AND NOTES -----

ADDRESS : 102 RIVERSTONE DR SUBDIV: RIVERSTONE
CONTRACTOR : SHER LOCH HOMES DM INC PHONE : (919) 777-0666
OWNER : INVESTMENT CHOICES IV PHONE :
PARCEL : 08-0652- - -0025- -09-
APPL NUMBER: 08-50020147 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 401 N RIGHT ON BALLARD RD RIGHT INTO
RIVERSTONE LOT 5 JB

STRUCTURE: 000 000 51X60 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/01/08 7/01/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001634609
B103 01	7/07/08 7/07/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001637009 19758069
B105 01	7/10/08 7/10/08	KS AP	R*OPEN FLOOR VRU #: 001639196
A814 01	8/01/08 8/01/08	TI AP	ADDRESS CONFIRMATION VRU #: 001654110 102 RIVERSTONE DR LOT 5
R425 01	8/04/08 8/04/08	KS DA	FOUR TRADE ROUGH IN VRU #: 001654677 1. Nuts and washers missing in garage 2. Gas line not secured to floor joists 3. Need a receptacle at floor level in cabinet wall.
I129 01	8/06/08 8/06/08	KS DA	R*INSULATION INSPECTION VRU #: 001656657 not insulated behind master bath tub
R425 02	8/06/08 8/06/08	KS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001656990
I129 02	8/07/08 <u>8-7</u>	TI <u>AP</u>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001658400

----- COMMENTS AND NOTES -----

ADDRESS : 102 RIVERSTONE DR SUBDIV: RIVERSTONE
 CONTRACTOR : SHER LOCH HOMES DM INC PHONE : (919) 777-0666
 OWNER : INVESTMENT CHOICES IV PHONE :
 PARCEL : 08-0652- - -0025- -09-
 APPL NUMBER: 08-50020147 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 401 N RIGHT ON BALLARD RD RIGHT INTO
 RIVERSTONE LOT 5 JB

STRUCTURE: 000 000 51X60 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/01/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001634609
	7/01/08	AP	
B103 01	7/07/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001637009
	7/07/08	AP	19758069
B105 01	7/10/08	KS	R*OPEN FLOOR VRU #: 001639196
	7/10/08	AP	
A814 01	8/01/08	TI	ADDRESS CONFIRMATION VRU #: 001654110
	8/01/08	AP	102 RIVERSTONE DR LOT 5
R425 01	8/04/08	KS	FOUR TRADE ROUGH IN VRU #: 001654677
	8/04/08	DA	1. Nuts and washers missing in garage 2. Gas line not secured to floor joists 3. Need a receptacle at floor level in cabinet wall.
I129 01	8/06/08	KS	R*INSULATION INSPECTION VRU #: 001656657
	8/06/08	DA	not insulated behind master bath tub
R425 02	8/06/08	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001656990
	8/06/08	AP	
I129 02	8/07/08	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001658400
	8/07/08	AP	
H824 01	9/04/08	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001680412
	9/04/08	AP	
R429 01	9/19/08	TI	FOUR TRADE FINAL VRU #: 001679179
	9/18/08	CA	CANCELLED FINAL INSPECTION FOR 09/19/08. NO OPERATIONS PERMIT ISSUED. N-TART
R429 02	9/22/08	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001680420
	<u>9/22/08</u>	<u>ARBS</u>	

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Owner: Shel Corby Homes DM Inc

911 Address: 102 Riverstone

State: NC Zip Code: _____

Date: 9.22.08

Brad Sitter

Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

MFG. Home: _____

085-20147