

01-13-2010  
app # 08-50020158

SCANNED  
1/29/10  
DATE

I went out on a complaint to this house today and met the homeowner and contractor about possible structural failure. There was a large crack in the sheetrock ceiling above the kitchen area. We could find no evidence of structural failure. The contractor is going to repair the sheetrock under the 1 year warranty and see if the problem persists.

Brad Sutton

