

Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 6/11/08

Proposed Facility: 4 Bedroom Home Design Flow (.1949): 480 gpd

Property Size:

Location of Site:

Property Recorded:

- Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2%	0-34"	G S	VFR NS/NP					PS .45
		34-48"	SBK SCL ⁺	FR SS/SP					
2		0-18"	G S	VFR NS/NP					PS .4
		18-40"	SBK SCL	FR SS/SP	VFR 2/2 @ 32" - POSSIBLE LITHOCRANIC				
3		0-10"	G S	VFR NS/NP					PS .4
		10-36"	SBK SCL	FR SS/SP					
		36" ⁺	M SCL	F1 SS/SP					
4		0-6"	G S	VFR NS/NP					US
		6-15"	SBK SCL	F1 SS/SP					
		15" ⁺	PM						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25% RCD	25% RCD
Site LTAR	.4	.4

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: OT
 Others Present: —

1x300' @ R"