

Property ID:  
 Lot #:  
 File #:  
 Code:

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant: 20205

Address:

Date Evaluated: 6-10-08 - 6-11-08

Proposed Facility: SFD

Design Flow (.1949): 480

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public  Individual  Well  Spring  Other

Evaluation Method:  Auger Boring  Pit  Cut

Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Saprot Class	.1944 Restr Horiz	
1	L 45%	0-6	SL	FR GR NSNP					.25
		6-36	SC-clay	FR 1/2" S.P.	30" SL 4.2				
2	L 4%	0-6	SL	FR GR NSNP					.25
		6-30	SC-clay	FR 1/2" S.P.	24" SL 4.2				
3	L 4%	0-6	SL	FR GR NSNP					.25
		6-36	SC-clay	FR 1/2" S.P.	36" SL 4.2				

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25%	25%/LPI?
Site LTAR	.25	.25

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PS  
 Evaluated By: [Signature]  
 Others Present: