


**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: _____
 Proposed Facility: _____ Design Flow (.1949): _____ Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

| P R O F I L E # | 1940 Landscape Position/ Slope% | Horizon Depth (IN.) | SOIL MORPHOLOGY .1941 | | OTHER PROFILE FACTORS | | | | Profile Class & LTAR |
|--------------------------------------|--|---------------------------|--------------------------------|------------------------------------|------------------------------------|------------------------------|-------------------------|-------------------------|----------------------------|
| | | | .1941 Structure/ Texture | .1941 Consistence Mineralogy | .1942 Soil Wetness/ Color | .1943 Soil Depth (IN.) | .1956 Sapro Class | .1944 Restr Horiz | |
| 1 | L 7% | 6-10 | SL | FR GR NSNP | | | | | .3 |
| | | 10-30 | SC | FR 15BK S.P. | | | | | |
| | | 30" | SAP | FR GR NSNP | | 36" | I | | |
| 2 | L 7% | 0-12 | SL | FR GR NSNP | | | | | .3 |
| | | 12-32 | SC | FR 15BK S.P. | | | | | |
| | | 32" | SAP | FR GR NSNP | | 32" | I | | |
| 3 | L 7% | 0-8 | SL | FR GR NSNP | | | | | .3 |
| | | 8-32 | SC | FR 15BK S.P. | | | | | |
| | | 32" | SAP | FR GR NSNP | | 32" | I | | |
| 4 | L 7 | 0-10 | SL | FR GR NSNP | | | | | .3 |
| | | 10-30 | SC | FR 15BK S.P. | | | | | |
| | | 30" | SAP | FR GR NSNP | | 38" | I | | |
| 5 6 7 | L 7% | 0-18 | SL | FR GR NSNP | | | | | .2 |
| | | 18-40 | SC | FR 15BK S.P. | | | | | |

| Description | Initial System | Repair System |
|-------------------------|----------------|---------------|
| Available Space (.1945) | | |
| System Type(s) | 22 | 22 |
| Site LTAR | .2 | .2 |

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: 
 Others Present: _____