

ADDRESS : 3630 WALKER RD
CONTRACTOR : PALM HARBOR HOMES (GC LICENSE)
OWNER : SMALL HORACE II & TRACEY
PARCEL : 12-0555- - -0035- - -
APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
WIRE RD TO WALKER RD RT.JD

SUBDIV: VASHTI HICKS
PHONE : (972) 991-2422
PHONE : (910) 578-2489

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 5.00
SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

B101 01	10/28/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232
---------	----------	----	---

APJH

I-pole passed

*Top is ready
A/50.*

COMMENTS AND NOTES

ADDRESS : 3630 WALKER RD
CONTRACTOR : CANADY BUILDERS INC
OWNER : SMALL HORACE II & TRACEY
PARCEL : 12-0555- - -0035- - -
APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
WIRE RD TO WALKER RD RT.JD

SUBDIV: VASHTI HICKS
PHONE : (910) 471-0053
PHONE : (910) 578-2489

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 5.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/28/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232
	10/28/08	AP	t-pole passed
A814 01	11/12/08	TI	ADDRESS CONFIRMATION VRU #: 001703693
B103 01	11/12/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001703701
	11/12/08	CA	
B103 02	11/13/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001704147

JH

COMMENTS AND NOTES

ADDRESS : 3630 WALKER RD SUBDIV: VASHTI HICKS
CONTRACTOR : CANADY BUILDERS INC PHONE : (910) 471-0053
OWNER : SMALL HORACE II & TRACEY PHONE : (910) 578-2489
PARCEL : 12-0555- - -0035- - -
APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
WIRE RD TO WALKER RD RT.JD

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 5.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/28/08 10/28/08	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232 t-pole passed
B103 01	11/12/08 11/12/08	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001703701
A814 01	11/12/08 11/12/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001703693 3630 Walker Rd
B103 02	11/13/08 11/13/08	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001704147 Foundation can not be inspected until dirt is removed from footings inside & outside of foundation wall & also around piers, most of floor system is already in before foundation inspection , do not continue until you get caught up with inspections. Pay \$50.00 reinspection fee
B103 03	11/18/08	TI <i>DA JH</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001706324

----- COMMENTS AND NOTES -----

ADDRESS : 3630 WALKER RD
 CONTRACTOR : CANADY BUILDERS INC
 OWNER : SMALL HORACE II & TRACEY
 PARCEL : 12-0555- - -0035- - -
 APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
 WIRE RD TO WALKER RD RT.JD

SUBDIV: VASHTI HICKS
 PHONE : (910) 471-0053
 PHONE : (910) 578-2489

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/28/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232
	10/28/08	AP	t-pole passed
B103 01	11/12/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001703701
	11/12/08	CA	
A814 01	11/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001703693
	11/12/08	AP	3630 Walker Rd
B103 02	11/13/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001704147
	11/13/08	DP	Foundation can not be inspected until dirt is removed from footings inside & outside of foundation wall & also around piers, most of floor system is already in before foundation inspection , do not continue until you get caught up with inspections. Pay \$50.00 reinspection fee
B103 03	11/18/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001706324
	11/18/08	DA	1)Center of pier not in the center 1/3 of the footing, circled in red on plans. 2)Pier on left corner of front porch has no projection on corner. 3)Need anchor bolts every 6 feet & 1 foot from every corner per code.
3103 04	11/21/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001708445
	<u>11/21/08</u>	<u>AR DJ</u>	

COMMENTS AND NOTES

ADDRESS : 3630 WALKER RD SUBDIV: VASHTI HICKS
 CONTRACTOR : CANADY BUILDERS INC PHONE : (910) 471-0053
 OWNER : SMALL HORACE II & TRACEY PHONE : (910) 578-2489
 PARCEL : 12-0555- - -0035- - -
 APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
 WIRE RD TO WALKER RD RT.JD

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/28/08 10/28/08	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232 t-pole passed
B103 01	11/12/08 11/12/08	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001703701
A814 01	11/12/08 11/12/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001703693 3630 Walker Rd
B103 02	11/13/08 11/13/08	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001704147 Foundation can not be inspected until dirt is removed from footings inside & outside of foundation wall & also around piers, most of floor system is already in before foundation inspection , do not continue until you get caught up with inspections. Pay \$50.00 reinspection fee
B103 03	11/18/08 11/18/08	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001706324 1)Center of pier not in the center 1/3 of the footing, circled in red on plans. 2)Pier on left corner of front porch has no projection on corner. 3)Need anchor bolts every 6 feet & 1 foot from every corner per code.
B103 04	11/21/08 11/21/08	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001708445
B105 01	11/24/08 <u>11-24-08</u>	TI <u>DPBS</u>	R*OPEN FLOOR TIME: 17:00 VRU #: 001708932

COMMENTS AND NOTES

ADDRESS : 3630 WALKER RD
 CONTRACTOR : CANADY BUILDERS INC
 OWNER : SMALL HORACE II & TRACEY
 PARCEL : 12-0555- - -0035- - -
 APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
 WIRE RD TO WALKER RD RT.JD

SUBDIV: VASHTI HICKS
 PHONE : (910) 471-0053
 PHONE : (910) 578-2489

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/28/08 10/28/08	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232 t-pole passed
B103 01	11/12/08 11/12/08	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001703701
A814 01	11/12/08 11/12/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001703693 3630 Walker Rd
B103 02	11/13/08 11/13/08	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001704147 Foundation can not be inspected until dirt is removed from footings inside & outside of foundation wall & also around piers, most of floor system is already in before foundation inspection , do not continue until you get caught up with inspections. Pay \$50.00 reinspection fee
B103 03	11/18/08 11/18/08	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001706324 1)Center of pier not in the center 1/3 of the footing, circled in red on plans. 2)Pier on left corner of front porch has no projection on corner. 3)Need anchor bolts every 6 feet & 1 foot from every corner per code.
B103 04	11/21/08 11/21/08	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001708445
B105 01	11/24/08 11/24/08	BS DP	R*OPEN FLOOR TIME: 17:00 VRU #: 001708932 1. All joints in girders must be over a pier, including the center board of a triple. 2. All girders must be in the center 1/3 of the supporting pier. 3. The sill plate supporting the floor system must be the one bolted to the foundation. Do not cover \$50. re fee
B105 02	11/26/08 <u>11/24/08</u>	TI <u>DA DT</u>	R*OPEN FLOOR TIME: 17:00 VRU #: 001710813
B111 01	11/26/08 <u>11/24/08</u>	TI <u>AP DT</u>	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001710839 WILL BE A MONOLITHIC.

COMMENTS AND NOTES

ADDRESS : 3630 WALKER RD SUBDIV: VASHTI HICKS
 CONTRACTOR : CANADY BUILDERS INC PHONE : (910) 471-0053
 OWNER : SMALL HORACE II & TRACEY PHONE : (910) 578-2489
 PARCEL : 12-0555- - -0035- - -
 APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
 WIRE RD TO WALKER RD RT.JD

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/28/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232
	10/28/08	AP	t-pole passed
B103 01	11/12/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001703701
	11/12/08	CA	
A814 01	11/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001703693
	11/12/08	AP	3630 Walker Rd
B103 02	11/13/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001704147
	11/13/08	DP	Foundation can not be inspected until dirt is removed from footings inside & outside of foundation wall & also around piers, most of floor system is already in before foundation inspection , do not continue until you get caught up with inspections. Pay \$50.00 reinspection fee
B103 03	11/18/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001706324
	11/18/08	DA	1)Center of pier not in the center 1/3 of the footing, circled in red on plans. 2)Pier on left corner of front porch has no projection on corner. 3)Need anchor bolts every 6 feet & 1 foot from every corner per code.
B103 04	11/21/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001708445
	11/21/08	AP	
B105 01	11/24/08	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001708932
	11/24/08	DP	1. All joints in girders must be over a pier, including the center board of a triple. 2. All girders must be in the center 1/3 of the supporting pier. 3. The sill plate supporting the floor system must be the one bolted to the foundation. Do not cover \$50. re fee
B105 02	11/26/08	DT	R*OPEN FLOOR TIME: 17:00 VRU #: 001710813
	11/26/08	DA	X Two girders not full bearing on piers. X Bolts angled at front porch.
B111 01	11/26/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001710839
	11/26/08	AP	WILL BE A MONOLITHIC.
B105 03	12/03/08	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 001712611

AP JH

COMMENTS AND NOTES

ADDRESS : 3630 WALKER RD SUBDIV: VASHTI HICKS
CONTRACTOR : CANADY BUILDERS INC PHONE : (910) 471-0053
OWNER : SMALL HORACE II & TRACEY PHONE : (910) 578-2489
PARCEL : 12-0555- - -0035- - -
APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R427 03	1/26/09	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001728120
	1/26/09	CA	called and canceled
R427 04	1/28/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001729193
	<i>1-28-09</i>	<i>DA JH</i>	

----- COMMENTS AND NOTES -----

ADDRESS : 3630 WALKER RD SUBDIV: VASHTI HICKS
 CONTRACTOR : CANADY BUILDERS INC PHONE : (910) 471-0053
 OWNER : SMALL HORACE II & TRACEY PHONE : (910) 578-2489
 PARCEL : 12-0555- - -0035- - -
 APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
 WIRE RD TO WALKER RD RT.JD

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/28/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232
	10/28/08	AP	t-pole passed
B103 01	11/12/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001703701
	11/12/08	CA	
A814 01	11/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001703693
	11/12/08	AP	3630 Walker Rd
B103 02	11/13/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001704147
	11/13/08	DP	Foundation can not be inspected until dirt is removed from footings inside & outside of foundation wall & also around piers, most of floor system is already in before foundation inspection, do not continue until you get caught up with inspections.
			Pay \$50.00 reinspection fee
B103 03	11/18/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001706324
	11/18/08	DA	1)Center of pier not in the center 1/3 of the footing, circled in red on plans. 2)Pier on left corner of front porch has no projection on corner. 3)Need anchor bolts every 6 feet & 1 foot from every corner per code.
B103 04	11/21/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001708445
	11/21/08	AP	
B105 01	11/24/08	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001708932
	11/24/08	DP	1. All joints in girders must be over a pier, including the center board of a triple. 2. All girders must be in the center 1/3 of the supporting pier. 3. The sill plate supporting the floor system must be the one bolted to the foundation. Do not cover \$50. re fee
B105 02	11/26/08	DT	R*OPEN FLOOR TIME: 17:00 VRU #: 001710813
	11/26/08	DA	1. Two girders not full bearing on piers. 2. Bolts angled at front porch.
B111 01	11/26/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001710839
	11/26/08	AP	WILL BE A MONOLITHIC.
B105 03	12/03/08	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001712611
	12/03/08	AP	
R427 01	1/22/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001727569
	1/22/09	CA	
R427 02	1/23/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001727890
	1/23/09	CA	

Application number, type 08 50020228 CP NEW RESIDENTIAL (SFD)

Property address 3630 WALKER RD

- 1) 14' max on flex duct for bath room exhaust fans.
- 2) A84 & B81 2ply roof truss need to be nailed per truss drawings.
- 3) A84 & B81 2ply truss need more strapping per truss drawings.
- 4) Need 100 psi on water lines.
- 5) Replace all cut or damaged straps for roof truss.
- 6) Missing bracing on A82, A83 & B82 roof truss per truss drawings.
- 7) Duct work under house needs to be 4" from the ground.



OK Exit Cancel Copy Insert Delete Time stamp User defaults

ADDRESS : 3630 WALKER RD
CONTRACTOR : CANADY BUILDERS INC
OWNER : SMALL HORACE II & TRACEY
PARCEL : 12-0555- - -0035- - -
APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)

SUBDIV: VASHTI HICKS
PHONE : (910) 471-0053
PHONE : (910) 578-2489

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R427 03	1/26/09	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001728120
	1/26/09	CA	called and canceled
R427 04	1/28/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001729193
	1/28/09	DA	<ul style="list-style-type: none">1) 14' max on flex duct for bath room exhaust fans.2) A04 & B01 2ply roof truss need to be nailed per truss drawings.3) A04 & B01 2ply truss need more strapping per truss drawings.4) Need 100 psi on water lines.5) Replace all cut or damaged straps for roof truss.6) Missing bracing on A02, A03 & B02 roof truss per truss drawings.7) Duct work under house needs to be 4" from the ground.
R427 05	2/02/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001730480

2-2-09 *ALJH*

COMMENTS AND NOTES

ADDRESS : 3630 WALKER RD SUBDIV: VASHTI HICKS
 CONTRACTOR : CANADY BUILDERS INC PHONE : (910) 471-0053
 OWNER : SMALL HORACE II & TRACEY PHONE : (910) 578-2489
 PARCEL : 12-0555- - -0035- - -
 APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
 WIRE RD TO WALKER RD RT.JD

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/28/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232
	10/28/08	AP	t-pole passed
B103 01	11/12/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001703701
	11/12/08	CA	
A814 01	11/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001703693
	11/12/08	AP	3630 Walker Rd
B103 02	11/13/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001704147
	11/13/08	DP	Foundation can not be inspected until dirt is removed from footings inside & outside of foundation wall & also around piers, most of floor system is already in before foundation inspection , do not continue until you get caught up with inspections. Pay \$50.00 reinspection fee
B103 03	11/18/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001706324
	11/18/08	DA	1)Center of pier not in the center 1/3 of the footing, circled in red on plans. 2)Pier on left corner of front porch has no projection on corner. 3)Need anchor bolts every 6 feet & 1 foot from every corner per code.
B103 04	11/21/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001708445
	11/21/08	AP	
B105 01	11/24/08	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001708932
	11/24/08	DP	1. All joints in girders must be over a pier, including the center board of a triple. 2. All girders must be in the center 1/3 of the supporting pier. 3. The sill plate supporting the floor system must be the one bolted to the foundation. Do not cover \$50. re fee
B105 02	11/26/08	DT	R*OPEN FLOOR TIME: 17:00 VRU #: 001710813
	11/26/08	DA	1. Two girders not full bearing on piers. 2. Bolts angled at front porch.
B111 01	11/26/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001710839
	11/26/08	AP	WILL BE A MONOLITHIC.
B105 03	12/03/08	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001712611
	12/03/08	AP	
R427 01	1/22/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001727569
	1/22/09	CA	
R427 02	1/23/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001727890
	1/23/09	CA	



Heating & Cooling Inc.
7213 Ogden Business Ln.
Suite 212
Wilmington NC, 28411

Jan 28 09 01:03
Jan 28 09 01:03

S
Da.
Fror.
To:

Fax Transmittal Form

To: 984-4768
893-2793

FROM:
Al Moore

Phone: 910-686-8174
Fax: 910-686-8175

Date sent: 1/28/2009

Time sent: 1:00 pm

Number of pages including cover page: 3

any Ave., P.O. Box 36

Attr
P
ment
ply

Re: Permit 08-50020228
3630 Walker Rd.

Notice- Lambro In
and it is given an
laboratory testin
such, Lambro I
responsible or
particular use
The
product or m
application. U
Proper
building codes

As per your request, I have attached the manufactures specs and the label from the box of the product we use to vent the bathroom exhaust fan in the home listed above. This is not a UL 181 listed product and is not limited to the 14 foot restriction. We purchase and utilize this product for this application, primarily for this reason and have done so for several years. I hope this information is helpful to you in this matter. We
I thank you for your help and look forward in dealing with you again in the future. Please feel free to call me @ 910-443-3066

Sincerely: Al Moore
Technical Services
Heating & Cooling Inc.

Flexible Laminate

- Description: -Flexit
- Construction: -Poly
- Diameters: -3", 4", 5
- Gauge: -1mil/1 mil
- Maximum Positive Pr
- Maximum Negative P
- Maximum Velocity: -40
- Temperature Range: -1
- Maximum Operating Te
- Flame Spread Index: -L
- Smoke Developed Index
- Film Tensile Strength (av
- Application: - HVAC
- Meets requirements of NF

with such.

PREPARED 2/04/09, 13:59:41
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 5
DATE 2/05/09

ADDRESS : 3630 WALKER RD
CONTRACTOR : CANADY BUILDERS INC
OWNER : SMALL HORACE II & TRACEY
PARCEL : 12-0555- - -0035- - -
APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)

SUBDIV: VASHTI HICKS
PHONE : (910) 471-0053
PHONE : (910) 578-2489

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R427 03	1/26/09	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001728120
	1/26/09	CA	called and canceled
R427 04	1/28/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001729193
	1/28/09	DA	1)14' max on flex duct for bath room exhaust fans. 2)A04 & B01 2ply roof truss need to be nailed per truss drawings. 3)A04 & B01 2ply truss need more strapping per truss drawings. 4)Need 100 psi on water lines. 5)Replace all cut or damaged straps for roof truss. 6)Missing bracing on A02, A03 & B02 roof truss per truss drawings. 7)Duct work under house needs to be 4" from the ground.
R427 05	2/02/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001730480
	2/02/09	AP	
I129 01	2/04/09	TI	R*INSULATION INSPECTION VRU #: 001731710
	2/03/09	CA	
I129 02	2/05/09	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001731769

2-5-09 AP JA

COMMENTS AND NOTES

ADDRESS : 3630 WALKER RD
 CONTRACTOR : CANADY BUILDERS INC
 OWNER : SMALL HORACE II & TRACEY
 PARCEL : 12-0555- - -0035- - -
 APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : RT 401 RT ON MCNEILL HOBBS RD LEFT ON
 WIRE RD TO WALKER RD RT.JD

SUBDIV: VASHTI HICKS
 PHONE : (910) 471-0053
 PHONE : (910) 578-2489

STRUCTURE: 000 000 82X42 5BR 3.5 BATH 2 CAR GAR WITH DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/28/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001698232
	10/28/08	AP	t-pole passed
B103 01	11/12/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001703701
	11/12/08	CA	
A814 01	11/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001703693
	11/12/08	AP	3630 Walker Rd
B103 02	11/13/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001704147
	11/13/08	DP	Foundation can not be inspected until dirt is removed from footings inside & outside of foundation wall & also around piers, most of floor system is already in before foundation inspection, do not continue until you get caught up with inspections.
			Pay \$50.00 reinspection fee
B103 03	11/18/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001706324
	11/18/08	DA	1)Center of pier not in the center 1/3 of the footing, circled in red on plans. 2)Pier on left corner of front porch has no projection on corner. 3)Need anchor bolts every 6 feet & 1 foot from every corner per code.
B103 04	11/21/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001708445
	11/21/08	AP	
B105 01	11/24/08	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001708932
	11/24/08	DP	1. All joints in girders must be over a pier, including the center board of a triple. 2. All girders must be in the center 1/3 of the supporting pier. 3. The sill plate supporting the floor system must be the one bolted to the foundation. Do not cover \$50. re fee
B105 02	11/26/08	DT	R*OPEN FLOOR TIME: 17:00 VRU #: 001710813
	11/26/08	DA	1. Two girders not full bearing on piers. 2. Bolts angled at front porch.
B111 01	11/26/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001710839
	11/26/08	AP	WILL BE A MONOLITHIC.
B105 03	12/03/08	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001712611
	12/03/08	AP	
R427 01	1/22/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001727569
	1/22/09	CA	
R427 02	1/23/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001727890
	1/23/09	CA	

CONTINUED ONTO NEXT PAGE

ADDRESS : 3630 WALKER RD
 CONTRACTOR : CANADY BUILDERS INC
 OWNER : SMALL HORACE II & TRACEY
 PARCEL : 12-0555- - -0035- - -
 APPL NUMBER: 08-50020228 CP NEW RESIDENTIAL (SFD)

SUBDIV: VASHTI HICKS
 PHONE : (910) 471-0053
 PHONE : (910) 578-2489

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R427 03	1/26/09	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001728120
	1/26/09	CA	called and canceled
R427 04	1/28/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001729193
	1/28/09	DA	1)14' max on flex duct for bath room exhaust fans. 2)A04 & B01 2ply roof truss need to be nailed per truss drawings. 3)A04 & B01 2ply truss need more strapping per truss drawings. 4)Need 100 psi on water lines. 5)Replace all cut or damaged straps for roof truss. 6)Missing bracing on A02, A03 & B02 roof truss per truss drawings. 7)Duct work under house needs to be 4" from the ground.
R427 05	2/02/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001730480
	2/02/09	AP	
I129 01	2/04/09	TI	R*INSULATION INSPECTION VRU #: 001731710
	2/03/09	CA	
I129 02	2/05/09	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001731769
	2/05/09	AP	
H824 01	2/16/09	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001735570
	2/16/09	AP	
R431 01	3/23/09	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 001744911

3-23-09
[Signature]

COMMENTS AND NOTES

[Large handwritten signature]

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: V

Owner: HARACE SMALL

911 Address: 3630 WALKER DR

State: A Zip Code: _____

Date: 3-23-9

[Signature]
Building Official

PERMIT NUMBERS

Building Permit No.: 8-5-20228


Electrical Permit No.: 8-5-20228

Insulation Permit No.: 8-5-20228

Plumbing Permit No.: 8-5-20228

Mech. Permit No.: 8-5-20228

MFG. Home: _____



Heating & Cooling Inc.
7213 Ogden Business Ln.
Suite 212
Wilmington NC, 28411

Fax Transmittal Form

TO: LILLINGTON INSPECT.

FROM:

Attn: Jimmy Hall

Al Moore

Phone number: 910-984-4768

Phone: 910-686-8174

Fax number: 910-893-2793

Fax: 910-686-8175

- Urgent
- For Review
- Please Comment
- Please Reply

Date sent: 1/28/2009

Time sent: 1:00 pm

Number of pages including cover page: 3

Message:

Re: Permit 08-50020228

3630 Walker Rd.

As per your request, I have attached the manufactures specs and the label from the box of the product we use to vent the bathroom exhaust fan in the home listed above. This is not a UL 181 listed product and is not limited to the 14 foot restriction. We purchase and utilize this product for this application, primarily for this reason and have done so for several years. I hope this information is helpful to you in this matter.

I thank you for your help and look forward in dealing with you again in the future. Please feel free to call me @ 910-443-3066

Sincerely: Al Moore
Technical Services
Heating & Cooling Inc.

Subj: **[Fwd: 400 Series Spec..doc]**
 Date: 1/28/2009 11:22:18 AM Eastern Standard Time
 From: benjie.mccall@mccallsinc.net
 To: hvacts@aol.com



any Ave., P.O. Box 367, Amityville, New York-11701
Phone # 631-842-8088, Fax # 631-841-1370

Notice- Lambro Industries furnishes technical information without charge or obligation and it is given and accepted at the recipient's sole risk. Information given is based on laboratory testing, actual conditions of use may vary and are beyond our control, as such, Lambro Industries, Inc. can make no representation about, and can not be responsible or liable for the accuracy or reliability of such data, applied toward the particular uses or application of any product describe herein.

The user must assume all risk and liability in connection with the use of the product or materials and must determine the suitability of the product for their application. Users are strongly advised to test under actual conditions prior to use.

Properties are representative and subject to change without notice. Consult local building codes for application suitability.

Flexible Laminate Duct: -400 series

- Description: -Flexible Air Connector
- Construction: -Polyester / Aluminum laminated, galvanized hard drawn spring wire helix
- Diameters: -3", 4", 5", 6", 7", 8", 9", 10"
- Gauge: -1mil/1 mil
- Maximum Positive Pressure: -6" W.C.
- Maximum Negative Pressure: -1/2" W.C.
- Maximum Velocity: -4000 fpm
- Temperature Range: -55 degrees F. to +300 degree F. Continuous use
- Maximum Operating Temperature: -250 Degrees F.
- Flame Spread Index: -Less then 25- U.L. 723
- Smoke Developed Index: - Less then 50 - U.L. 723
- Film Tensile Strength (average): - >13500 P.S.I ASTM-D882
- Application: - HVAC
- Meets requirements of NFPA 90A, 90B, when installed in accordance with such.

ITEM NUMBER

413



DESCRIPTION:

**3" X 25' LamaFlex Connector
5 Layer Foil Laminate**

PACK QUANTITY:

1 Pc.



01169 11:21

