
ADDRESS . . : 145 FAIR BARN RD
 CONTRACTOR : CUMBERLAND HOMES INC
 OWNER . . . : SILVERADO HOMES LLC #82
 PARCEL . . . : 03-9577- - -0028- -82-
 APPL NUMBER: 08-50020256 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : PERSIMMON HILL #82-27W RT HOOVER RD
 LEFT WELLSTONE RT FAIR BARN.JD

SUBDIV: PERSIMMON HILL 83LOTS
 PHONE : (910) 892-4345
 PHONE : (910) 892-4345

STRUCTURE: 000 000 57X42 3BR W/GRG,PATIO, FN BNRM (01)
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/15/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001662592
A814 01	8/15/08	AP	
	9/04/08	TI	ADDRESS CONFIRMATION VRU #: 001671429
B103 01	<u>9/04/08</u> 9-4-8	TI AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001671411

COMMENTS AND NOTES

FS

ADDRESS : 145 FAIR BARN RD SUBDIV: PERSIMMON HILL 83LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : SILVERADO HOMES LLC #82 PHONE : (910) 892-4345
PARCEL : 03-9577- - -0028- -82-
APPL NUMBER: 08-50020256 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PERSIMMON HILL #82-27W RT HOOVER RD
LEFT WELLSTONE RT FAIR BARN.JD

STRUCTURE: 000 000 57X42 3BR W/GRG, PATIO, FN BNRM (01)
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/15/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001662592
	8/15/08	AP	
A814 01	9/04/08	TI	ADDRESS CONFIRMATION VRU #: 001671429
	9/08/08	AP	145 FAIR BARN RD LOT 82
B103 01	9/04/08	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001671411
	9/04/08	AP	
P309 01	9/10/08	TT	R*PLUMB UNDER SLAB VRU #: 001674555

9/10/08 *AP*

----- COMMENTS AND NOTES -----

FS

ADDRESS . . : 145 FAIR BARN RD SUBDIV: PERSIMMON HILL 83LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . . : SILVERADO HOMES LLC #82 PHONE : (910) 892-4345
PARCEL . . . : 03-9577- - -0028- -82-
APPL NUMBER: 08-50020256 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PERSIMMON HILL #82-27W RT HOOVER RD
LEFT WELLSTONE RT FAIR BARN.JD

STRUCTURE: 000 000 57X42 3BR W/GRG,PATIO,PN BNRM (01)
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/15/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001662592
	8/15/08	AP	
A814 01	9/04/08	TI	ADDRESS CONFIRMATION VRU #: 001671429
	9/08/08	AP	145 FAIR BARN RD LOT 82
B103 01	9/04/08	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001671411
	9/04/08	AP	
P309 01	9/10/08	FS	R*PLUMB UNDER SLAB VRU #: 001674555
	9/10/08	AP	
B111 01	9/12/08	TI	R*BLDG SLAB INSP VRU #: 001675982
	9-12-8	AP	

----- COMMENTS AND NOTES -----

FS

ADDRESS : 145 FAIR BARN RD SUBDIV: PERSIMMON HILL 83LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : SILVERADO HOMES LLC #82 PHONE : (910) 892-4345
PARCEL : 03-9577- - -0028- -82-
APPL NUMBER: 08-50020256 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PERSIMMON HILL #82-27W RT HOOVER RD
LEFT WELLSTONE RT FAIR BARN.JD

STRUCTURE: 000 000 57X42 3BR W/GRG,PATIO,PN BNRM (01)
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/15/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001662592
	8/15/08	AP	
A814 01	9/04/08	TI	ADDRESS CONFIRMATION VRU #: 001671429
	9/08/08	AP	145 FAIR BARN RD LOT 82
B103 01	9/04/08	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001671411
	9/04/08	AP	
P309 01	9/10/08	FS	R*PLUMB UNDER SLAB VRU #: 001674555
	9/10/08	AP	
B111 01	9/12/08	FS	R*BLDG SLAB INSP VRU #: 001675982
	9/12/08	AP	
R425 01	10/15/08	JH	FOUR TRADE ROUGH IN VRU #: 001691237
	10/15/08	DA	1)Missing jack studs under each end of triple TJIs plans call for 6 jack studs. 2)Missing fire caulk on all wires on first floor. 3)Missing nails in roof truss hangers in bed #2 on 2ply truss. 4)Need 3' head of water on drain line test.
I129 01	10/21/08	TI	R*INSULATION INSPECTION VRU #: 001694561
	10-21-8	AP	
R425 02	10/21/08	TI	FOUR TRADE ROUGH IN VRU #: 001694579
	10-21-8	AP	

----- COMMENTS AND NOTES -----

ADDRESS : 145 FAIR BARN RD SUBDIV: PERSIMMON HILL 83LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : SILVERADO HOMES LLC #82 PHONE : (910) 892-4345
PARCEL : 03-9577- - -0028- -82-
APPL NUMBER: 08-50020256 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : PERSIMMON HILL #82-27W RT HOOVER RD
LEFT WELLSTONE RT FAIR BARN.JD

STRUCTURE: 000 000 57X42 3BR W/GRG, PATIO, FN BNRM (01)
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/15/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001662592
	8/15/08	AP	
A814 01	9/04/08	TI	ADDRESS CONFIRMATION VRU #: 001671429
	9/08/08	AP	✓ 145 FAIR BARN RD LOT 82
B103 01	9/04/08	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001671411
	9/04/08	AP	
P309 01	9/10/08	FS	R*PLUMB UNDER SLAB VRU #: 001674555
	9/10/08	AP	
B111 01	9/12/08	FS	R*BLDG SLAB INSP VRU #: 001675982
	9/12/08	AP	
R425 01	10/15/08	JH	FOUR TRADE ROUGH IN VRU #: 001691237
	10/15/08	DA	1)Missing jack studs under each end of triple TJIs plans call for 6 jack studs. 2)Missing fire caulk on all wires on first floor. 3)Missing nails in roof truss hangers in bed #2 on 2ply truss. 4)Need 3' head of water on drain line test.
I129 01	10/21/08	FS	R*INSULATION INSPECTION VRU #: 001694561
	10/21/08	AP	
R425 02	10/21/08	FS	FOUR TRADE ROUGH IN VRU #: 001694579
	10/21/08	AP	
R429 01	12/15/08	TI	FOUR TRADE FINAL VRU #: 001716059
	12/12/08	CA	CANCELLED FINAL INSPECTION FOR 12/15/08. NO OPERATIONS. N-TART
R429 02	12/18/08	TI	FOUR TRADE FINAL VRU #: 001718246
	12/17/08	CA	CANCELLED FINAL INSPECTION. NO OPERATIONS PERMIT. N-TART
H824 01	1/05/09	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001723212
	1/05/09	AP	
R431 01	1/08/09	TI	FOUR TRADE FINAL >2500 VRU #: 001723758

1-8-9 AP

JS

COMMENTS AND NOTES

PE 11:45
1-8-9

09603171

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: K

PERMIT NUMBERS

Owner: SILVERADO Homes

Building Permit No.: 8-5-20255

911 Address: 145 FAIR BARR

Electrical Permit No.: 8-5-20256

Insulation Permit No.: 8-5-20256

Plumbing Permit No.: 8-5-20256

Mech. Permit No.: 8-5-20256

MFG. Home: _____

State: _____ Zip Code: _____

Date: 1-8-9

[Signature]

Building Official