

HTE# 08-500-202562

Harnett County Department of Public Health

24954

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cumberland Homes; PROPERTY LOCATION: Hoover Rd; SUBDIVISION: Persimmon H.11; LOT # 82; Type of Structure: SFD-57x42-302; Proposed Wastewater System Type: Pump to 25% Reduct-50ft; Projected Daily Flow: 360 GPD; Number of bedrooms: 3; Number of Occupants: 6 max; Basement: No; Pump Required: Yes; Type of Water Supply: Public; Permit conditions: Meet on site maintain all setbacks STUB at Plumbing shallow at ground level or higher

Authorized State Agent: J. L. Warr; Date: 08-12-08; SEE ATTACHED SITE SKETCH; The issuance of this permit by the Health Department in no way guarantees the issuance of other permits.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: Cumberland Homes; PROPERTY LOCATION: Hoover Rd; SUBDIVISION: Persimmon H.11; LOT # 82; Facility Type: SFD-57x42-302 New; Basement: No; Type of Wastewater System: Pump to 25% Reduct-50ft (Initial) Wastewater Flow: 360 GPD; 25% Reduction system (Repair)

Installation Requirements/Conditions: Septic Tank Size 1000 gallons; Pump Tank Size 1000 gallons; Number of trenches 1; Exact length of each trench 300 feet; Trench Spacing: 9 Feet on Center; Soil Cover: 6 inches; Pump Requirements: _____ ft. TDH vs. _____ GPM; Aggregate Depth: _____ inches below pipe, _____ inches above pipe, _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: J. L. Warr; Date: 08-12-08; Construction Authorization Expiration Date: 08-12-2013

HTE# 08-500-20256R

Permit # 24954

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cumberland Home PROPERTY LOCATOR: Hoover Rd
SUBDIVISION: Per Summer Hill LOT # 82

Authorized State Agent: J. W. [Signature] Date: 08-12-08

Meet onsite

Maintain All set Backs

Install 300 + 25% Reduction system at 18"

