

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: \_\_\_\_\_ Applicant: \_\_\_\_\_  
 Address: \_\_\_\_\_ Date Evaluated: \_\_\_\_\_  
 Proposed Facility: \_\_\_\_\_ Design Flow (.1949): \_\_\_\_\_ Property Size: \_\_\_\_\_  
 Location of Site: \_\_\_\_\_ Property Recorded: \_\_\_\_\_  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapra Class	.1944 Restr Horiz	
5 30%		0-24	GR SL	VFR JE					.4
		24-32	SBKJCL	FR JE					
		32-78	SBKJCL	FR SF					
		0-30	GR SL	VFR JE					.5
		30-38	SBKJCL	FR SF					
		0-30	GR SL	VFR JE					.5
		30-38	SBKJCL	FR SF					
		0-24	GR SL	VFR JE					.4
		24-32	SBKJCL	FR JE					
		32-78	SBKJCL	FR SF					
		0-30	GR SL	VFR JE					.4
		30-38	SBKJCL	FR SF					
	0-24	GR SL	VFR SF					.4	
	24-32	SBKJCL	FR JE						
	32-78	SBKJCL	FR JE						

Description	Initial System	Repair System
Available Space (.1945)	✓	
System Type(s)	25%	25%
Site LTAR	.4	.4

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PJ  
 Evaluated By: GW  
 Others Present: \_\_\_\_\_