

June 25, 2008

Comfort Homes Inc
P O Box 369
Clayton, NC 27528

Re: Status of Improvement Permit Application Forest Trails Lots: 98,100,101,103,104
08-5-20291, 08-5-20299, 08-5-20292, 08-5-20293,
08-5-20294

To Whom It May Concern,

On , an attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Property lines/corners not marked or labeled (*\$25.00 fee incurred*)
- 2. House corners not marked or labeled (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs brush or vegetation removed
- 5. Backhoe pits required
- 6. *Other – Please see the attached regarding the above listed lots. Setbacks and flags do not match site plans. Any changes to applications will require a revision to be submitted to Central Permitting.*

Your application will be put on hold until the selected items above have been addressed.
When completed please call 910-893-7547 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Bryan McSwain, R. S.
Environmental Health Specialist
Harnett County Department of Public Health

BM/sgs
Copy: Central Permitting

Forest Trails

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

08-5-20291 - Lt 98

House flags 64' x 32' (not 64' x 41') – per site plan
Front setback 43' not 40'

08-5-20299 – Lt 100

House flags 58' x 29' (not 62' x 40') – per site plan
Front setback 49' not 40'

08-5-20292 – Lt 101

House flags 72' x 36' (not 70' x 46') – per site plan
Front setback 44' not 40'

08-5-20293 – Lt 103

House flags 69' x 49' (not 69' x 64') – per site plan

08-5-20294 – Lt 104

House flags 58' x 29' (not 58' x 39') – per site plan

If houses have decks, either mark decks with flags or have decks contained in footprint of house flags.