

HTE# 08-5-20299

Harnett County Department of Public Health 24575

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Comfort Homes, Inc.
 NEW REPAIR EXPANSION
 Type of Structure: SFD 62' x 46' Garage + Deck
 Proposed Wastewater System Type: Pump to 25% Reduction
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet
 Permit conditions: _____

PROPERTY LOCATION: Christian Light Rd.
 SUBDIVISION Forest Trail LOT # 100
 Site Improvements required prior to Construction Authorization Issuance: _____

Permit valid for: Five years
 No expiration

Authorized State Agent: Bryan McSwain, P.E. Date: 7/7/2008 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Comfort Homes, Inc. PROPERTY LOCATION: Christian Light Rd.
 SUBDIVISION Forest Trail LOT # 100
 Facility Type: SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** pump to 25% Reduction (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable
pump to 25% Reduction (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 4 x 80 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 18 MAX inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/- 1/4" in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 _____ inches total
 Conditions: Run drain lines on contour & NO DEEPER than 18 inches
See drawing for Manhole Specifications

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Bryan McSwain, P.E. Date: 7/7/2008 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 7/7/2013

HTE# 08-5-20299

Permit # 24575

Harnett County Department of Public Health Site Sketch

ISSUED TO: Comfort Homes, Inc. PROPERTY LOCATOR: Christian Light Rd
SUBDIVISION: Forest Trails LOT # 100

Authorized State Agent: Bryan McSwain, R.S. Date: 7/7/2005

* Use 4 1/2" sch 40 TAPS
* 5" draw down
TDH 1 ft 30gpm

