

Property ID:  
 Lot #:  
 File #:  
 Code:

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 2/30/08

Proposed Facility: 3 BEDROOM HOME Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 5 0-2%	0-10	G LS	VFL NS/NP					P5 .5
		10-43	SBX SCL	FL SS/S					
2		0-34	C LS	VFL NS/NP					P5 .5
		34-44	SBX SCL	FL SS/S					
3	SS 7-10%	0-20"	G LS	VFL NS/NP					P5.8

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CUN	25' (RFD)
Site LTAR	.5	.8

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): P5  
 Evaluated By: [Signature]  
 Others Present: