

**SOIL/SITE EVALUATION  
for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 7/9/08

Proposed Facility: 3 Bedroom HOUSE Design Flow (.1949): 365 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public  Individual  Well

Spring  Other

Evaluation Method:  Auger Boring  Pit

Cut

Type of Wastewater:  Sewage  Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro: Class	.1944 Restr: Horiz.		
1	LS 5-10%	0-6	G SL	VFL NS/NP					PS .35	
		6-27	SBK CL	FR S/SP						
		27-40	SBK EL	FR S/P						
		BT @ 40"								
2		0-8"	G SL	VFL NS/NP				PS .35		
		8-27"	SBK CL	FR S/P						
		27-36"	SBK C	FR S/P						
		BT @ 36"								

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	PUMP TO 25' x 20'	=
Site LTAR	.35	.35

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PS  
 Evaluated By: BT  
 Others Present:

\*NEED TRIPARTY AGREEMENT PRIOR TO CA