

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Wynn Court PROPERTY LOCATION: 1235
NEW REPAIR EXPANSION SUBDIVISION Pioneer Farms LOT # 16

Type of Structure: SFD 36x30 3BR MAX Site Improvements required prior to Construction Authorization Issuance: NOTE - DRIVEWAY must be along
Proposed Wastewater System Type: Ultra shallow placed
Projected Daily Flow: 360 GPD 25% Reduction system 15/16 Prospects Line And be 10' max
Number of bedrooms: 3 MAX Number of Occupants: 6 max
Basement Yes No Wide

Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well 100 feet Permit valid for: Five years
Permit conditions: MEET ON SITE for Final layout maintain All setbacks No expiration
MUST Bring In 8"x12" of Approved cover soil - NOTE FRENCH DRAIN

Authorized State Agent: Ja WARS Date: 08-21-08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Wynn Court PROPERTY LOCATION: 1235
SUBDIVISION Pioneer Farms LOT # 16

Facility Type: SFD-36x30-3BR MAX New Expansion Repair
Basement? Yes No Basement Fixtures? Yes No
Type of Wastewater System** ultra shallow 25% Reduction system (Initial) Wastewater Flow: MAX 360 GPD
(See note below, if applicable) 25% Reduction system (Repair)

Installation Requirements/Conditions
Septic Tank Size 1000 gallons Number of trenches 1
Pump Tank Size 1000 gallons Exact length of each trench 300 feet Trench Spacing: 9 Feet on Center
Trenches shall be installed on contour at a Soil Cover: 6 inches
Maximum Trench Depth of: 12 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
(Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
Aggregate Depth: _____ inches above pipe
Conditions: _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: [Signature] Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Ja WARS Date: 08-21-08
Construction Authorization Expiration Date: 08-21-2013

HTE# 08-500-20486R

Permit # 24973


Harnett County Department of Public Health Site Sketch

ISSUED TO: Wynn Const.

PROPERTY LOCATOR: 1235
SUBDIVISION: Pioneer Farm LOT # 16

Authorized State Agent: Ju W. [Signature]

Date: 8-21-08



Meet onsite for final layout
 Maintain all setbacks
 NOTE DRIVE must be along Lot 15/16 Property Line and to be a max of 10' wide
 Must bring in 8 to 12" of approved cover
 French Drain to be 48 to 60" Deep with gravel to within 6" of the top of the ground