

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Wynn Const. PROPERTY LOCATION: Adcock Rd
NEW REPAIR EXPANSION SUBDIVISION: Pioneer Farms LOT # 18

Type of Structure: SFD-45x37-3BR
Proposed Wastewater System Type: 25% Reduction System
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement Yes No

Site Improvements required prior to Construction Authorization Issuance:

Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well 190 feet Permit valid for: Five years
Permit conditions: STUB out Plumbing shall be at ground level or higher where shown. Meet on site for final layout. Maintain all set back Key cleaning to 10' from easement line No expiration

Authorized State Agent: Ju L... Date: 08-01-08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Wynn Const. PROPERTY LOCATION: Adcock Rd
Facility Type: SFD-45x37-3BR New Expansion Repair
Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable) 25% Reduction System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Number of trenches 1
Pump Tank Size _____ gallons Exact length of each trench 300 feet Trench Spacing: 9 Feet on Center
Trenches shall be installed on contour at a Soil Cover: 6 inches
Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
(Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
Conditions: _____ inches above pipe
_____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Ju L... Date: 08-01-08
Construction Authorization Expiration Date: 08-01-2013

HTE# 08-500-20487R

Permit # 21895

Harnett County Department of Public Health Site Sketch

ISSUED TO: Wm Const.


PROPERTY LOCATION: Adesch M

SUBDIVISION Pioneer Farm

LOT # 12

Authorized State Agent: J. L. L...

Date: 08-01-08



Meet onsite for
Final layout
maintain all set Backs
keep drainfield 10'
from septic easement
line
Stub out plumbing
shallow at
ground level or
higher where
shown
Install 300'
25% Reduction
System