

HTE# U8-500-20595R

Harnett County Department of Public Health

25509

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cumberland Homes PROPERTY LOCATION: 1111
 NEW REPAIR EXPANSION SUBDIVISION: Ashe Ford LOT # 62
 Type of Structure: SFD- 52x31 3BR max Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% Reduction System
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 max Number of Occupants: 6 max
 Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 100 feet Permit valid for: Five years
 No expiration

Permit conditions: Meet onsite for final layout maintain all set back
STUB out plumbing shall be at ground level or higher where shown
INSTALL French Drain AS SHOWN, French Drain to be at least 60" Deep with Gran.

Authorized State Agent: Jim Wright RI Date: 6-26-09 SEE ATTACHED SITE SKETCH to within 6" surface

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cumberland Homes PROPERTY LOCATION: 1111
 SUBDIVISION: Ashe Ford LOT # 62

Facility Type: SFD- 52x31 3BR max New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable) Dr.p (Repair)

Installation Requirements/Conditions
 Septic Tank Size 1000 gallons Number of trenches 1
 Pump Tank Size _____ gallons Exact length of each trench 200 feet Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
 Aggregate Depth: _____ inches above pipe
 _____ inches total

Conditions: Must be installed as shown, per consultants report

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Jim Wright Date: 062609
 Construction Authorization Expiration Date: 06262014

HTE# 08-500-20595R

Permit # 25509

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cumberland Homes

PROPERTY LOCATION: 1111

SUBDIVISION Ashe Ford


LOT # 62

Authorized State Agent: J. L. [Signature]

Date: 06-26-39

Meet onsite for Final
Layout

Dr. Repair



EXISTING
FRENCH
DRAIN

NOTE
FRENCH
DRAIN MUST
GO ALONG
BACK OF BEAM
FRENCH DRAIN TO
BE 60" DEEP WITH
GRAVEL WITHIN 6" OF
SURFACE

Install 200'
of 25% Reduction
System at 18" Deep
Maintain All set Back,

HAVISTOCK
CT