

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner: 08-500-20642

Applicant:

Address:

Date Evaluated:

Proposed Facility: JFD

Design Flow (.1949): 360

Property Size:

Location of Site: VLDN

Property Recorded:

Water Supply: Public Individual Well

Spring Other

Evaluation Method: Auger Boring Pit

Cut

Type of Wastewater: Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
3		012	GR SL	VFA SE					.5
		1042	GR SCL	FA SE					
5		010	GR SL	VFA SE					.5
		1042	SH SCL	FA SE					
		016	GR SL	VFA SE					.5
		1042	SH SCL	FA SE					
		018	GR SL	VFA SE					.5
		1842	SH SCL	FA SE					
		018	GR SL	VFA SE					.1
		1842	SH SCL	FA SE					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25	Panel Plat
Site LTAR	15	.5

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: GW
 Others Present: CGOATG


COMMENTS: _____


<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1	VFI-VERY FIRM	VS-VERY STICKY
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).






S38°22'18"E L=56.73'
38.87 R=625.00

OMAHA DRIVE
50' PUBLIC R/W

SITE PLAN APPROVAL

DISTRICT BARBOR USE SFD

#BEDROOMS 3

Date 7/30/08 
Zoning Administrator

THIS MAP WAS PREPARED FROM RECORDED DATA, AS NOTED, AND FROM OTHER SOURCES PROVIDED BY THE OWNER. THIS IS A PRELIMINARY SITE PLAN, INTENDED FOR PLANNING USE ONLY AND IN NO WAY REPRESENTS A SURVEY MADE BY THIS COMPANY. THIS MAP IS NOT INTENDED FOR RECORDATION, CONVEYANCES, OR SALES.

Charlie T. Carpenter, P.L.S.
Professional Land Surveyor
1940 Juniper Church Road
Four Oaks, NC 27524
(919) 963-2909
(919) 320-5281



PRELIMINARY SITE PLAN FOR:
WYNN CONSTRUCTION

PIN 9597-35-4085.000
PARCEL ID 039576 0088 60
LOT 60 TINGEN POINTE S/D
PB2007 PG711-718
7/26/08
1"=40'

533 OMAHA DRIVE
BROADWAY, NC 27505