

ADDRESS : RAY RD
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.
T/S: 08/07/2008 09:20 AM VBROWN ----

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
	12/01/08	CA	
B101 02	12/03/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670

AP-MR

COMMENTS AND NOTES

PREPARED 12/04/08, 14:00:45
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 21
DATE 12/05/08

ADDRESS : RAY RD
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.
T/S: 08/07/2008 09:20 AM VBROWN ----

SUBDIV: DANNIE W WEST
PHONE :
PHONE : (910) 497-1848

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08 12/01/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
B101 02	12/03/08 12/03/08	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670
B103 01	12/05/08	TI <i>AP JV</i>	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001713494 STORAGE AREA WALLS.

COMMENTS AND NOTES

PREPARED 12/12/08, 13:59:27
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 17
DATE 12/15/08

ADDRESS : RAY RD
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.
T/S: 08/07/2008 09:20 AM VBROWN ----

SUBDIV: DANNIE W WEST
PHONE :
PHONE : (910) 497-1848

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
	12/01/08	CA	
B101 02	12/03/08	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670
	12/03/08	AP	
B103 01	12/05/08	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001713494
	12/05/08	AP	STORAGE AREA WALLS.
A814 01	12/15/08	TI	ADDRESS CONFIRMATION VRU #: 001716745
B103 02	12/15/08	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001716752
	12/15/08	AP DI	

COMMENTS AND NOTES

PREPARED 1/12/09, 13:59:22
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 18
DATE 1/13/09

ADDRESS : 74 GREAT DANE LN
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.
T/S: 08/07/2008 09:20 AM VBROWN ----

SUBDIV: DANNIE W WEST
PHONE :
PHONE : (910) 497-1848

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
	12/01/08	CA	
B101 02	12/03/08	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670
	12/03/08	AP	
B103 01	12/05/08	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001713494
	12/05/08	AP	STORAGE AREA WALLS.
A814 01	12/15/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001716745
	1/05/09	AP	74 great dane ln check for # by drive & on home
B103 02	12/15/08	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001716752
	12/15/08	AP	
B105 01	1/13/09	TI	R*OPEN FLOOR VRU #: 001724962

1-13-09 ALJH

----- COMMENTS AND NOTES -----

PREPARED 3/10/09, 14:12:34
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 1
DATE 3/11/09

ADDRESS : 74 GREAT DANE LN
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)

SUBDIV: DANNIE W WEST
PHONE :
PHONE : (910) 497-1848

DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.
T/S: 08/07/2008 09:20 AM VBROWN ----

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
	12/01/08	CA	
B101 02	12/03/08	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670
	12/03/08	AP	
B103 01	12/05/08	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001713494
	12/05/08	AP	STORAGE AREA WALLS.
A814 01	12/15/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001716745
	1/05/09	AP	74 great dane ln check for # by drive & on home
B103 02	12/15/08	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001716752
	12/15/08	AP	
H824 01	1/12/09	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001725837
	1/12/09	AP	
B105 01	1/13/09	JH	R*OPEN FLOOR VRU #: 001724962
	1/13/09	AP	
B111 01	3/11/09	TI	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001742105
	3-11-09 APJH		WILL BE FOR AN ELEVATED SLAB IN THE BACK OF THE HOUSE..

----- COMMENTS AND NOTES -----

PREPARED 3/16/09, 13:59:48
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 2
DATE 3/17/09

ADDRESS : 74 GREAT DANE LN
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.
T/S: 08/07/2008 09:20 AM VBROWN

SUBDIV: DANNIE W WEST
PHONE :
PHONE : (910) 497-1848

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
	12/01/08	CA	
B101 02	12/03/08	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670
	12/03/08	AP	
B103 01	12/05/08	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001713494
	12/05/08	AP	STORAGE AREA WALLS.
A814 01	12/15/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001716745
	1/05/09	AP	74 great dane ln check for # by drive & on home
B103 02	12/15/08	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001716752
	12/15/08	AP	
H824 01	1/12/09	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001725837
	1/12/09	AP	
B105 01	1/13/09	JH	R*OPEN FLOOR VRU #: 001724962
	1/13/09	AP	
B111 01	3/11/09	JH	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001742105
	3/11/09	AP	WILL BE FOR AN ELEVATED SLAB IN THE BACK OF THE HOUSE..
R427 01	3/17/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001744044

3-17-09 DA JV

COMMENTS AND NOTES

    HTE		3/17/2009	1:09:06 PM				
Application number, type		08 50020680 CP,NEW RESIDENTIAL (SFD)					
Property address		74 GREAT DANE LN					
1)Bond motor on tub to faucet in master bathroom. 2)Flex duct 14' max for bath exhaust fans. 3)No bundling wires at switches no more than 3 wires together in staples. 4)Need smoke detector outside of bed #3. 5)Need receptacle at door of bed #3 & #4 inside room. 6)Need repair letter for hole drilled in truss @ dormers. 7)Nail all 2ply & 3ply roof truss per truss drawings. 8)100psi on water lines test with water. 9)Replace cut floor joist under tube in all bathrooms. 10)Water lines for outside faucet need to be tied in to test. 11)Need to strap drain lines under house every 4' per code.  							
OK	Exit	Cancel	Copy	Insert	Delete	Time stamp	User defaults

ADDRESS : 74 GREAT DANE LN
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.
T/S: 08/07/2008 09:20 AM VBROWN ----

SUBDIV: DANNIE W WEST
PHONE :
PHONE : (910) 497-1848

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
	12/01/08	CA	
B101 02	12/03/08	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670
	12/03/08	AP	
B103 01	12/05/08	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001713494
	12/05/08	AP	STORAGE AREA WALLS.
A814 01	12/15/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001716745
	1/05/09	AP	74 great dane ln check for # by drive & on home
B103 02	12/15/08	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001716752
	12/15/08	AP	
H824 01	1/12/09	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001725837
	1/12/09	AP	
B105 01	1/13/09	JH	R*OPEN FLOOR VRU #: 001724962
	1/13/09	AP	
B111 01	3/11/09	JH	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001742105
	3/11/09	AP	WILL BE FOR AN ELEVATED SLAB IN THE BACK OF THE HOUSE..
R427 01	3/17/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001744044
	3/17/09	DA	1) Bond motor on tub to faucet in master bathroom. 2) Flex duct 14' max for bath exhaust fans. 3) No bundling wires at switches no more than 3 wires together in staples. 4) Need smoke detector outside of bed #3. 5) Need receptacle at door of bed #3 & #4 inside room. 6) Need repair letter for hole drilled in truss @ dormers. 7) Nail all 2ply & 3ply roof truss per truss drawings. 8) 100psi on water lines test with water. 9) Replace cut floor joist under tubs in all bathrooms. 10) Water lines for outside faucet need to be tied in to test. 11) Need to strap drain lines under house every 4' per code.
R427 02	3/20/09 3-20-09	TI DAB	FOUR TRADE ROUGH IN >2500 VRU #: 001745314

ADDRESS : 74 GREAT DANE LN
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.
T/S: 08/07/2008 09:20 AM VBROWN ----

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
	12/01/08	CA	
B101 02	12/03/08	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670
	12/03/08	AP	
B103 01	12/05/08	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001713494
	12/05/08	AP	STORAGE AREA WALLS.
A814 01	12/15/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001716745
	1/05/09	AP	74 great dane ln check for # by drive & on home
B103 02	12/15/08	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001716752
	12/15/08	AP	
H824 01	1/12/09	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001725837
	1/12/09	AP	
B105 01	1/13/09	JH	R*OPEN FLOOR VRU #: 001724962
	1/13/09	AP	
B111 01	3/11/09	JH	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001742105
	3/11/09	AP	WILL BE FOR AN ELEVATED SLAB IN THE BACK OF THE HOUSE..
R427 01	3/17/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001744044
	3/17/09	DA	1)Bond motor on tub to faucet in master bathroom. 2)Flex duct 14' max for bath exhaust fans. 3)No bundling wires at switches no more than 3 wires together in staples. 4)Need smoke detector outside of bed #3. 5)Need receptacle at door of bed #3 & #4 inside room. 6)Need repair letter for hole drilled in truss @ dormers. 7)Nail all 2ply & 3ply roof truss per truss drawings. 8)100psi on water lines test with water. 9)Replace cut floor joist under tubs in all bathrooms. 10)Water lines for outside faucet need to be tied in to test. 11)Need to strap drain lines under house every 4' per code.
R427 02	3/20/09	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001745314
	3/20/09	DA	need letter on trusses drilled per previous violation. Will check at insulation inspection. All other violations

PREPARED - 4/07/09, 13:59:19
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 6
DATE 4/08/09

ADDRESS : 74 GREAT DANE LN
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)

SUBDIV: DANNIE W WEST
PHONE :
PHONE : (910) 497-1848

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

M305 01	4/08/09 <u>4-8-9</u>	TI <u>AP-MR</u>	corrected R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 001752385
---------	-------------------------	--------------------	--

COMMENTS AND NOTES

connection to Septic Tank

Has Not
had Red-
or issue.

ADDRESS : 74 GREAT DANE LN

SUBDIV: DANNIE W WEST

CONTRACTOR :

PHONE :

OWNER : FINK GEORGE R & AMANDA

PHONE : (910) 497-1848

PARCEL : 01-0504- - -0151- -01-

APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.

T/S: 08/07/2008 09:20 AM VBROWN ----

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
	12/01/08	CA	
B101 02	12/03/08	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670
	12/03/08	AP	
B103 01	12/05/08	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001713494
	12/05/08	AP	STORAGE AREA WALLS.
A814 01	12/15/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001716745
	1/05/09	AP	74 great dane ln check for # by drive & on home
B103 02	12/15/08	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001716752
	12/15/08	AP	
H824 01	1/12/09	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001725837
	1/12/09	AP	
B105 01	1/13/09	JH	R*OPEN FLOOR VRU #: 001724962
	1/13/09	AP	
B111 01	3/11/09	JH	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001742105
	3/11/09	AP	WILL BE FOR AN ELEVATED SLAB IN THE BACK OF THE HOUSE..
R427 01	3/17/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001744044
	3/17/09	DA	1)Bond motor on tub to faucet in master bathroom. 2)Flex duct 14' max for bath exhaust fans. 3)No bundling wires at switches no more than 3 wires together in staples. 4)Need smoke detector outside of bed #3. 5)Need receptacle at door of bed #3 & #4 inside room. 6)Need repair letter for hole drilled in truss @ dormers. 7)Nail all 2ply & 3ply roof truss per truss drawings. 8)100psi on water lines test with water. 9)Replace cut floor joist under tubs in all bathrooms. 10)Water lines for outside faucet need to be tied in to test. 11)Need to strap drain lines under house every 4' per code.
R427 02	3/20/09	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001745314
	3/20/09	DA	need letter on trusses drilled per previous violation. Will check at insulation inspection. All other violations

CONTINUED ONTO NEXT PAGE

PREPARED 4/29/09, 13:58:55
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 10
DATE 4/30/09

ADDRESS : 74 GREAT DANE LN

SUBDIV: DANNIE W WEST

CONTRACTOR :

PHONE :

OWNER . . : FINK GEORGE R & AMANDA

PHONE : (910) 497-1848

PARCEL . . : 01-0504- - -0151- -01-

APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
			corrected
M305 01	4/08/09	MR	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 001752385
	4/08/09	AP	connection to septic tank
I129 01	4/30/09	TI	R*INSULATION INSPECTION VRU #: 001761741
	<u>4-30-09</u>	<u>APBS</u>	
R427 03	4/30/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001761733
	<u>4-30-09</u>	<u>P</u>	

COMMENTS AND NOTES

STOCK Components

1175-A South Park Dr, Kennesawville NC 27284


Job Name
SBS #4023/ ROBERT FINK - FINK RESIDENCE

Truss
C03
2-PLY

REPAIR DETAIL



Carlin - 5/10/18



Standard Notes: (Applicable if referenced above)

1.

7/16" OSB each face. 10d Box or Common nails staggered 2.5" o/c one face through all members, clinched on back ply.

2.

7/16" OSB each face. 10d Box or Common nails 2" o/c through all members.

3.


3/4" (Nom) OSB each face. 16d Box nails (135 x 3.5") one face staggered 2.5" o/c through all members, clinched on back ply.

4.

2 x 4 scab(s) as noted, centered on break if possible. Nail with at least the detailed number of 10d nails staggered and equally spaced each side of break, each scab.

Notes 1, 2, 3 - Trace members on OSB if necessary to assure proper nailing throughout all webs and chords.

THIS IS A SPECIFIC REPAIR ONLY FOR THE SITUATION(S) INDICATED ON THIS DRAWING. THIS DOES NOT IMPLY THAT NO OTHER DAMAGE EXISTS. THE ENTIRE TRUSS SHALL BE INSPECTED TO VERIFY THAT NO OTHER REPAIRS ARE REQUIRED. ALL MEMBERS MUST BE RETURNED TO THEIR PROPER POSITIONS BEFORE APPLYING REPAIR. AND HELD IN PLACE DURING APPLICATION OF REPAIR.





Re: 910-497-1848

Robert Fink 919-427-5538
ATT Larry

LIVE LOAD = 40 PSF
ULTIMATE LIVELOAD = $1.7 \times 40 =$
68 PSF

153 #/sf > 68 PSF OK



SUMMARY: THE ATTACHED TABLE INDICATES THE CAPACITY OF THE STEEL IS 153 #/SF WHICH IS GREATER THAN THE 68 PSF ACTUAL LIVELOAD.

ADDRESS : 74 GREAT DANE LN
CONTRACTOR :
OWNER : FINK GEORGE R & AMANDA
PARCEL : 01-0504- - -0151- -01-
APPL NUMBER: 08-50020680 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 74 GRATE DANE LANE 1 MI OFF OF RAY RD.
HWY 210 TOWARD SPRING LAKE, RIGHT AT
LIGHT ONTO RAY RD ABOUT 2 OR 3 MI LEFT
ON KILLDEER, KILLDEER TURNS INTO JOHN
RAYAN LN, BEAR RIGHT ONTO GREAT DANE
THEN TAKE IMMEDIATE RIGHT, SITE IS
BEHIND TAN MOBILE HM.
T/S: 08/07/2008 09:20 AM VBROWN ----

SUBDIV: DANNIE W WEST
PHONE :
PHONE : (910) 497-1848

STRUCTURE: 000 000 102X60 3BDR 3.5BATH SFD

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/01/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711035
	12/01/08	CA	
B101 02	12/03/08	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001711670
	12/03/08	AP	
B103 01	12/05/08	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001713494
	12/05/08	AP	STORAGE AREA WALLS.
A814 01	12/15/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001716745
	1/05/09	AP	✓ 74 great dane ln check for # by drive & on home
B103 02	12/15/08	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001716752
	12/15/08	AP	
H824 01	1/12/09	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001725837
	1/12/09	AP	
B105 01	1/13/09	JH	R*OPEN FLOOR VRU #: 001724962
	1/13/09	AP	
B111 01	3/11/09	JH	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001742105
	3/11/09	AP	WILL BE FOR AN ELEVATED SLAB IN THE BACK OF THE HOUSE..
R427 01	3/17/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001744044
	3/17/09	DA	1)Bond motor on tub to faucet in master bathroom. 2)Flex duct 14' max for bath exhaust fans. 3)No bundling wires at switches no more than 3 wires together in staples. 4)Need smoke detector outside of bed #3. 5)Need receptacle at door of bed #3 & #4 inside room. 6)Need repair letter for hole drilled in truss @ dormers. 7)Nail all 2ply & 3ply roof truss per truss drawings. 8)100psi on water lines test with water. 9)Replace cut floor joist under tubs in all bathrooms. 10)Water lines for outside faucet need to be tied in to test. 11)Need to strap drain lines under house every 4' per code.
R427 02	3/20/09	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001745314
	3/20/09	DA	need letter on trusses drilled per previous violation. Will check at insulation inspection. All other violations

CONTINUED ONTO NEXT PAGE

INSPECTION TICKET
INSPECTOR: IVR

PREPARED 9/09/09, 14:03:34
Barnett County

SUBDIV: DANNIE W WEST
PHONE :
PHONE : (910) 497-1848

ADDRESS : 74 GREAT DANE LN
CONTRACTOR : FINK GEORGE R & AMANDA
OWNER : 01-0504- -0151- -01-
PARCEL : 08-50020680 CP NEW RESIDENTIAL (SFD)
APPL NUMBER: 08-50020680

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	TIME	VRU #
M305 01	4/08/09	MR	corrected	TIME: 17:00	VRU #: 001752385
	4/08/09	AP	R*PLUMB SEWER CONNECTION		
I129 01	4/30/09	BS	connection to septic tank		
	4/30/09	AP	R*INSULATION INSPECTION		VRU #: 001761741
R427 03	4/30/09	BS	FOUR TRADE ROUGH IN >2500		VRU #: 001761733
	4/30/09	AP	FOUR TRADE FINAL >2500	TIME: 17:00	VRU #: 001818905
R431 01	9/09/09	VC	T/S: 09/08/2009 03:34	PM VBROWN	
	9/08/09	CA	T/S: 09/08/2009 04:09	PM VBROWN	
			SCHED. WRONG DATE.		
			FOUR TRADE FINAL >2500	TIME: 17:00	VRU #: 001818921
R431 02	9/10/09	TI	T/S: 09/08/2009 04:10	PM VBROWN	
	9-10-09	APJH			
			COMMENTS AND NOTES		

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFO
Owner: George & Amanda Fink
911 Address: 74 Great Dane Ln

State: N.C. Zip Code: _____
Date: 9-10-09
James Z. Hall
Building Official

PERMIT NUMBERS

Building Permit No.: _____
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: _____
Mech. Permit No.: _____
MFG. Home: _____

08500200580