
ADDRESS : 116 GOLD DUST LN SUBDIV:
 CONTRACTOR : STATE MOBILE HOME MOVERS PHONE : (910) 894-8038
 OWNER : CURR-WELL DEVELOPMENTS PHONE :
 PARCEL : 07-1610- - -0051- -01-
 APPL NUMBER: 09-50022191 CP MOBILE HOME PARK
 LAND NOTES : LXMN 3/15/00 TRADERS BLUFF MHP LOT 6

STRUCTURE: 000 000 14X70 SWMH IN PARK 2BED 1983

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 2.00 MOBILE HOME YEAR : 1983.00
 PROPOSED USE : SWMH SEPTIC - EXISTING? : EXISTING

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	7/21/09 <u>7-21</u>	TI <u>DA</u>	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001796994 T/S: 07/20/2009 08:57 AM NTART

COMMENTS AND NOTES

**Violation Notice
Do Not Remove**

**Harnett County Inspection Department
102 East Front St P.O. Box 65
Lillington, NC 27546
Phone (910) 893-7525 Fax (910) 893-2793**

09-50022191

July 21, 2009

1. Water leaked down in stand pipe.
2. Rear steps require pickets spaced no greater than 4 inches apart.
3. Grass below home shall be no taller than 2 inches.

Ken Slattum

ADDRESS : 116 GOLD DUST LN SUBDIV:
CONTRACTOR : STATE MOBILE HOME MOVERS PHONE : (910) 894-8038
OWNER : CURR-WELL DEVELOPMENTS PHONE :
PARCEL : 07-1610- - -0051- -01-
APPL NUMBER: 09-50022191 CP MOBILE HOME PARK
LAND NOTES : LXMN 3/15/00 TRADERS BLUFF MHP LOT 6

STRUCTURE: 000 000 14X70 SWMH IN PARK 2BED 1983

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 2.00 MOBILE HOME YEAR : 1983.00
PROPOSED USE : SWMH SEPTIC - EXISTING? : EXISTING

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	7/21/09 7/21/09	KS DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001796994 T/S: 07/20/2009 08:57 AM NTART ----- Water leaked down in standpipe. Rear steps require pickets spaced no greater than 4 inches. Grass below trailer has to be no longer than 2 inches. T/S: 07/21/2009 02:37 PM KSLATTUM ----- T/S: 07/21/2009 02:39 PM KSLATTUM -----
T501 02	8/05/09 <u>8.5.09</u>	TI <u>APBS</u>	R*MOBILE HOME FOUND./ M. WALL VRU #: 001804814

----- COMMENTS AND NOTES -----

ADDRESS : 116 GOLD DUST LN
 CONTRACTOR : STATE MOBILE HOME MOVERS
 OWNER : CURR-WELL DEVELOPMENTS
 PARCEL : 07-1610- - -0051- -01-
 APPL NUMBER: 09-50022191 CP MOBILE HOME PARK
 LAND NOTES : LXMN 3/15/00 TRADERS BLUFF MHP LOT 6

SUBDIV:
 PHONE : (910) 894-8038
 PHONE :

STRUCTURE: 000 000 14X70 SWMH IN PARK 2BED 1983

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 2.00
 PROPOSED USE : SWMH

MOBILE HOME YEAR : 1983.00
 SEPTIC - EXISTING? : EXISTING

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	7/21/09 7/21/09	KS DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001796994 T/S: 07/20/2009 08:57 AM NTART ----- Water leaked down in standpipe. Rear steps require pickets spaced no greater than 4 inches. Grass below trailer has to be no longer than 2 inches. T/S: 07/21/2009 02:37 PM KSLATTUM ----- T/S: 07/21/2009 02:39 PM KSLATTUM -----
T501 02	8/05/09 8/05/09	BS AP	R*MOBILE HOME FOUND./ M. WALL VRU #: 001804814 T/S: August 05, 2009 12:24 PM BSUTTON -----
A814 01	8/20/09	TI	ADDRESS CONFIRMATION VRU #: 001811363
Z818 01	8/20/09 <u>8/20/09</u>	TI <u>AP/AD</u>	PZ*ZONING INSPECTION VRU #: 001811355

COMMENTS AND NOTES

ADDRESS : 116 GOLD DUST LN SUBDIV:
CONTRACTOR : STATE MOBILE HOME MOVERS PHONE : (910) 894-8038
OWNER : CURR-WELL DEVELOPMENTS PHONE :
PARCEL : 07-1610- - -0051- -01-
APPL NUMBER: 09-50022191 CP MOBILE HOME PARK
LAND NOTES : LXMN 3/15/00 TRADERS BLUFF MHP LOT 6

STRUCTURE: 000 000 14X70 SWMH IN PARK 2BED 1983

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 2.00 MOBILE HOME YEAR : 1983.00
PROPOSED USE : SWMH SEPTIC - EXISTING? : EXISTING

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	7/21/09 7/21/09	KS DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001796994 T/S: 07/20/2009 08:57 AM NTART ----- Water leaked down in standpipe. Rear steps require pickets spaced no greater than 4 inches. Grass below trailer has to be no longer than 2 inches. T/S: 07/21/2009 02:37 PM KSLATTUM ----- T/S: 07/21/2009 02:39 PM KSLATTUM -----
T501 02	8/05/09 8/05/09	BS AP	R*MOBILE HOME FOUND./ M. WALL VRU #: 001804814 T/S: August 05, 2009 12:24 PM BSUTTON -----
A814 01	8/20/09 8/25/09	FB AP	✓ADDRESS CONFIRMATION VRU #: 001811363 T/S: 08/25/2009 09:13 AM FBURGESS -----
Z818 01	8/20/09 8/20/09	AD AP	✓116 GOLD DUST LN COATS, NC 27521 LOT 6 PZ*ZONING INSPECTION VRU #: 001811355 T/S: 08/20/2009 10:24 AM NTART -----
T503 01	8/26/09 <i>8-26-09</i>	TI <i>ARBS</i>	R*MOBILE HOME INSPECTION VRU #: 001813112

----- COMMENTS AND NOTES -----

Final

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Conditional Use Permit No.: NA

Type of Construction: Manufactured 1x

Building Permit No.: MH 09-50022191

Owner of Building: Curr-Well Dev

Electrical Permit No.: _____

Building Address: 116 Gold Dust Lane

Insulation Permit No.: _____

Zoning District: NA

Plumbing Permit No.: _____

Zoning Permit No.: NA

Mech. Permit No.: _____

Date: 08/26/09

Envir. C.O. No.: _____

Brad Sutton

NA

Building Official

Zoning Official