

Property ID:  
 Lot #:  
 File #:  
 Code:

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 9/30/02

Proposed Facility: 3 BEDROOM HOME

Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public [ ] Individual [ ] Well [ ] Spring [ ] Other

Evaluation Method:  Auger Boring [ ] Pit [ ] Cut

Type of Wastewater:  Sewage [ ] Industrial Process [ ] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 7-10%	0-12	G SL/LS	VF2 SS/MP					US PS R12 .3
		12-38"	SBK SL	F2 SS/SR	10YR 7/1 @ 22"				
2		0-11"	G SL	VF2 SS/MP					PS .45
		11-35"	SBK SL	F2 SS/SR	2.5Y 7/2 @ 32"				
3		0-10"	G LS/SL	VF2 SS/MP					PS .45
		10-33"	SBK SL	F2 SS/SR	2.5Y 7/2 @ 31"				

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	CON	CON
Site LTAR	.45	.45

3x90' @ 18"-12"

Other Factors (.1946): \_\_\_\_\_

Site Classification (.1948): PS

Evaluated By: OI

Others Present:


COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE


Show profile locations and other site features (dimensions, reference or benchmark, and North).



CREEKSVILLE CHURCH ROAD

AREA  
DEDIC

60' R/W



PER SECTION 5.11 OF  
HARRETT COUNTY SUBDIVISION  
REGULATIONS

CINCINNATI CAPITAL PARTNERS XX, LLC.  
2100-111  
0513-35-4136  
ZONED - RA-20M

#BEDROOMS  
0.17.06  
DISTRICT  
SITE PLAN APPROVAL  
USE  
STP

ZONING ADMINISTRATOR

10' DRAINAGE &  
UTILITY EASEMENT  
TYPICAL EACH LOT

BEING ALL OF LOTS 22 AND 23  
44,000.00 sq. ft.  
1.010 acres