

Property ID:  
 Lot #:  
 File #:  
 Code:

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 9/30/08

Proposed Facility: 3 Bedroom Home Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public [ ] Individual [ ] Well [ ] Spring [ ] Other  
 Evaluation Method:  Auger Boring [ ] Pit [ ] Cut  
 Type of Wastewater:  Sewage [ ] Industrial Process [ ] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 7-10%	0-11	C LS	VFR NS/HP					PS .34
		11-27	SBK SCL	FR SS/SP					
		27"	M SCL	F1	10x2 7/16 @ 27"				
2		0-12	G LS	VFR NS/HP					PS .4
		12-31"	SBK SCL	FR SS/SP	10x2 7/16 @ 31"				
3		0-10"	C LS	VFR NS/HP					PS .45
		10-35"	SBK SCL	FR SS/SP	2.51 7/12 @ 32"				

Description	Initial System	Repair System
Available Space (.1945)	CON	25% RED PUMP
System Type(s)	✓	✓
Site LTAR	.4	.4

4 x 75 @ 18"-12"

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PS  
 Evaluated By: [Signature]  
 Others Present:

COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			


STRUCTURE

- SG-SINGLE GRAIN
- M-MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE


Show profile locations and other site features (dimensions, reference or benchmark, and North).



CREEKSVILLE CHURCH ROAD

AREA  
DEDIC

60' R/W



PER SECTION 5.11 OF  
HARRETT COUNTY SUBDIVISION  
REGULATIONS

CINCINNATI CAPITAL PARTNERS XX, LLC.

2100-111  
0513-35-4136  
ZONED - RA-20M

SITE PLAN APPROVAL  
DISTRICT 147011 USE SF1

#BEDROOMS  
3

ZONING ADMINISTRATOR

10' DRAINAGE &  
UTILITY EASEMENT  
TYPICAL EACH LOT

BEING ALL OF LOTS 22 AND 23  
44,000.00 sq. ft.  
1.010 acres

42,164  
0.96