
ADDRESS . : 120 JAYLIN BLVD
 CONTRACTOR : FAMILY HOME CONSTRUCTION
 OWNER . . : JS PROPERTIES #6
 PARCEL . . : 01-0513- - -0217- -06-
 APPL NUMBER: 08-50020921 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 6

STRUCTURE: 000 000 80X53 3 BR NO DECKS/GARAGES/PORCHES/CRWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10 <u>4/30/10</u>	TI <u>AP DT</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918770

----- COMMENTS AND NOTES -----

ADDRESS . : 120 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : FAMILY HOME CONSTRUCTION PHONE : (910) 321-1002
 OWNER . . : JS PROPERTIES #6 PHONE : (910) 551-4736
 PARCEL . . : 01-0513- - -0217- -06-
 APPL NUMBER: 08-50020921 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 6

STRUCTURE: 000 000 80X53 3 BR NO DECKS/GARAGES/PORCHES/CRWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918770
	4/30/10	AP	
A814 01	5/17/10	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001927318 T/S: 05/14/2010 01:18 PM VBROWN -----
B103 01	5/17/10	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001927300 T/S: 05/14/2010 01:18 PM VBROWN -----

5-17 AP

COMMENTS AND NOTES

ADDRESS . . : 120 JAYLIN BLVD
 CONTRACTOR : FAMILY HOME CONSTRUCTION
 OWNER . . . : JS PROPERTIES #6
 PARCEL . . . : 01-0513- - -0217- -06-
 APPL NUMBER: 08-50020921 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 6

STRUCTURE: 000 000 80X53 3 BR NO DECKS/GARAGES/PORCHES/CRWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918770
	4/30/10	AP	
A814 01	5/17/10	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001927318
	5/17/10	AP	T/S: 05/14/2010 01:18 PM VBROWN ----- T/S: 05/17/2010 01:05 PM FBURGESS ----- 120 JAYLIN BLVD SPRING LAKE, NC 28390 LOT 6
B103 01	5/17/10	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001927300
	5/17/10	AP	T/S: 05/14/2010 01:18 PM VBROWN -----
B105 01	5/20/10	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 001929298
			T/S: 05/19/2010 09:11 AM RDCONTE -----

5-20-10 APJV

----- COMMENTS AND NOTES -----

ADDRESS . . : 120 JAYLIN BLVD
 CONTRACTOR : FAMILY HOME CONSTRUCTION
 OWNER . . . : JS PROPERTIES #6
 PARCEL . . . : 01-0513- - -0217- -06-
 APPL NUMBER: 08-50020921 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 6

SUBDIV: JAYLIN OAKS
 PHONE : (910) 321-1002
 PHONE : (910) 551-4736

STRUCTURE: 000 000 80X53 3 BR NO DECKS/GARAGES/PORCHES/CRWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918770
	4/30/10	AP	
A814 01	5/17/10	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001927318
	5/17/10	AP	T/S: 05/14/2010 01:18 PM VBROWN ----- T/S: 05/17/2010 01:05 PM FBURGESS ----- 120 JAYLIN BLVD SPRING LAKE, NC 28390 LOT 6
B103 01	5/17/10	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001927300
	5/17/10	AP	T/S: 05/14/2010 01:18 PM VBROWN -----
B105 01	5/20/10	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001929298
	5/20/10	AP	T/S: 05/19/2010 09:11 AM RDCONTE -----
R427 01	7/06/10 <i>7-6-10</i>	TI <i>DA JH</i>	FOUR TRADE ROUGH IN >2500 VRU #: 001949700

COMMENTS AND NOTES

ADDRESS : 120 JAYLIN BLVD
 CONTRACTOR : FAMILY HOME CONSTRUCTION
 OWNER : JS PROPERTIES #6
 PARCEL : 01-0513- - -0217- -06-
 APPL NUMBER: 08-50020921 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 6

SUBDIV: JAYLIN OAKS
 PHONE : (910) 321-1002
 PHONE : (910) 551-4736

STRUCTURE: 000 000 80X53 3 BR NO DECKS/GARAGES/PORCHES/CRWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918770
	4/30/10	AP	
A814 01	5/17/10	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001927318
	5/17/10	AP	T/S: 05/14/2010 01:18 PM VBROWN T/S: 05/17/2010 01:05 PM FBURGESS 120 JAYLIN BLVD SPRING LAKE, NC 28390 LOT 6
B103 01	5/17/10	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001927300
	5/17/10	AP	T/S: 05/14/2010 01:18 PM VBROWN
B105 01	5/20/10	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001929298
	5/20/10	AP	T/S: 05/19/2010 09:11 AM RDCONTE
R427 01	7/06/10	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001949700
	7/06/10	DA	1) Fire caulk dryer duct @ bottom plate. 2) Strap top plate in kitchen nook with 24" strap. 3) All A truss need more straps. 4) Fire caulk hole in top plate to left of bed 2 door. 5) AGDR truss missing strap @ joint 17. 6) Door in garage not framed out completely.
I129 01	7/08/10 <u>7-8-10</u>	TI <u>APJV</u>	R*INSULATION INSPECTION VRU #: 001950625
R427 02	7/08/10 <u>7-8-10</u>	TI <u>APJV</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001950617 ready for re-inspect

COMMENTS AND NOTES

ADDRESS : 120 JAYLIN BLVD
 CONTRACTOR : FAMILY HOME CONSTRUCTION
 OWNER : JS PROPERTIES #6
 PARCEL : 01-0513- - -0217- -06-
 APPL NUMBER: 08-50020921 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 6

SUBDIV: JAYLIN OAKS
 PHONE : (910) 321-1002
 PHONE : (910) 551-4736

STRUCTURE: 000 000 80X53 3 BR NO DECKS/GARAGES/PORCHES/CRWL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918770
	4/30/10	AP	
A814 01	5/17/10	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001927318
	5/17/10	AP	T/S: 05/14/2010 01:18 PM VBROWN T/S: 05/17/2010 01:05 PM FBURGESS
B103 01	5/17/10	KS	✓ 120 JAYLIN BLVD SPRING LAKE, NC 28390 LOT 6
	5/17/10	AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001927300
B105 01	5/20/10	JH	T/S: 05/14/2010 01:18 PM VBROWN
	5/20/10	AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001929298 T/S: 05/19/2010 09:11 AM RDCONTE
R427 01	7/06/10	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001949700
	7/06/10	DA	1)Fire caulk dryer duct @ bottom plate. 2)Strap top plate in kitchen nook with 24" strap. 3)All A truss need more straps. 4)Fire caulk hole in top plate to left of bed 2 door. 5)AGDR truss missing strap @ joint 17. 6)Door in garage not framed out completly.
I129 01	7/08/10	JH	R*INSULATION INSPECTION VRU #: 001950625
	7/08/10	AP	
R427 02	7/08/10	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001950617
	7/08/10	AP	ready for re-inspect
H824 01	7/15/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001955715
	7/15/10	AP	T/S: 07/16/2010 10:01 AM SZIMMER T/S: 07/16/2010 10:01 AM SZIMMER
R431 01	8/11/10	TI	FOUR TRADE FINAL >2500 VRU #: 001967546
	8-11-10	Op Jd	ready for a.m. if possible

COMMENTS AND NOTES

ADDRESS : 120 JAYLIN BLVD SUBDIV: JAYLIN OAKS
CONTRACTOR : FAMILY HOME CONSTRUCTION PHONE : (910) 321-1002
OWNER : JS PROPERTIES #6 PHONE : (910) 551-4736
PARCEL : 01-0513- - -0217- -06-
APPL NUMBER: 08-50020921 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
LESS AND TURN ON CREEKSVILLE CHURCH RD
TIL YOU COME TO SUBD.
T/S: 09/15/2008 12:03 PM DJOHNSON --
JAYLIN OAKS LOT 6

STRUCTURE: 000 000 80X53 3 BR NO DECKS/GARAGES/PORCHES/CRWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/30/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918770
	4/30/10	AP	
A814 01	5/17/10	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001927318
	5/17/10	AP	T/S: 05/14/2010 01:18 PM VBROWN ----- T/S: 05/17/2010 01:05 PM FBURGESS ----- ✓120 JAYLIN BLVD SPRING LAKE, NC 28390 LOT 6
B103 01	5/17/10	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001927300
	5/17/10	AP	T/S: 05/14/2010 01:18 PM VBROWN -----
B105 01	5/20/10	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001929298
	5/20/10	AP	T/S: 05/19/2010 09:11 AM RDCONTE -----
R427 01	7/06/10	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001949700
	7/06/10	DA	1)Fire caulk dryer duct @ bottom plate. 2)Strap top plate in kitchen nook with 24" strap. 3)All A truss need more straps. 4)Fire caulk hole in top plate to left of bed 2 door. 5)AGDR truss missing strap @ joint 17. 6)Door in garage not framed out completly.
I129 01	7/08/10	JH	R*INSULATION INSPECTION VRU #: 001950625
	7/08/10	AP	-----
R427 02	7/08/10	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001950617
	7/08/10	AP	ready for re-inspect -----
H824 01	7/15/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001955715
	7/15/10	AP	T/S: 07/16/2010 10:01 AM SZIMMER ----- T/S: 07/16/2010 10:01 AM SZIMMER -----
R431 01	8/11/10	JH	FOUR TRADE FINAL >2500 VRU #: 001967546
	8/11/10	DP	ready for a.m. if possible Ⓢ Protection for water heater. Ⓢ Plat form in attic needs to be 24" walkway & 30" clear @ AHU. Ⓢ Missing ground bar for cable @ meter. Ⓢ Need to strap ground wire & ground rods need to be @ grade. Ⓢ Dryer vent can not be closer than 12" from grade unless you meet the exception. Ⓢ Foundation drain pipe not installed. Ⓢ Crawl access door need to paint untreated wood.

PREPARED 8/11/10, 14:44:38
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 2
DATE 8/12/10

ADDRESS . : 120 JAYLIN BLVD
CONTRACTOR : FAMILY HOME CONSTRUCTION
OWNER . . : JS PROPERTIES #6
PARCEL . . : 01-0513- - -0217- -06-
APPL NUMBER: 08-50020921 CP NEW RESIDENTIAL (SFD)

SUBDIV: JAYLIN OAKS
PHONE : (910) 321-1002
PHONE : (910) 551-4736

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

R431 02 8/12/10 TI FOUR TRADE FINAL >2500 VRU #: 001968692
8-12-10 APJH all items complete ready for a.m. re-inspect if possible

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFO

Permit Numbers

Name: Family Home Construction

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Address: 120 Jaylin Blvd

Date: 8-12-10

Building Official: Juan 7 Hall

160000589