
ADDRESS . . : 101 JAYLIN BLVD
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER . . . : JS PROPERTIES #8
 PARCEL . . . : 01-0513- - -0217- -08-
 APPL NUMBER: 08-50020923 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 8
 T/S: 02/19/2010 02:14 PM RDCONTE ---
 *****SOUTH RIVER*****

STRUCTURE: 000 000 84X55 3 BR NO DECKS/GARAGES/PORCHES
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10 3-8-10	TI <i>APJH</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001890961 <i>T-pole passed</i>

COMMENTS AND NOTES

ADDRESS . . : 101 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . : JS PROPERTIES #8 PHONE : (910) 551-4736
 PARCEL . . : 01-0513- - -0217- -08-
 APPL NUMBER: 08-50020923 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 8
 T/S: 02/19/2010 02:14 PM RDCONTE ---
 *****SOUTH RIVER*****

STRUCTURE: 000 000 84X55 3 BR NO DECKS/GARAGES/PORCHES
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001890961
	3/08/10	AP	t-pole passed
A814 01	3/12/10	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001893981 T/S: 03/11/2010 10:30 AM VBROWN
B103 01	3/12/10 <u>3-12-10</u>	TI <u>APTID</u>	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001893973 T/S: 03/11/2010 10:29 AM VBROWN

----- COMMENTS AND NOTES -----

ADDRESS : 101 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : JS PROPERTIES #8 PHONE : (910) 551-4736
 PARCEL : 01-0513- - -0217- -08-
 APPL NUMBER: 08-50020923 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 8
 T/S: 02/19/2010 02:14 PM RDCONTE ---
 *****SOUTH RIVER*****

STRUCTURE: 000 000 84X55 3 BR NO DECKS/GARAGES/PORCHES
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001890961
	3/08/10	AP	t-pole passed
A814 01	3/12/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001893981
	3/12/10	AP	T/S: 03/11/2010 10:30 AM VBROWN 101 jaylin blvd lot 8 spring lake 28390
			T/S: 03/12/2010 10:27 AM TWARD
B103 01	3/12/10	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001893973
	3/12/10	AP	T/S: 03/11/2010 10:29 AM VBROWN
B105 01	3/17/10	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 001895234
	<u>3-17-10</u>	<u>AP JV</u>	T/S: 03/15/2010 03:48 PM VBROWN

----- COMMENTS AND NOTES -----

ADDRESS : 101 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : JS PROPERTIES #8 PHONE : (910) 551-4736
 PARCEL : 01-0513- - -0217- -08-
 APPL NUMBER: 08-50020923 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 8
 T/S: 02/19/2010 02:14 PM RDCONTE ---
 ****SOUTH RIVER****

STRUCTURE: 000 000 84X55 3 BR NO DECKS/GARAGES/PORCHES

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001890961
	3/08/10	AP	t-pole passed
A814 01	3/12/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001893981
	3/12/10	AP	T/S: 03/11/2010 10:30 AM VBROWN 101 jaylin blvd lot 8 spring lake 28390
			T/S: 03/12/2010 10:27 AM TWARD
B103 01	3/12/10	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001893973
	3/12/10	AP	T/S: 03/11/2010 10:29 AM VBROWN
B105 01	3/17/10	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001895234
	3/17/10	AP	T/S: 03/15/2010 03:48 PM VBROWN
R425 01	4/09/10 <i>4-9-10</i>	TI <i>DAJH</i>	FOUR TRADE ROUGH IN VRU #: 001907208

COMMENTS AND NOTES

ADDRESS : 101 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : JS PROPERTIES #8 PHONE : (910) 551-4736
 PARCEL : 01-0513- - -0217- -08-
 APPL NUMBER: 08-50020923 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 8
 T/S: 02/19/2010 02:14 PM RDCONTE ---
 ****SOUTH RIVER****


STRUCTURE: 000 000 84X55 3 BR NO DECKS/GARAGES/PORCHES

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001890961
	3/08/10	AP	t-pole passed
A814 01	3/12/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001893981
	3/12/10	AP	T/S: 03/11/2010 10:30 AM VBROWN 101 jaylin blvd lot 8 spring lake 28390 T/S: 03/12/2010 10:27 AM TWARD
B103 01	3/12/10	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001893973
	3/12/10	AP	T/S: 03/11/2010 10:29 AM VBROWN
B105 01	3/17/10	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001895234
	3/17/10	AP	T/S: 03/15/2010 03:48 PM VBROWN
R425 01	4/09/10	JH	FOUR TRADE ROUGH IN VRU #: 001907208
	4/09/10	DA	1 Nail all lvls per truss drawings. 2 Nail all 2 ply truss per truss drawings. 3 Missing A06 2 ply truss. 4 Seal under tubs & showers. 5 Missing bracing on A04 & A05 per drawings.
I129 01	4/14/10	TI	R*INSULATION INSPECTION VRU #: 001909621
	4-14-10	APJB	
R325 01	4/14/10	TI	THREE TRADE ROUGH IN VRU #: 001909613
	4-14-10	APJB	

COMMENTS AND NOTES



ECS Carolinas, LLP

9001 Glenwood Avenue
RALEIGH, NC 27617-7505
(800) 327-5832
(919) 861-9910 (voice)
(919) 861-9911 (fax)

FIELD REPORT

Project LOT# 8 Jaylin oaks

Project No. _____

Location _____

Day/Date 3/24/10

Client Builders First Source

Temp./Weather _____ / _____

Permits Clo Chuck

Arrive _____ : _____ : _____
 A P | A P | A P

Task Wyan Const. Co.

Depart _____ : _____ : _____
 A P | A P | A P

No. of Trips _____ Total Mileage _____

On-Site Time _____ Travel Time _____


Chargeable Equipment Used _____

Lab/Office Time _____ Total Time _____

Reinspection Time _____

OFFICE USE ONLY	
Reg. Time _____	Overtime _____

AS REQUESTED, ECS, LTD Eng. REVIEWED THE LOADS
 ON ONE-PLY GIRDER ROOF TRUSS THAT WAS PLACED
 AS SINGLE NOT DOUBLE AS SHOWN ON LAY-OUT.
 AT THE ABOVE REFERENCED LOT
 BASED ON OUR EVALUATION, THE SINGLE A06 TRUSS
 IS SUFFICIENT TO CARRY THE LOADS.
 NO REPAIRS ARE NEEDED



This report is preliminary until reviewed by the engineering staff.

Field data, locations, elevations, & depths are estimates.

Copy Received By: _____
Site Representative _____

Prepared By _____

Title/Company _____

Printed Name _____

ADDRESS : 101 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : JS PROPERTIES #8 PHONE : (910) 551-4736
 PARCEL : 01-0513- - -0217- -08-
 APPL NUMBER: 08-50020923 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 8
 T/S: 02/19/2010 02:14 PM RDCONTE ---
 *****SOUTH RIVER*****

STRUCTURE: 000 000 84X55 3 BR NO DECKS/GARAGES/PORCHES

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001890961
	3/08/10	AP	t-pole passed
A814 01	3/12/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001893981
	3/12/10	AP	T/S: 03/11/2010 10:30 AM VLBROWN ✓ 101 jaylin blvd lot 8 spring lake 28390 T/S: 03/12/2010 10:27 AM TWARD
B103 01	3/12/10	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001893973
	3/12/10	AP	T/S: 03/11/2010 10:29 AM VLBROWN
B105 01	3/17/10	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001895234
	3/17/10	AP	T/S: 03/15/2010 03:48 PM VLBROWN
R425 01	4/09/10	JH	FOUR TRADE ROUGH IN VRU #: 001907208
	4/09/10	DA	1)Nail all lvls per truss drawings. 2)Nail all 2 ply truss per truss drawings. 3)Missing A06 2 ply truss. 4)Seal under tubs & showers. 5)Missing bracing on A04 & A05 per drawings.
I129 01	4/14/10	JH	R*INSULATION INSPECTION VRU #: 001909621
	4/14/10	AP	
R325 01	4/14/10	JH	THREE TRADE ROUGH IN VRU #: 001909613
	4/14/10	AP	
H824 01	5/24/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001932219
	5/24/10	AP	T/S: 05/25/2010 10:12 AM SSTEWARD T/S: 05/25/2010 10:12 AM SSTEWARD
R429 01	6/03/10	TI	FOUR TRADE FINAL VRU #: 001935071

6-3-10 DAJB

COMMENTS AND NOTES

ADDRESS : 101 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : JS PROPERTIES #8 PHONE : (910) 551-4736
 PARCEL : 01-0513- - -0217- -08-
 APPL NUMBER: 08-50020923 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR
 LESS AND TURN ON CREEKSVILLE CHURCH RD
 TIL YOU COME TO SUBD.
 T/S: 09/15/2008 12:03 PM DJOHNSON --
 JAYLIN OAKS LOT 8
 T/S: 02/19/2010 02:14 PM RDCONTE ---
 ****SOUTH RIVER****

STRUCTURE: 000 000 84X55 3 BR NO DECKS/GARAGES/PORCHES

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001890961
	3/08/10	AP	t-pole passed
A814 01	3/12/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001893981
	3/12/10	AP	✓ T/S: 03/11/2010 10:30 AM VBROWN 101 jaylin blvd lot 8 spring lake 28390 T/S: 03/12/2010 10:27 AM TWARD
B103 01	3/12/10	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001893973
	3/12/10	AP	T/S: 03/11/2010 10:29 AM VBROWN
B105 01	3/17/10	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 001895234
	3/17/10	AP	T/S: 03/15/2010 03:48 PM VBROWN
R425 01	4/09/10	JH	FOUR TRADE ROUGH IN VRU #: 001907208
	4/09/10	DA	1)Nail all lvls per truss drawings. 2)Nail all 2 ply truss per truss drawings. 3)Missing A06 2 ply truss. 4)Seal under tubs & showers. 5)Missing bracing on A04 & A05 per drawings.
I129 01	4/14/10	JH	R*INSULATION INSPECTION VRU #: 001909621
	4/14/10	AP	
R325 01	4/14/10	JH	THREE TRADE ROUGH IN VRU #: 001909613
	4/14/10	AP	
H824 01	5/24/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001932219
	5/24/10	AP	T/S: 05/25/2010 10:12 AM SSTEWARD T/S: 05/25/2010 10:12 AM SSTEWARD
R429 01	6/03/10	JH	FOUR TRADE FINAL VRU #: 001935071
	6/03/10	DA	1)Attic insulation needs to be R38 which is 12" by the card 2)Need 24" walkway to unit in attic & 30" work space ion front of unit. 3)100 percent cover on poly under house lap joints 12"
R429 02	6/04/10	TI	FOUR TRADE FINAL VRU #: 001936012

6/4/10 APDI

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: x

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Wynn Construction

Address: 101 Jaylin Blvd
Spring Lake, NC 28390

Date: 6/4/10

Building Official: [Signature]

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: 085020923

MFG Home: _____