

-----

ADDRESS . . : 75 JAYLIN OAKS DR  
 CONTRACTOR : FAMILY HOME CONSTRUCTION  
 OWNER . . . : POMALES FAMILY INVESTMENTS  
 PARCEL . . . : 01-0513- - -0217- -19-  
 APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
 LESS AND TURN ON CREEKSVILLE CHURCH RD  
 TIL YOU COME TO SUBD.  
 T/S: 09/15/2008 12:03 PM DJOHNSON --  
 JAYLIN OAKS LOT 19

-----

STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00  
 SEPTIC - EXISTING? . . . . : NEW

PROPOSED USE . . . . . : SFD  
 WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11 <u>1-19-11</u>	TI <u>AP JH</u>	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575 T/S: 01/18/2011 01:13 PM NTART

----- COMMENTS AND NOTES -----

-----  
ADDRESS : 75 JAYLIN OAKS DR SUBDIV: JAYLIN OAKS  
CONTRACTOR : FAMILY HOME CONSTRUCTION PHONE : (910) 321-1002  
OWNER : POMALES FAMILY INVESTMENTS PHONE : (910) 987-2020  
PARCEL : 01-0513- - -0217- -19-  
APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
LESS AND TURN ON CREEKSVILLE CHURCH RD  
TIL YOU COME TO SUBD.  
T/S: 09/15/2008 12:03 PM DJOHNSON --  
JAYLIN OAKS LOT 19  
-----

-----  
**STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM**  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11 1/19/11	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575 T/S: 01/18/2011 01:13 PM NTART ----- T-pole passed -----
B101 02	1/27/11 <u>1-27-11</u>	TI <u>AA-JH</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034338
B101 01	1/27/11 1/26/11	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034072

----- COMMENTS AND NOTES -----

-----  
ADDRESS : 75 JAYLIN OAKS DR SUBDIV: JAYLIN OAKS  
CONTRACTOR : FAMILY HOME CONSTRUCTION PHONE : (910) 321-1002  
OWNER : POMALES FAMILY INVESTMENTS PHONE : (910) 987-2020  
PARCEL : 01-0513- - -0217- -19-  
APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)  
-----

DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
LESS AND TURN ON CREEKSVILLE CHURCH RD  
TIL YOU COME TO SUBD.  
T/S: 09/15/2008 12:03 PM DJOHNSON --  
JAYLIN OAKS LOT 19  
-----

STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11 1/19/11	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575 T/S: 01/18/2011 01:13 PM NTART ----- T-pole passed -----
B101 02	1/27/11 1/27/11	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034338 1)Remove stump in back left corner of footing. 2)Misssing pier footing on 2nd row from front and 3rd pier over.
B101 01	1/27/11 1/26/11	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034072
B101 03	1/28/11 <i>1-28-11</i>	TI <i>APJH</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034858

----- COMMENTS AND NOTES -----

-----

ADDRESS : 75 JAYLIN OAKS DR  
 CONTRACTOR : FAMILY HOME CONSTRUCTION  
 OWNER : POMALES FAMILY INVESTMENTS  
 PARCEL : 01-0513- - -0217- -19-  
 APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
 LESS AND TURN ON CREEKSVILLE CHURCH RD  
 TIL YOU COME TO SUBD.  
 T/S: 09/15/2008 12:03 PM DJOHNSON --  
 JAYLIN OAKS LOT 19

SUBDIV: JAYLIN OAKS  
 PHONE : (910) 321-1002  
 PHONE : (910) 987-2020

-----

**STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM**

FLOOD ZONE . . . . : FLOOD ZONE X

# BEDROOMS . . . . . : 3.00

SEPTIC - EXISTING? . . . . : NEW

PROPOSED USE . . . . . : SFD

WATER SUPPLY . . . . . : COUNTY

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11 1/19/11	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575 T/S: 01/18/2011 01:13 PM NTART ----- T-pole passed -----
B101 02	1/27/11 1/27/11	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034338 1)Remove stump in back left corner of footing. 2)Misssing pier footing on 2nd row from front and 3rd pier over.
B101 01	1/27/11 1/26/11	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034072
B101 03	1/28/11 1/28/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034858
B103 01	2/18/11 <u>2/18/11</u>	TI <u>AP DT</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 002043321

-----

COMMENTS AND NOTES -----

Harnett County

INSPECTOR: IVR

DATE 2/23/11

-----

ADDRESS . . : 75 JAYLIN OAKS DR SUBDIV: JAYLIN OAKS  
 CONTRACTOR : FAMILY HOME CONSTRUCTION PHONE : (910) 321-1002  
 OWNER . . . : POMALES FAMILY INVESTMENTS PHONE : (910) 987-2020  
 PARCEL . . . : 01-0513- - -0217- -19-  
 APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)

-----

DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
 LESS AND TURN ON CREEKSVILLE CHURCH RD  
 TIL YOU COME TO SUBD.  
 T/S: 09/15/2008 12:03 PM DJOHNSON --  
 JAYLIN OAKS LOT 19

-----

STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11 1/19/11	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575 T/S: 01/18/2011 01:13 PM NTART ----- T-pole passed -----
B101 02	1/27/11 1/27/11	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034338 1)Remove stump in back left corner of footing. 2)Misssing pier footing on 2nd row from front and 3rd pier over.
B101 01	1/27/11 1/26/11	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034072
B101 03	1/28/11 1/28/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034858 -----
B103 01	2/18/11 2/21/11	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002043321
B105 01	2/23/11	TI	R*OPEN FLOOR VRU #: 002044089

*2-23-11 AP TB*

----- COMMENTS AND NOTES -----

ADDRESS . : 75 JAYLIN OAKS DR SUBDIV: JAYLIN OAKS  
 CONTRACTOR : FAMILY HOME CONSTRUCTION PHONE : (910) 321-1002  
 OWNER . . : POMALES FAMILY INVESTMENTS PHONE : (910) 987-2020  
 PARCEL . . : 01-0513- - -0217- -19-  
 APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
 LESS AND TURN ON CREEKSVILLE CHURCH RD  
 TIL YOU COME TO SUBD.  
 T/S: 09/15/2008 12:03 PM DJOHNSON --  
 JAYLIN OAKS LOT 19

**STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM**  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575
	1/19/11	AP	T/S: 01/18/2011 01:13 PM NTART ----- T-pole passed -----
B101 02	1/27/11	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034338
	1/27/11	DA	1)Remove stump in back left corner of footing. 2)Misssing pier footing on 2nd row from front and 3rd pier over.
B101 01	1/27/11	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034072
	1/26/11	CA	
B101 03	1/28/11	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034858
	1/28/11	AP	-----
B103 01	2/18/11	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002043321
	2/21/11	AP	
B105 01	2/23/11	JH	R*OPEN FLOOR VRU #: 002044089
	2/23/11	AP	-----
R425 01	3/23/11	TI	FOUR TRADE ROUGH IN VRU #: 002057453

*3-23-11 DAJH*

COMMENTS AND NOTES

ADDRESS : 75 JAYLIN OAKS DR  
 CONTRACTOR : FAMILY HOME CONSTRUCTION  
 OWNER : POMALES FAMILY INVESTMENTS  
 PARCEL : 01-0513- - -0217- -19-  
 APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
 LESS AND TURN ON CREEKSVILLE CHURCH RD  
 TIL YOU COME TO SUBD.  
 T/S: 09/15/2008 12:03 PM DJOHNSON --  
 JAYLIN OAKS LOT 19

SUBDIV: JAYLIN OAKS  
 PHONE : (910) 321-1002  
 PHONE : (910) 987-2020

STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00  
 SEPTIC - EXISTING? : NEW  
 PROPOSED USE : SFD  
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575
	1/19/11	AP	T/S: 01/18/2011 01:13 PM NTART T-pole passed
B101 02	1/27/11	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034338
	1/27/11	DA	1)Remove stump in back left corner of footing. 2)Missing pier footing on 2nd row from front and 3rd pier over.
B101 01	1/27/11	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034072
	1/26/11	CA	
B101 03	1/28/11	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034858
	1/28/11	AP	
B103 01	2/18/11	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002043321
	2/21/11	AP	
B105 01	2/23/11	JH	R*OPEN FLOOR VRU #: 002044089
	2/23/11	AP	
R425 01	3/23/11	JH	FOUR TRADE ROUGH IN VRU #: 002057453
	3/23/11	DA	1)No baffels. 2)Repair letter for damaged lvl @ single garage door. 3)Missing anchor bolt to left of rear door in garage. 4)3' head of water on drain lines.
R425 02	3/28/11	TI	FOUR TRADE ROUGH IN VRU #: 002059442
	<u>3/28/11</u>	<u>AP DT</u>	

COMMENTS AND NOTES

ADDRESS : 75 JAYLIN OAKS DR SUBDIV: JAYLIN OAKS  
 CONTRACTOR : FAMILY HOME CONSTRUCTION PHONE : (910) 321-1002  
 OWNER : POMALES FAMILY INVESTMENTS PHONE : (910) 987-2020  
 PARCEL : 01-0513- - -0217- -19-  
 APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
 LESS AND TURN ON CREEKSVILLE CHURCH RD  
 TIL YOU COME TO SUBD.  
 T/S: 09/15/2008 12:03 PM DJOHNSON --  
 JAYLIN OAKS LOT 19

STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11 1/19/11	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575 T/S: 01/18/2011 01:13 PM NTART ----- T-pole passed -----
B101 02	1/27/11 1/27/11	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034338 1)Remove stump in back left corner of footing. 2)Misssing pier footing on 2nd row from front and 3rd pier over.
B101 01	1/27/11 1/26/11	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034072
B101 03	1/28/11 1/28/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034858
B103 01	2/18/11 2/21/11	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002043321
B105 01	2/23/11 2/23/11	JH AP	R*OPEN FLOOR VRU #: 002044089
R425 01	3/23/11 3/23/11	JH DA	FOUR TRADE ROUGH IN VRU #: 002057453 1)No baffels. 2)Repair letter for damaged lvl @ single garage door. 3)Missing anchor bolt to left of rear door in garage. 4)3' head of water on drain lines.
R425 02	3/28/11 3/28/11	DT AP	FOUR TRADE ROUGH IN VRU #: 002059442
A814 01	4/04/11 4/07/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002061844 75 jaylin oaks dr lot 19 spring lake 28390---- T/S: 04/07/2011 11:45 AM TWARD -----
I129 01	4/11/11 <u>4-11-11</u>	TI <u>APJW</u>	R*INSULATION INSPECTION VRU #: 002064939

COMMENTS AND NOTES



ADDRESS : 75 JAYLIN OAKS DR  
 CONTRACTOR : FAMILY HOME CONSTRUCTION  
 OWNER : POMALES FAMILY INVESTMENTS  
 PARCEL : 01-0513- - -0217- -19-  
 APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
 LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
 LESS AND TURN ON CREEKSVILLE CHURCH RD  
 TIL YOU COME TO SUBD.  
 T/S: 09/15/2008 12:03 PM DJOHNSON --  
 JAYLIN OAKS LOT 19

SUBDIV: JAYLIN OAKS  
 PHONE : (910) 321-1002  
 PHONE : (910) 987-2020

STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00  
 SEPTIC - EXISTING? : NEW  
 PROPOSED USE : SFD  
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11 1/19/11	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575 T/S: 01/18/2011 01:13 PM NTART T-pole passed
B101 02	1/27/11 1/27/11	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034338 1)Remove stump in back left corner of footing. 2)Misssing pier footing on 2nd row from front and 3rd pier over.
B101 01	1/27/11 1/26/11	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034072
B101 03	1/28/11 1/28/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034858
B103 01	2/18/11 2/21/11	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002043321
B105 01	2/23/11 2/23/11	JH AP	R*OPEN FLOOR VRU #: 002044089
R425 01	3/23/11 3/23/11	JH DA	FOUR TRADE ROUGH IN VRU #: 002057453 1)No baffels. 2)Repair letter for damaged lvl @ single garage door. 3)Missing anchor bolt to left of rear door in garage. 4)3' head of water on drain lines.
R425 02	3/28/11 3/28/11	DT AP	FOUR TRADE ROUGH IN VRU #: 002059442
A814 01	4/04/11 4/07/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002061844 ✓ 75 jaylin oaks dr lot 19 spring lake 28390---- T/S: 04/07/2011 11:45 AM TWARD
I129 01	4/11/11 4/11/11	JH AP	R*INSULATION INSPECTION VRU #: 002064939
H824 01	5/18/11 5/18/11	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002083194 T/S: 05/19/2011 11:20 AM SZIMMER T/S: 05/19/2011 11:20 AM SZIMMER
R431 01	6/10/11 <i>6-10-11</i>	TI <i>DPJH</i>	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002091569 T/S: 06/08/2011 02:21 PM VBROWN

COMMENTS AND NOTES

ADDRESS : 75 JAYLIN OAKS DR SUBDIV: JAYLIN OAKS  
CONTRACTOR : FAMILY HOME CONSTRUCTION PHONE : (910) 321-1002  
OWNER : POMALES FAMILY INVESTMENTS PHONE : (910) 987-2020  
PARCEL : 01-0513- - -0217- -19-  
APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 210 TOWARDS FAYETTEVILLE, TURN RIGHT AT  
LIGHT ONTO RAY RD, GO DOWN 1 MILES OR  
LESS AND TURN ON CREEKSVILLE CHURCH RD  
TIL YOU COME TO SUBD.  
T/S: 09/15/2008 12:03 PM DJOHNSON --  
JAYLIN OAKS LOT 19

STRUCTURE: 000 000 52X48 CRAWL 3BD/2BA W/GAR & FIN BN RM  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/19/11 1/19/11	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002030575 T/S: 01/18/2011 01:13 PM NTART ----- T-pole passed -----
B101 02	1/27/11 1/27/11	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034338 1)Remove stump in back left corner of footing. 2)Missing pier footing on 2nd row from front and 3rd pier over.
B101 01	1/27/11 1/26/11	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034072
B101 03	1/28/11 1/28/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002034858
B103 01	2/18/11 2/21/11	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002043321
B105 01	2/23/11 2/23/11	JH AP	R*OPEN FLOOR VRU #: 002044089
R425 01	3/23/11 3/23/11	JH DA	FOUR TRADE ROUGH IN VRU #: 002057453 1)No baffels. 2)Repair letter for damaged lvl @ single garage door. 3)Missing anchor bolt to left of rear door in garage. 4)3' head of water on drain lines.
R425 02	3/28/11 3/28/11	DT AP	FOUR TRADE ROUGH IN VRU #: 002059442
A814 01	4/04/11 4/07/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002061844 ✓75 jaylin oaks dr lot 19 spring lake 28390----- T/S: 04/07/2011 11:45 AM TWARD -----
I129 01	4/11/11 4/11/11	JH AP	R*INSULATION INSPECTION VRU #: 002064939
H824 01	5/18/11 5/18/11	OT AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002083194 T/S: 05/19/2011 11:20 AM SZIMMER ----- T/S: 05/19/2011 11:20 AM SZIMMER -----
R431 01	6/10/11 6/10/11	JH DP	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002091569 T/S: 06/08/2011 02:21 PM VBROWN ----- ✓Cover for fan in spare bathroom. ✓Toilets need to be caulked. ✓Receptacles in 2 front bedrooms over 12' they should be covered up. ✓Missing ground wire, ground rods & grounding bar for cable & phone. ✓Missing wood under back door. ✓Nail supports 2x8s for deck steps under deck.

ADDRESS : 75 JAYLIN OAKS DR  
CONTRACTOR : FAMILY HOME CONSTRUCTION  
OWNER : POMALES FAMILY INVESTMENTS  
PARCEL : 01-0513- - -0217- -19-  
APPL NUMBER: 08-50020933 CP NEW RESIDENTIAL (SFD)

SUBDIV: JAYLIN OAKS  
PHONE : (910) 321-1002  
PHONE : (910) 987-2020

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R431 02	6/13/11 <i>6-13-11</i>	TI <i>APJH</i>	<ul style="list-style-type: none"> <li>Need receptacle on back of house accessible from grade.</li> <li>Need carbon monoxide detectors per code.</li> </ul> FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002093573 T/S: 06/10/2011 02:02 PM NTART -----

----- COMMENTS AND NOTES -----

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance: \_\_\_ Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

**Permit Numbers**

Name: Family Home Construction

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Address: 75 Taylor Oaks Dr

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

Date: 6-13-11

Building Official: \_\_\_\_\_

[Signature]

08-500-20935