

HTE# 08-500-20938

Harnett County Department of Public Health

25067

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Bill Clark Homes PROPERTY LOCATION: 1139
 SUBDIVISION: Patton Point LOT # 106
 NEW REPAIR EXPANSION
 Type of Structure: SFD 52x32-43R Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% Reduction system
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 100 feet Permit valid for: Five years
 Permit conditions: Meet code - maintain all at back No expiration
STUB out plumbing shallow at ground level or higher where shown

Authorized State Agent: Joe W. R. Date: 10-07-08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Bill Clark Homes PROPERTY LOCATION: 1139
 SUBDIVISION: Patton Point LOT # 106
 Facility Type: SFD 52x32-43R New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction system (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable) 25% Reduction system (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Number of trenches 1
 Pump Tank Size _____ gallons Exact length of each trench 180 feet Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/- 1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 Conditions: _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Joe W. R. Date: 10-07-08
 Construction Authorization Expiration Date: 10-07-2017

HTE# 08-50-20934

Permit # 25067

Harnett County Department of Public Health Site Sketch

ISSUED TO: Bill Clark Home


PROPERTY LOCATOR: 1137

SUBDIVISION: Pattern Point

LOT # 106

Authorized State Agent: [Signature]

Date: 10-07-08



Meet on site
 MAINTAIN ALL SETBACKS
 STUB OUT PLUMBING
 SHALLOW AT GROUND LEVEL
 OR HIGHER WHERE SHOWN
 INSTALL 180° + 90° REDUCTION
 SYSTEM AT 18" TO 24"