

March 24, 2009

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Alicia W Shytle
8352 Old US 421
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

RE: Harnett County Land Use Application #08-5-20991R

Dear Ms. Shytle,

The Harnett County Department of Public Health, Environmental Health Division on March 23, 2009, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your revision. According to your application requesting a barn, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for a revision is **DENIED**. The site is denied based on the following:

_____ 15A NCAC 18A.1950 a (16) Any swimming pool must be 15' from any part of septic system.


 X 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area.

 X 15A NCAC 18A.1950 (10) – Any building to be 5' from drain line.

The barn is in the middle of proposed septic area (see attached permit). The area is marked by the blue flags placed on site. You have the option to move the barn out of the septic and repair area.

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,



Joe West, R.S.
Environmental Health Specialist
Harnett County Department of Public Health

JW/sgs

HTE# 08505-2011

Harnett County Department of Public Health Site Sketch

Permit # 25078

ISSUED TO: Jessica & Freddy Gallegos


PROPERTY LOCATOR: Old 421

SUBDIVISION Alicia W. SHYTLER LOT # 2
9.2

Authorized State Agent: J. [Signature]

Date: 10.22.24

Wood Line is approx Rear Property Line



Site LTAR

Others Present:

Front Driveway