

PREPARED: 5/05/10, 13:58:24
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 3
DATE 5/06/10

ADDRESS : 569 OMAHA DR SUBDIV: TINGEN POINTE 86LOTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER : THE HARNETT LAND GROUP II LLC PHONE :
PARCEL : 03-9576- - -0088- -62-
APPL NUMBER: 08-50021031 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
HARNETT HIGH SCHOOL LOT 62 JB

STRUCTURE: 000 000 49X59 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	5/06/10	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001921371
	<i>5-6-10</i>	<i>AP-MR</i>	

----- COMMENTS AND NOTES -----

56109038

ADDRESS : 569 OMAHA DR
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER : THE HARNETT LAND GROUP II LLC
 PARCEL : 03-9576- - -0088- -62-
 APPL NUMBER: 08-50021031 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
 HARNETT HIGH SCHOOL LOT 62 JB

SUBDIV: TINGEN POINTE 86LOTS
 PHONE : (919) 528-1347
 PHONE :

STRUCTURE: 000 000 49X59 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001921371
	5/06/10	AP	T/S: 05/06/2010 01:03 PM MREARIC -----
B103 01	5/13/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001925420
	<i>5-13-10</i>	<i>AP MR</i>	

COMMENTS AND NOTES

ADDRESS : 569 OMAHA DR
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576- - -0088- -62-
APPL NUMBER: 08-50021031 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
HARNETT HIGH SCHOOL LOT 62 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 49X59 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001921371
	5/06/10	AP	T/S: 05/06/2010 01:03 PM MREARIC -----
B103 01	5/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001925420
	5/13/10	AP	T/S: 05/13/2010 11:56 AM MREARIC -----
B105 01	5/14/10	TI	R*OPEN FLOOR VRU #: 001926198
	<u>5-14-10</u>	<u>AP-MR</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 569 OMAHA DR
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576- - -0088- -62-
APPL NUMBER: 08-50021031 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
HARNETT HIGH SCHOOL LOT 62 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 49X59 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001921371
	5/06/10	AP	T/S: 05/06/2010 01:03 PM MREARIC -----
B103 01	5/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001925420
	5/13/10	AP	T/S: 05/13/2010 11:56 AM MREARIC -----
B105 01	5/14/10	MR	R*OPEN FLOOR VRU #: 001926198
	5/14/10	AP	T/S: 05/14/2010 01:31 PM MREARIC -----
A814 01	5/18/10	FB	ADDRESS CONFIRMATION VRU #: 001925439
	5/13/10	AP	T/S: 05/13/2010 11:03 AM FBURGESS ----- 569 OMAHA DR BROADWAY, NC 27505 LOT 62
R425 01	6/08/10	TI	FOUR TRADE ROUGH IN VRU #: 001937355

6-8-10 DA-MR

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 06-08-10

PERMIT # 08-50021031

ADDRESS: 569 omaha.

VIOLATIONS:

1. Check multi-lam beam across garage for correct nail or bolt pattern
2. Fireblock at fireplace
3. Ok to insulate and side

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 569 OMAHA DR SUBDIV: TINGEN POINTE 86LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL : 03-9576- - -0088- -62-
 APPL NUMBER: 08-50021031 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
 HARNETT HIGH SCHOOL LOT 62 JB

STRUCTURE: 000 000 49X59 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001921371
	5/06/10	AP	T/S: 05/06/2010 01:03 PM MREARIC -----
B103 01	5/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001925420
	5/13/10	AP	T/S: 05/13/2010 11:56 AM MREARIC -----
B105 01	5/14/10	MR	R*OPEN FLOOR VRU #: 001926198
	5/14/10	AP	T/S: 05/14/2010 01:31 PM MREARIC -----
A814 01	5/18/10	FB	ADDRESS CONFIRMATION VRU #: 001925439
	5/13/10	AP	T/S: 05/13/2010 11:03 AM FBURGESS ----- 569 OMAHA DR BROADWAY, NC 27505 LOT 62
R425 01	6/08/10	MR	FOUR TRADE ROUGH IN VRU #: 001937355
	6/08/10	DA	T/S: 06/08/2010 12:35 PM MREARIC ----- 1. check nailing or bolting of lam beam over garage 2. fireblock at fireplace 3. ok to side and insul.
I129 01	6/10/10	TI	R*INSULATION INSPECTION VRU #: 001938880
	<u>6-10-10</u>	<u>AP-MR</u>	
R425 02	6/10/10	TI	FOUR TRADE ROUGH IN VRU #: 001938871
	<u>6-10-10</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS : 569 OMAHA DR
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER : THE HARNETT LAND GROUP II LLC
 PARCEL : 03-9576- - -0088- -62-
 APPL NUMBER: 08-50021031 CP NEW RESIDENTIAL (SFD)

SUBDIV: TINGEN POINTE 86LOTS
 PHONE : (919) 528-1347
 PHONE :

DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
 HARNETT HIGH SCHOOL LOT 62 JB

STRUCTURE: 000 000 49X59 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW TANK
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001921371
	5/06/10	AP	T/S: 05/06/2010 01:03 PM MREARIC -----
B103 01	5/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001925420
	5/13/10	AP	T/S: 05/13/2010 11:56 AM MREARIC -----
B105 01	5/14/10	MR	R*OPEN FLOOR VRU #: 001926198
	5/14/10	AP	T/S: 05/14/2010 01:31 PM MREARIC -----
A814 01	5/18/10	FB	ADDRESS CONFIRMATION VRU #: 001925439
	5/13/10	AP	T/S: 05/13/2010 11:03 AM FBURGESS -----
R425 01	6/08/10	MR	✓ 569 OMAHA DR BROADWAY, NC 27505 LOT 62
	6/08/10	DA	FOUR TRADE ROUGH IN VRU #: 001937355
			T/S: 06/08/2010 12:35 PM MREARIC -----
			1. check nailing or bolting of lam beam over garage
			2. fireblock at fireplace
			3. ok to side and insul.
I129 01	6/10/10	MR	R*INSULATION INSPECTION VRU #: 001938880
	6/10/10	AP	T/S: 06/10/2010 11:59 AM MREARIC -----
R425 02	6/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001938871
	6/10/10	AP	T/S: 06/10/2010 11:59 AM MREARIC -----
H824 01	6/23/10	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001946557
	6/23/10	AP	T/S: 06/25/2010 10:15 AM SSTEWARD -----
			T/S: 06/25/2010 10:16 AM SSTEWARD -----
R429 01	7/20/10	TI	FOUR TRADE FINAL VRU #: 001956459

7-20-10 AP-MR

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: Harnett Land Group II, LLC

Building: 08-50021031

Address: 569 Omaha Dr.

Electrical: 1

Insulation: 1

Plumbing: 1

Mechanical: 1

MFG Home: _____

Date: 7-20-10

Building Official: M. Michael Reavis

56109038