

ADDRESS : 591 OMAHA DR SUBDIV: TINGEN POINTE 86LOTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER : THE HARNETT LAND GROUP II LLC PHONE :
PARCEL : 03-9576- - -0088- -63-
APPL NUMBER: 08-50021032 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
HARNETT HIGH SCHOOL LOT 63 JB

STRUCTURE: 000 000 50X50 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10 <u>4-8-10</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001906569 T/S: 04/07/2010 01:04 PM JBROCK -----

COMMENTS AND NOTES

87113849

3697955

1 Anna 4/10

ADDRESS : 591 OMAHA DR
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576- - -0088- -63-
APPL NUMBER: 08-50021032 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
HARNETT HIGH SCHOOL LOT 63 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 50X50 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001906569
	4/08/10	AP	T/S: 04/07/2010 01:04 PM JBROCK T/S: 04/08/2010 12:55 PM MREARIC
B103 01	4/13/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001908840
	<u>9-17-10</u>	<u>AP-IVR</u>	

COMMENTS AND NOTES

ADDRESS : 591 OMAHA DR
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576- - -0088- -63-
APPL NUMBER: 08-50021032 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
HARNETT HIGH SCHOOL LOT 63 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 50X50 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001906569
	4/08/10	AP	T/S: 04/07/2010 01:04 PM JBROCK ----- T/S: 04/08/2010 12:55 PM MREARIC -----
B103 01	4/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001908840
	4/13/10	AP	T/S: 04/13/2010 01:15 PM MREARIC -----
B105 01	4/20/10	TI	R*OPEN FLOOR VRU #: 001912693
	<u>4-20-10</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS : 591 OMAHA DR
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576- - -0088- -63-
APPL NUMBER: 08-50021032 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
HARNETT HIGH SCHOOL LOT 63 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 50X50 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001906569
	4/08/10	AP	T/S: 04/07/2010 01:04 PM JBROCK T/S: 04/08/2010 12:55 PM MREARIC
B103 01	4/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001908840
	4/13/10	AP	T/S: 04/13/2010 01:15 PM MREARIC
B105 01	4/20/10	MR	R*OPEN FLOOR VRU #: 001912693
	4/20/10	AP	T/S: 04/20/2010 12:18 PM MREARIC
A814 01	5/07/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919767
	5/04/10	AP	591 OMAHA DR LOT 63 BROADWAY 27505 T/S: 05/04/2010 09:23 AM TWARD
R425 01	5/10/10	TI	FOUR TRADE ROUGH IN VRU #: 001922851
	<u>5-10-10</u>	<u>DA-MR</u>	

COMMENTS AND NOTES

Provide enqing on garage beam and bolt pattern

ADDRESS : 591 OMAHA DR SUBDIV: TINGEN POINTE 86LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL : 03-9576- - -0088- -63-
 APPL NUMBER: 08-50021032 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
 HARNETT HIGH SCHOOL LOT 63 JB

STRUCTURE: 000 000 50X50 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001906569
	4/08/10	AP	T/S: 04/07/2010 01:04 PM JBROCK ----- T/S: 04/08/2010 12:55 PM MREARIC -----
B103 01	4/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001908840
	4/13/10	AP	T/S: 04/13/2010 01:15 PM MREARIC -----
B105 01	4/20/10	MR	R*OPEN FLOOR VRU #: 001912693
	4/20/10	AP	T/S: 04/20/2010 12:18 PM MREARIC -----
A814 01	5/07/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919767
	5/04/10	AP	591 OMAHA DR LOT 63 ----- BROADWAY 27505 T/S: 05/04/2010 09:23 AM TWARD -----
R425 01	5/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001922851
	5/10/10	DA	T/S: 05/10/2010 11:16 AM MREARIC ----- 1. provide eng. letter or info on garage beam and the bolt pattern
R425 02	5/14/10	TI	FOUR TRADE ROUGH IN VRU #: 001926214
	5-14-10	AP-MR	

COMMENTS AND NOTES

Mark E. Jones, PE
Structural Engineering and Design

May 5, 2010

Wynn Construction
2550 Capitol Drive, Suite 105
Creedmoor, NC 27522
Ph: (919) 528-1347
Fax: (919) 528-4145

Ref: Plan clarification
The Lily Plan
Project No. 08-183

To Whom it may concern;

The above referenced plan was reviewed on May 5, 2010 to address the following structural condition(s):

1. Plan clarification for connection of 4-ply LVL beam.


Based on analysis, the conclusions regarding the condition(s) are:

1. The 4-ply LVL beam above the garage shall be connected with ½" diameter through bolts at 24" on center, staggered.

Thank you for this opportunity to assist you. If you have any questions or need any further assistance, please do not hesitate to call.

Respectfully,

Mark E. Jones, PE



ADDRESS : 591 OMAHA DR SUBDIV: TINGEN POINTE 86LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL : 03-9576- - -0088- -63-
 APPL NUMBER: 08-50021032 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
 HARNETT HIGH SCHOOL LOT 63 JB

STRUCTURE: 000 000 50X50 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001906569
	4/08/10	AP	T/S: 04/07/2010 01:04 PM JBROCK ----- T/S: 04/08/2010 12:55 PM MREARIC -----
B103 01	4/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001908840
	4/13/10	AP	T/S: 04/13/2010 01:15 PM MREARIC -----
B105 01	4/20/10	MR	R*OPEN FLOOR VRU #: 001912693
	4/20/10	AP	T/S: 04/20/2010 12:18 PM MREARIC -----
A814 01	5/07/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919767
	5/04/10	AP	591 OMAHA DR LOT 63 ----- BROADWAY 27505 T/S: 05/04/2010 09:23 AM TWARD -----
R425 01	5/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001922851
	5/10/10	DA	T/S: 05/10/2010 11:16 AM MREARIC ----- 1. provide eng. letter or info on garage beam and the bolt pattern
R425 02	5/14/10	MR	FOUR TRADE ROUGH IN VRU #: 001926214
	5/14/10	AP	T/S: 05/14/2010 01:31 PM MREARIC -----
I129 01	5/18/10	TI	R*INSULATION INSPECTION VRU #: 001927874

5-18-10 AP-MR

COMMENTS AND NOTES

ADDRESS . . : 591 OMAHA DR SUBDIV: TINGEN POINTE 86LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . . : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL . . . : 03-9576- - -0088- -63-
 APPL NUMBER: 08-50021032 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
 HARNETT HIGH SCHOOL LOT 63 JB

STRUCTURE: 000 000 50X50 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001906569
	4/08/10	AP	T/S: 04/07/2010 01:04 PM JBROCK ----- T/S: 04/08/2010 12:55 PM MREARIC -----
B103 01	4/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001908840
	4/13/10	AP	T/S: 04/13/2010 01:15 PM MREARIC -----
B105 01	4/20/10	MR	R*OPEN FLOOR VRU #: 001912693
	4/20/10	AP	T/S: 04/20/2010 12:18 PM MREARIC -----
A814 01	5/07/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919767
	5/04/10	AP	591 OMAHA DR LOT 63 ----- BROADWAY 27505 T/S: 05/04/2010 09:23 AM TWARD -----
R425 01	5/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001922851
	5/10/10	DA	T/S: 05/10/2010 11:16 AM MREARIC ----- 1. provide eng. letter or info on garage beam and the bolt pattern
R425 02	5/14/10	MR	FOUR TRADE ROUGH IN VRU #: 001926214
	5/14/10	AP	T/S: 05/14/2010 01:31 PM MREARIC -----
I129 01	5/18/10	MR	R*INSULATION INSPECTION VRU #: 001927874
	5/18/10	AP	T/S: 05/18/2010 12:23 PM MREARIC -----
H824 01	5/19/10	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001930015
	5/19/10	AP	T/S: 05/20/2010 10:20 AM SSTEWARD ----- T/S: 05/20/2010 10:20 AM SSTEWARD -----
R429 01	7/16/10	TI	FOUR TRADE FINAL VRU #: 001955156

7-16-10 DP-MR

COMMENTS AND NOTES

Finish AC Ducts

ADDRESS : 591 OMAHA DR
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576- - -0088- -63-
APPL NUMBER: 08-50021032 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TO S/D 3 MILES PAST WESTERN
HARNETT HIGH SCHOOL LOT 63 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 50X50 3BDR CRAWL W/ GARAGE NO DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001906569
	4/08/10	AP	T/S: 04/07/2010 01:04 PM JBROCK ----- T/S: 04/08/2010 12:55 PM MREARIC -----
B103 01	4/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001908840
	4/13/10	AP	T/S: 04/13/2010 01:15 PM MREARIC -----
B105 01	4/20/10	MR	R*OPEN FLOOR VRU #: 001912693
	4/20/10	AP	T/S: 04/20/2010 12:18 PM MREARIC -----
A814 01	5/07/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001919767
	5/04/10	AP	✓ 591 OMAHA DR LOT 63 ----- BROADWAY 27505 T/S: 05/04/2010 09:23 AM TWARD -----
R425 01	5/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001922851
	5/10/10	DA	T/S: 05/10/2010 11:16 AM MREARIC ----- 1. provide eng. letter or info on garage beam and the bolt pattern
R425 02	5/14/10	MR	FOUR TRADE ROUGH IN VRU #: 001926214
	5/14/10	AP	T/S: 05/14/2010 01:31 PM MREARIC -----
I129 01	5/18/10	MR	R*INSULATION INSPECTION VRU #: 001927874
	5/18/10	AP	T/S: 05/18/2010 12:23 PM MREARIC -----
H824 01	5/19/10	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001930015
	5/19/10	AP	T/S: 05/20/2010 10:20 AM SSTEWARD ----- T/S: 05/20/2010 10:20 AM SSTEWARD -----
R429 01	7/16/10	MR	FOUR TRADE FINAL VRU #: 001955156
	7/16/10	DP	T/S: 07/16/2010 01:49 PM NTART ----- T/S: 07/16/2010 01:55 PM MREARIC ----- finish ducts
R429 02	7/19/10	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001956168
	7-19-10	AP-MR	T/S: 07/16/2010 01:52 PM NTART -----

COMMENTS AND NOTES

87113849

1
2
3

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Name: Wynn Const.

Address: 591 Omaha

Date: 7-19-10

Permit Numbers

Building: 08-50021032

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: "

MFG Home: _____

Building Official: T. Michel Ream