

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: 08-502-21102

Applicant:

Address:

Date Evaluated:

Proposed Facility: SFD

Design Flow (.1949): 360

Property Size:

Location of Site: 1229

Property Recorded:

Water Supply:  Public  Individual  Well

Spring  Other

Evaluation Method:  Auger Boring  Pit

Cut

Type of Wastewater:  Sewage  Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
S 2%		6-32	GR SL	VFR SE					.5
		72-40	SOH SCL	FR SE					
		0-28	GR SL	VFR SE					.5
		28-40	SOH SCL	FR SE					
		0-30	GR SL	VFR SE					.5
		30-40	SOH SCL	FR SE					
		0-30	GR SL	VFR SE					.5
		30-40	SOH SCL	FR SE					
		0-28	GR SL	VFR SE					.5
		28-38	SOH SCL	FR SE					

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	25-1	25-1
Site LTAR	.5	.5

Other Factors (.1946):  
 Site Classification (.1948): P  
 Evaluated By: [Signature]  
 Others Present:  
 May be repaired if 18-24" depth

At 18 to 24