

Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 12/3/07

Proposed Facility: 4 BEDROOM HOME Design Flow (.1949): 400 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public [] Individual [] Well [] Spring [] Other
 Evaluation Method: Auger Boring [] Pit [] Cut
 Type of Wastewater: Sewage [] Industrial Process [] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	0-2%	0-3"	FILL						PS .55
		3-52"	SBK SCL	FL SS/MP					
2		0-5"	FILL						PS .5
		5-30"	SBK SCL	FL SS/MP	10x2 7/2 @ 30"				
3		0-3"	FILL						PS .55
		3-56"	SBK SCL	FL SS/MP					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CANY.	LPR
Site LTAR	.55	.55 .5

Other Factors (.1946): _____

Site Classification (.1948): PS

Evaluated By: OT

Others Present: _____