

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:
 Address:
 Proposed Facility: 3 Bedroom Home Design Flow (.1949): 360 gpd
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant:
 Date Evaluated: 12/8/09
 Property Size:
 Property Recorded:
 Spring Other
 Cut
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2%	0-16	G SL	VFR 15/NP					PS .55
		16-48	S&K SCL	FR S/NP	10R 7/2 C 39"				
2		0-16	G SL	VFR 15/NP					PS .5
		16-39	S&K SCL	FR S/NP					
		39-48	G S	VFR 15/NP					

Description	Initial System	Repair System
Available Space (.1945)	CON ✓	✓
System Type(s)	CON	CON CON
Site LTAR	.55	.5

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: OK
 Others Present: -

1 x 220' c 24"