

HTE# 08-500-21308

Harnett County Department of Public Health

25213

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cumberland Homes
PROPERTY LOCATION: NC 27
SUBDIVISION: Laurel Valley
LOT #: 55
Type of Structure: SFD- 52x43- 4BR
Proposed Wastewater System Type: Pump to 25% Reduction Sys.
Projected Daily Flow: 480 GPD
Number of bedrooms: 4 Number of Occupants: 8 max
Basement: No
Pump Required: Yes
Type of Water Supply: Public
Permit conditions: Meet on site for final layout maintain all setbacks

Authorized State Agent: J. Waters Date: 12-4-08 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: Cumberland Homes
PROPERTY LOCATION: NC 27
SUBDIVISION: Laurel Valley
LOT #: 55
Facility Type: SFD- 52x43- 4BR
Type of Wastewater System: Pump to 25% Reduction System
(See note below, if applicable) LPP Repair (Repair)

Installation Requirements/Conditions
Septic Tank Size: 1000 gallons
Pump Tank Size: 1000 gallons
Number of trenches: 1
Exact length of each trench: 300 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 6 inches
Maximum Trench Depth: 18 inches
Pump Requirements: _____ ft. TDH vs. _____ GPM
Aggregate Depth: _____ inches below pipe
_____ inches above pipe
_____ inches total

*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: J. Waters Date: 12.4.08
Construction Authorization Expiration Date: 12.4.2013

HTE# 08-500-21308

Permit # 25213

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cumberland Homes PROPERTY LOCATOR: N127
SUBDIVISION: Laurel Valley LOT # 55

Authorized State Agent: Ju WA (2) Date: 12-7-08

Meet on site for Final Layout
MAINTAIN ALL SETBACKS

Install 300' + 25% Reduction
System at 18"

