

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: *08500 21308*

Applicant:

Address:

Date Evaluated:

Proposed Facility: *SFO*

Design Flow (.1949): *48*

Property Size:

Location of Site: *N127*

Property Recorded:

Water Supply: Public Individual Well Spring Other

Evaluation Method: Auger Boring Pit Cut

Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	
1	<i>5</i>	<i>0-38</i>	<i>GR SL</i>	<i>VFA J=</i>					<i>.6</i>
2	<i>33</i>	<i>0-30</i>	<i>GR SL</i>	<i>VFA J=</i>					<i>.6</i>
3		<i>0-30</i>	<i>GR SL</i>	<i>VFA J=</i>					<i>.6</i>
4		<i>0-30</i>	<i>GR SL</i>	<i>VFA J=</i>					<i>.5</i>
		<i>30-36</i>	<i>SOU SCL</i>	<i>FA J=</i>					
5		<i>0-24</i>	<i>GR SL</i>	<i>VFA J=</i>					
		<i>24-36</i>	<i>SOU SCL</i>	<i>FA J=</i>					<i>.4</i>
		<i>36-30</i>	<i>SOU SCL</i>	<i>FE J=</i>					
6		<i>0-24</i>	<i>GR SL</i>	<i>VFA J=</i>					
		<i>24-36</i>	<i>SOU SCL</i>	<i>FA J=</i>					<i>.4</i>
		<i>36-30</i>	<i>SOU SL</i>	<i>FE J=</i>					
7	<i>18</i>	<i>0-18</i>	<i>GR SL</i>	<i>VFA J=</i>					
		<i>18-36</i>	<i>SOU SCL</i>	<i>FA J=</i>					
		<i>26-36</i>	<i>SOU SL</i>	<i>FE J=</i>					

Description	Initial System	Repair System
Available Space (.1945)	<i>—</i>	<i>✓</i>
System Type(s)	<i>25</i>	<i>200</i>
Site LTAR	<i>.4</i>	<i>.2</i>

Other Factors (.1946): _____
 Site Classification (.1948): *P1*
 Evaluated By: *gwa*
 Others Present: